



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

**Melbourne Assesment Prison**  
317 Spencer Street West Melbourne  
Contract No: CBC

## Callouts: 22368

Date of Call: 22-11-2018 13:47:30  
Time of Arrival: 23-11-2018 8:15:00  
Rectification Time: 23-11-2018 10:10:00  
Time of Departure: 23-11-2018 10:15:00

### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** O.O.O

**For Lift(s):** 2

**For Floor(s):** g

**Call Description:** Lift has stopped and is now 100mm above level

**Order Number:** 4281431

### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** See Work description

**Work Description:** reported lift 2 not levelling checked control circuit replaced sh2 bridging contacts \r\nreplaced RKUET1 relay checked operation ok.

**Part Required:** 31z relay

**Service Technician**

Robert Pelle

**Report Customer**

Peter 93284977