

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:

Metro Laverton

Metro Laverton Station Laverton

Contract No: P3587

Callouts: 22474

Date of Call: 04-12-2018 9:11:00 Time of Arrival: 04-12-2018 9:30:00 Rectification Time: 04-12-2018 10:30:00 Time of Departure: 04-12-2018 11:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): Lift 4

For Floor(s): concourse

Call Description: lift 4 doors open stuck on top

Order Number: 02AA602703

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Doors forced open air cord bracket broken on car re connect and tune car doors

Part Required: No Parts Required

Service Technician Report Customer

Phil Dodsworth yes