



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

Maroondah Hwy 92  
92 Maroondah Highway Ringwood  
Contract No: P3764

## Callouts:

Date of Call: 16-11-2018 16:00:00  
Time of Arrival: 16-11-2018 16:40:00  
Rectification Time: 16-11-2018 18:20:00  
Time of Departure: 16-11-2018 18:30:00

### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** O.O.O

**For Lift(s):** 2

**For Floor(s):** 0

**Call Description:** Lift ooo

**Order Number:** 0

### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** See Work description

**Work Description:** Lift over the top by 80mm.\r\nDrive lift below level and required error reset to run again.\r\nCheck all inductors and limits and tested ok.\r\nlift and monitored error logs. Did not fault. Will check again when getting serviced monday.

**Part Required:** No Parts Required

**Service Technician**

Zane Tregurtha

**Report Customer**

0