



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Metro Box Hill
Metro Box Hill Station Box Hill
Contract No: P3581

Callouts:

Date of Call: 19-11-2018 21:26:00
Time of Arrival: 19-11-2018 22:25:00
Rectification Time: 19-11-2018 22:40:00
Time of Departure: 19-11-2018 23:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): Lift 1

For Floor(s): platform

Call Description: Ooo

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Lock Faulty

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: Lift ooo - lr not in\r\nFound platform landing doors out of adjustment possibly been hir\r\nthis was stoppinf doors from closing fully\r\nAdj door and test ok

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer