



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

**Pegasus Suites Hotel**  
206-216 A'Beckett St Melbourne  
Contract No: P3382

## Callouts ID: 21985

Date of Call: 12-10-2018 16:46:40  
Time of Arrival: 12-10-2018 16:55:00  
Rectification Time: 12-10-2018 17:00:00  
Time of Departure: 12-10-2018 17:02:00

### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** Not Stopping Level

**For Lift(s):** 4

**For Floor(s):** G

**Call Description:** lift not stopping level above floor level

**Order Number:** x

### DESCRIPTION OF WORK

**Fault Found (CAUSE):** Faulty Brakes

**Work Action (CORRECTION):** See Work description

**Work Description:** Brake out of adjustment. Lift shutdown for further investigation.

**Part Required:** No Parts Required

**Service Technician**

Gavin Pedlar

**Report Customer**

x