



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Lt Bourke 451, Melbourne
451 Lt Bourke Melbourne
Contract No: P3040

Callouts: 22162

Date of Call: 01-11-2018 15:22:51
Time of Arrival: 01-11-2018 15:35:00
Rectification Time: 01-11-2018 18:25:00
Time of Departure: 01-11-2018 18:33:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 2

For Floor(s): 10 & 11

Call Description: SWP

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Released passenger on level 10\error 27 checked up levelling switch,\ndiscovered noisy diverter sheave bearing lift shut down to be repaired

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

.