



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Ormond St 80, Kensington
80 Ormond St Kensington
Contract No: P3427

Callouts:

Date of Call: 31-10-2018 7:45:00
Time of Arrival: 31-10-2018 7:50:00
Rectification Time: 31-10-2018 9:35:00
Time of Departure: 31-10-2018 9:55:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): gnd

Call Description: OOO

Order Number: 1

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Trailing flex caught around ladder tore flex \r\nThe flex has been repaired\r\nThis flex will need to be replaced

Part Required: No Parts Required

Service Technician

Phil Dodsworth

Report Customer

yes