



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Little Saigon

61 Byron Street (32 Leeds St) Footscray

Contract No: 3736

Callouts: 22765

Date of Call: 03-01-2019 9:55:00

Time of Arrival: 03-01-2019 10:15:00

Rectification Time: 03-01-2019 11:10:00

Time of Departure: 03-01-2019 11:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): 4

Call Description: car park lift not working , lights are flashing error 08

Order Number: 35702

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Wire fallen out of kg contactor re connect \r\nAdjust landing door locks\r\nAdjust governor idler sheave guard

Part Required: No Parts Required

Service Technician

Phil Dodsworth

Report Customer

yes