



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

Civic Centre City of Whittlesea  
25 Ferres Blvd South Morang  
Contract No: S3042

**Callouts: 22395**

Date of Call: 26-11-2018 11:59:31  
Time of Arrival: 26-11-2018 12:45:00  
Rectification Time: 26-11-2018 13:00:00  
Time of Departure: 26-11-2018 13:20:00

#### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** S.W.P

**For Lift(s):** Civic Centre

**For Floor(s):** Basement

**Call Description:** person stuck in lift

**Order Number:** .

#### DESCRIPTION OF WORK

**Fault Found (CAUSE):** Running On Arrival

**Work Action (CORRECTION):** See Work description

**Work Description:** Pax out on arrival. DO button stuck in on B level. Release button. Check lift for correct operation.

**Part Required:** No Parts Required

**Service Technician**

mat tehan

**Report Customer**

Carol