



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
03 9687 9099  
info@unitedlifts.com.au

Customer Details:

**Nunawading Library & Civic Centre**  
379-399 Whitehorse Rd Nunawading  
Contract No: 3473 - B507

## Maintenance:

Date of Call: 03-01-2019  
Time of Arrival: 12:44:00  
Time of Departure: 12:44:00

### Maintenance Details

**Maintenance Description:** Regular service \r\nAdjust ground door on dumbwaiter

Maintenance Task	1	2	3
Contact Building Rep. Check Ride & Appointments.	Y	Y	Y
Test all car safties	Y	Y	Y
Clean & Check all M/R Equipment	Y	Y	Y
Clean out controller ad check operation of various parts.	Y	Y	Y
Lubricate All Sheaves	Y	Y	Y
Check car door operator and associated equipment.	Y	Y	Y
Clean & check landing door equipment	Y	Y	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y	Y	Y
Check pit equipment and check water for pit	Y	Y	Y
Check trailer flexes, attachments running clearance	Y	Y	Y
Test Emergency Light Unit	Y	Y	Y
Test Lift Communications	Y	Y	Y

**Service Technician**

Zane Tregurtha

**Customer Email**

caroline@unitedlifts.com.au