



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Nelson Place 235, Williamstown
235 Nelson Place Williamstown
Contract No: P3467

Callouts:

Date of Call: 07-11-2018 1:39:00
Time of Arrival: 07-11-2018 2:15:00
Rectification Time: 07-11-2018 3:15:00
Time of Departure: 07-11-2018 3:32:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 6

Call Description: stuck on level 6

Order Number: 15433

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: safety circuit fuse open\r\n209 relay auxiliary fault\r\nreplaced auxiliary and fuse checked operation ok.

Part Required: auxiliary contact 2N/O

Service Technician

Robert Pelle

Report Customer

Barry