



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

**Wangaratta St 13, Richmond**  
13 Wangaratta St / 71 Tanner Richmond  
Contract No: P3232

## Callouts:

Date of Call: 14-12-2018 19:28:00  
Time of Arrival: 14-12-2018 22:30:00  
Rectification Time: 14-12-2018 23:05:00  
Time of Departure: 14-12-2018 23:10:00

### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** O.O.O

**For Lift(s):** 1

**For Floor(s):** .

**Call Description:** reported lots of water in lift shaft

**Order Number:** .

### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** See Work description

**Work Description:** lift out of order in basement, \r\nobstruction in landing doors due car park flooding cleaned doors tracks, \r\nchecked operation returned lift back to service.

**Part Required:** No Parts Required

**Service Technician**

Robert Pelle

**Report Customer**

Marcus