



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

The Alfred Main Ward Block
55 Alfred Main Ward Block Melbourne
Contract No: P3544

Callouts:

Date of Call: 22-12-2018 16:27:00
Time of Arrival: 22-12-2018 17:05:00
Rectification Time: 22-12-2018 19:20:00
Time of Departure: 22-12-2018 19:45:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 9

For Floor(s): 5

Call Description: Swp

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): Compensator Switch Tripped

Work Action (CORRECTION): Reset/Adjust Switch

Work Description: Release passenger\r\nFound high resistant compensator chain switch\r\nClean contacts and adjust switch\r\nTest operation

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer