



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Henry St 71, Kensington
71 Henry St Kensington
Contract No: P3503

Callouts: 22540

Date of Call: 10-12-2018 11:50:47
Time of Arrival: 10-12-2018 11:38:00
Rectification Time: 10-12-2018 12:38:00
Time of Departure: 10-12-2018 13:15:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): 3

Call Description: lift not working

Order Number: 007153

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Found lift controller to be de energised. Rectified issue by finding phase failure relay faulty. Re adjusted to another unused terminal. Returned service.

Part Required: No Parts Required

Service Technician

Marek Torrico

Report Customer

#