



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Clifford Terrace 50, Kensington
50 Clifford Terrace Kensington
Contract No: P3494

Callouts:

Date of Call: 21-12-2018 19:00:00
Time of Arrival: 21-12-2018 19:25:00
Rectification Time: 21-12-2018 19:45:00
Time of Departure: 21-12-2018 19:55:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): g

Call Description: Lift ooo on ground with doors open

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Loose Wire

Work Action (CORRECTION): Tighten Terminal

Work Description: Lift ooo on g with 53 fault, which is break monitoring, found nc wire loose in terminal pulled out and re terminated also checked contacts for resistance all okay tested lift

Part Required: No Parts Required

Service Technician

Dwain Sanderson

Report Customer

security