



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Melbourne Business College (200 Leicester St, Carlton)
200 Leicester St Carlton
Contract No: P3310

Callouts ID: 22010

Date of Call: 16-10-2018 14:57:28
Time of Arrival: 16-10-2018 15:28:00
Rectification Time: 16-10-2018 16:00:00
Time of Departure: 16-10-2018 16:02:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): B

Call Description: Stuck on basement floor

Order Number: x

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Error 146. Replaced 12v battery on car top.

Part Required: No Parts Required

Service Technician

Gavin Pedlar

Report Customer

Mick 0407824005