

Alteration or Upgrade of Inverter Energy System (IES)

Inverter Energy System Type	Solar Wind	Solar Wind	Solar/Wind Combined	Other	Other
System Size Limit	Up to 4.6kW	4.6kW- 15kW ☐ Single line diagram included	4.6kW- 15kW ☐ Single line diagram included	Up to 4.6kW	4.6kW- 15kW Single line diagram included
Customer Phases	1 2 3	1 2 3	1 2 3	1 2 3	1 2 3

SECTION 1: INSTALLATION DETAILS (to be completed, signed and submitted to AusNet Services by the installer)

Installer Company Name				Installer Phone Number					
Installer Company Address									
Is an existing Embedded Generator Installed at this premise		☐ Yes		No		KW			
Total Installed Capacity (Total rating of, all solar panels, all turbines, or all other energy sources including existing total panel rating)			Inverter Power Rating (1 hour or continuous rating. Include existing Inverter detai		ontinuous rating.	kW			
Installed Capacity Per Phase (mark N/A for phases not available)		Phase A:	kW	Phase	B:kW	Phase	e C:		_kW
Operating Manual Provided to Customer		☐ Yes	Instruc	Instructed Customer in Operation of system				Yes	
By signing this form, you a	and represe	ent that the	informatio	on provided is tr	ue and c	orrect.			
Installer Name:		Ins	taller Accre	ditation N	o*				
Installer Signature: Fire Fire Fire Fire		Date:							
SECTION 2: INSTALLATION COMPLIANCE (to be completed and signed by the Registered Electrical Contractor)									
Inverter Number of Phases		hase 230V se 230/400V	Г Г	_	hase 400V ase 230/460V	Access to	Meter,	П	Yes
Load Number of Phases		ohase 230V ase 230/400\			ohase 400V nase 230/460V	Switchbo		Г	No

INVERTER TEST RECORDS This test must be conducted at a time of day when the prevailing weather conditions allow the PV system to be producing at least a minimum output. This must be greater than 20% of the rated output of the PV array or the inverter (whichever is less)

INVERTER TYPE 1 (include existing Inverter	Inverter Make	Inverter Model	
details) MICRO INVERTERS Yes No □	Total Inverters Installed		
ANTI ISLANDING OPERATION			
Test 1: Time for inverter/s to disconnect.	<u>Measurement</u>	Result (please circle one)	
Must be < 2 seconds to pass			
	Seconds	Pass/Fail	
Test 2: Time for inverter to reconnect. Must be >			
60 seconds to pass	Seconds	Pass/Fail	



Alteration or Upgrade of Inverter Energy System (IES)

INVERTER TYPE 2 (if applicable)	Inverter Make	Inverter Model
MICRO INVERTERS Yes No		
ANTI ISLANDING OPERATION	Total Inverters Installed	
Test 1: Time for inverter/s to disconnect.	<u>Measurement</u>	Result (please circle one)
Must be < 2 seconds to pass		
	Seconds	Pass/Fail
Test 2: Time for inverter to reconnect. Must be >		
60 seconds to pass	Seconds	Pass/Fail

By signing this form, you acknowledge and represent that:

- the Inverter Energy System complies with the Electricity Safety Act 1998 (Vic) and associated Safety Regulations, the Electricity Distribution Code, the Victorian Service & Installation Rules, AS/NZS3000 (Wiring Rules) and AS4777 (Grid Connection of Energy Systems via Inverters), and any other relevant Acts, regulations, standards or guidelines;
- the Inverter Energy System is connected to a dedicated circuit complete with lockable isolating switch at the switchboard;
- the main switchboard, isolating fuse/switch/circuit breaker are labelled correctly;
- commissioning tests as specified in the Service & Installation Rules and in section 2 of this form have been completed and
- alternative supply signage has been installed;
- a Prescribed Certificate of Electrical Safety (CES) has been obtained; with
- copies of this form and the CES to be sent directly to AusNet Services and the Inverter Energy System owner's Retailer.

TESTS UNDERTAKEN BY:		
Licenced Electrical Installat	ion Worker Name:	
Licence No*	Date:	
Signature:		

SECTION 3: INVERTER ENERGY SYSTEM OWNER DETAILS (to be completed and signed by the IES owner)

		•			
Customer Name*	Customer NMI* (Refer to your electricity bill)				
Supply Address*		Mailing Addres	ss*		
Phone Number*	Business Hours:	,	After H	lours:	
Existing Meter Number*					

CUSTOMER ACKNOWLEDGEMENT, INDEMNITY AND RELEASE

By signing this form, you acknowledge and represent that you have read, understand and agree to comply with the connection obligations, and that you:

- are the owner of the Inverter Energy System listed under the Supply Address in section 3 above;
- have received an Inverter Energy System operating manual from, and been instructed on the operation of the Inverter Energy System by, the Installation Company detailed in section 1;
- accept that approval will only be granted for the Inverter Energy System detailed in this form, and that you must obtain further prior approval from your Distributor to alter your Inverter Energy System in any way;
- release and indemnify and agree to keep indemnified your Distributor, its officers, employees and agents against all actions, proceedings, claims and demands whatsoever which may be brought, including any indirect or consequential loss or any other form of pure economic loss, made or prosecuted against them or any of them by any person in respect of the installation of your Inverter Energy System, particularly in relation to works completed by the Installation Company detailed in section 1 or the compliance certification provided by the registered electrical contractor in section 2, or in respect of connection of your Inverter Energy System to the Victorian electricity grid.

Customer Name:	Customer Signature: 🏴	Date: