

Alteration or Upgrade of Inverter Energy System (IES)

Inverter Energy System Type	Solar Wind	Solar Wind	Solar/Wind Combined	Other	Other
System Size Limit	Up to 4.6kW	4.6kW- 15kW ☐ Single line diagram included	4.6kW- 15kW ☐ Single line diagram included	Up to 4.6kW	4.6kW- 15kW Single line diagram included
Customer Phases	1 2 3	1 2 3	1 2 3	1 2 3	1 2 3

Installer Company Name		Installer Phone N			ne Number		
Installer Company Address				1	1		
Is an existing Embedded Generator Installed at this premise		☐ Yes		□ No	KW		
Total Installed Capacity (Total rating of, all solar panels, all turbines, or all other energy sources including existing total panel rating)			kW	Inverter Power Rating (1 hour or continuous rating. Include existing Inverter det		kW	
Installed Capacity Per Phase (mark N/A for phases not available)		Phase A:	kW	Phase B:k	W Phase C:	kW	
Operating Manual Provided to Customer		Yes Instructed Customer in Operation of system Yes					
By signing this form, you a	acknowledge	and represe	ent that the	information provided i	s true and correct.		
nstaller Name:		Ins	taller Accre	ditation No*			
nstaller Name: nstaller Signature:	50	124		Date:			
SECTION 2: INSTALLATIO	N COMPLIA	NCE (to be o	completed a	nd signed by the Regi	stered Electrical Co	ontractor	
Inverter Number of Phases	_	Single phase 230V Two phase 230/400V		Three phase 400V Two phase 230/460V	Access to Meter	☐ Yes	
Load Number of Phases	ses Single phase 230V Two phase 230/400V		Three phase 400V Two phase 230/460	Switchboard	☐ No		

INVERTER TEST RECORDS This test must be conducted at a time of day when the prevailing weather conditions allow the PV system to be producing at least a minimum output. This must be greater than 20% of the rated output of the PV array or the inverter (whichever is less)

INVERTER TYPE 1 (include existing Inverter	Inverter Make	Inverter Model
details) MICRO INVERTERS Yes No □	Total Inverters Installed	
ANTI ISLANDING OPERATION		
Test 1: Time for inverter/s to disconnect.	<u>Measurement</u>	Result (please circle one)
Must be < 2 seconds to pass		
	Seconds	Pass/Fail
Test 2: Time for inverter to reconnect. Must be >		
60 seconds to pass	Seconds	Pass/Fail



Alteration or Upgrade of Inverter Energy System (IES)

INVERTER TYPE 2 (if applicable)	Inverter Make	Inverter Model
MICRO INVERTERS Yes No		
ANTI ISLANDING OPERATION	Total Inverters Installed	
Test 1: Time for inverter/s to disconnect.	<u>Measurement</u>	Result (please circle one)
Must be < 2 seconds to pass		
	Seconds	Pass/Fail
Test 2: Time for inverter to reconnect. Must be >		
60 seconds to pass	Seconds	Pass/Fail
	·	·

By signing this form, you acknowledge and represent that:

- the Inverter Energy System complies with the Electricity Safety
 Act 1998 (Vic) and associated Safety Regulations, the Electricity
 Distribution Code, the Victorian Service & Installation Rules,
 AS/NZS3000 (Wiring Rules) and AS4777 (Grid Connection of
 Energy Systems via Inverters), and any other relevant Acts,
 regulations, standards or guidelines;
- the Inverter Energy System is connected to a dedicated circuit complete with lockable isolating switch at the switchboard;
- the main switchboard, isolating fuse/switch/circuit breaker are labelled correctly;
- commissioning tests as specified in the Service & Installation Rules and in section 2 of this form have been completed and passed.
- alternative supply signage has been installed;
- a Prescribed Certificate of Electrical Safety (CES) has been obtained; with
- copies of this form and the CES to be sent directly to AusNet Services and the Inverter Energy System owner's Retailer.

TESTS UNDERTAKEN BY:		
Licenced Electrical Installati	on Worker Name:	
Licence No*	Date:	
Signature:		

SECTION 3: INVERTER ENERGY SYSTEM OWNER DETAILS (to be completed and signed by the IES owner)

OZOTIONO: INVENTEN	ENERGY GIGIEM GWILL	1 02 17 1120 (10	DO 0011	iprotod drid orginod by the 120 chinery
Customer Name*		Customer NI (Refer to your electr		
Supply Address*		Mailing Addr	ess*	
Phone Number*	Business Hours:	•	After F	lours:
Existing Meter Number*		_		

CUSTOMER ACKNOWLEDGEMENT, INDEMNITY AND RELEASE

By signing this form, you acknowledge and represent that you have read, understand and agree to comply with the connection obligations, and that you:

- are the owner of the Inverter Energy System listed under the Supply Address in section 3 above;
- have received an Inverter Energy System operating manual from, and been instructed on the operation of the Inverter Energy System by, the Installation Company detailed in section 1;
- accept that approval will only be granted for the Inverter Energy System detailed in this form, and that you must obtain further prior approval from your Distributor to alter your Inverter Energy System in any way;
- release and indemnify and agree to keep indemnified your Distributor, its officers, employees and agents against all actions, proceedings, claims and demands whatsoever which may be brought, including any indirect or consequential loss or any other form of pure economic loss, made or prosecuted against them or any of them by any person in respect of the installation of your Inverter Energy System, particularly in relation to works completed by the Installation Company detailed in section 1 or the compliance certification provided by the registered electrical contractor in section 2, or in respect of connection of your Inverter Energy System to the Victorian electricity grid.

Customer Name:	Customer Signature:	Date:
PRIVACY STATEMENT: The personal information you prov	ide in this form will be collected by your Distributor for the purpose of connecting your Inve	erter Energy System to the Victorian electricity grid