

Permit #: 25341

HOT WORK PERMIT**Permit Is Valid for One Shift Only****HOT WORK PERMIT ISSUE SECTION**

Location of Hot Work: _____ Date: _____

Name of Requestor _____

(Person Performing Work): Klovov Danil _____ Name of Fire Watch: _____

Note: For open flame winter thawing activities, a fire watch is NOT required. See Procedure for requirements.**Atmospheric Monitoring Record:**☐ Check this box If the hot work is in a confined space and the records of monitoring will only be recorded on the Confined Space Entry Permit or Certification of Reclassification.

Test Equipment Model #: _____ Serial #: _____ Cal Date: _____

Fire Watch Required	☐ Y ☐ N	Time of Initial Test		Initial Reading - Combustibles (LEL) Under 10%	
---------------------	---	----------------------	--	--	--

Additional Monitoring Results If Required If required - write down results approximately every 2 hours of hot work	Time	Reading	Time	Reading	Time	Reading	Time	Reading	Time	Reading

HOT WORK PERMIT CHECKLIST AND APPROVAL SECTION

- | Y | NA | |
|--------------------------|--------------------------|---|
| ☐ | ☐ | General Condition of Area Housekeeping is acceptable. |
| ☐ | ☐ | Remove, cover, or otherwise protect all flammable and combustible materials in area. (35 feet from work area) |
| ☐ | ☐ | Sweep or vacuum away all combustible dust or debris. If possible, wet down area after it is cleaned. |
| ☐ | ☐ | Walls, roofs, ceilings, pipes, tanks and partitions assessed for conductive or radiated heat and preventive measures taken. |
| ☐ | ☐ | Purge or inert piping or vessels prior to hot work (if used for transporting or storing flammables or combustibles) per site procedure. |
| ☐ | ☐ | Openings in floors or walls covered to contain sparks and hot slag. |
| ☐ | ☐ | Ductwork shutdown or otherwise protected to prevent causing a fire at a distant location. |
| ☐ | ☐ | Necessary equipment de-energized and locked out of service per LOTO requirements. |
| ☐ | ☐ | Communications checked in the area for use in emergency (phones, radios) |
| ☐ | ☐ | Fire Watch is aware of their duties, is fire extinguisher trained, knows location of fire extinguishers, and emergency procedures |
| ☐ | ☐ | The fire extinguisher immediately available and the backup have been inspected and are suitable for use. |
| ☐ | ☐ | Fire Protection System in service. <i>If area has a fire system and it is out of service, the Plant Manager MUST approve the permit and notification to insurance carrier is required.</i> |

Special Instructions: _____

Hot Work Permit Approved (Issuer Signature): _____ Date/Time: _____

Plant Manager (or Designee) Approval (Fire Systems Disabled): _____ Date/Time: _____

HOT WORK PERMIT CANCELLATION SECTION

Fire Watch/Fire Monitoring (as required by the table below) have been completed and all ignition sources have been extinguished.

Name of Requestor _____ Signature: _____ Date/Time: _____

Name of Fire Watch _____ Signature _____ Date/Time: _____

☐ The Hot Work is completed; the area has been inspected and this permit is closed out.

Hot Work Permit Cancelled: _____ Date/Time: _____

Post Copy at Location - Keep Original in Control Room - Upon Completion, File Original in Binder, Copy May be Destroyed.

Construction and Occupancy Factors for Post-Work Fire Watch and Monitoring Periods

		Construction Factors					
		Noncombustible construction, or Class 1, or Class A building materials		Combustible construction without concealed cavities		Combustible construction with unprotected concealed cavities	
		Watch	Monitor	Watch	Monitor	Watch	Monitor
Occupancy Factors	Noncombustible with any combustibles contained within closed equipment (e.g., ignitable liquid within piping)	30 minutes	0 hours	1 hour	3 hours	1 hour	5 hours
	Office, retail or manufacturing with limited combustible loading	1 hour	1 hour	1 hour	3 hours	1 hour	5 hours
	Manufacturing with moderate combustible loading	1 hour	2 hours	1 hour	3 hours	1 hour	5 hours
	Warehousing	1 hour	2 hours	1 hour	3 hours	1 hour	5 hours
	Exceptions: Occupancies with processing or having bulk storage of combustible materials capable of supporting slow-growing fires (e.g., paper, pulp, textile fibers, wood, bark, grain, coal or charcoal)	1 hour	3 hours	1 hour	3 hours	1 hour	5 hours

Definitions:

Fire Monitor - Provisions implemented to provide early warning of smoldering fire conditions in the hot work area following completion of the established fire watch time period.

Fire Watch - A person or persons responsible for continuously observing the hot work area, maintaining fire-safe conditions, and responding to emergencies during hot work operations and in the established period following.

[illegible]