



Emergency Eyewash & Safety Shower Inspection Form

Appendix C

Purpose: To ensure regulation compliance and function of the emergency eyewash/shower units.

References: ANSI Z358.1-1998

Frequency: Weekly (Steps 1-9)
Annual (Steps 1-10)

Revision No:

Date:

Procedure

Step	Action
1.	Ensure that the area immediately around the unit is clear of obstructions or sharp objects.
2.	Ensure that the area is well lighted.
3.	Ensure that the Emergency Eyewash/Shower sign is present and visible at each unit.
4.	Flush each plumbed unit to ensure function and to flush the water line. Verify that valve opens in one second and stays open.
5.	Ensure that both eyewash nozzles are operating and that both eyes could be flushed at the same time. Verify that the pressure would not cause further eye damage.
6.	Ensure that the eyewash nozzles are protected from airborne contaminants (the caps must be in place)
7.	Ensure that portable units are full and water additive complies with manufacturer recommendation (6mo). Ensure that pressurized units have the proper operating pressure.
8.	Document any discrepancies and the corrective action taken below. Communicate the same with the shift supervisor to ensure that work orders are generated to make needed corrections that require work orders.
9.	Verify flow switch alarm comes into control room.
10.	Shower: Measure the diameter of the flushing pattern (20") Connect flowmeter and measure delivery (minimum 75.7 liters per minutes/20 gpm). Eyewash: Measurement of flowmeter must be 1.5 liters per minute or 0.4 gpm)

#	Location	Comments	Unit OK
1	Water Treatment Building		
2	Unit 2 Outside TCP		
3	Unit 2 SCR Skid		
4	Unit 2 Chemical Shack		
5	Unit 2 Sample Panel		
6	Aqueous Ammonia Storage Tank Area East		
7	Aqueous Ammonia Storage Tank Area West		
8	Aux Boiler Building		
9	Unit 2 Calcite Filter Platform		
10	Medium Voltage Enclosure South		
11	Medium Voltage Enclosure North		
12	Unit 1 Outside TCP		
13	Unit 1 SCR Skid		
14	Unit 1 Chemical Shack		
15	Unit 1 Sample Panel		
16	Unit 1 Calcite Filter Platform		
17	Switch Yard Enclosure		

Inspector's name:	Date
-------------------	------