



SYSTEMS

BY **RM** MANIFOLD

MES EXHAUST SHAFT SIZING REPORT

Muilt-Family Shaft Constant Pressure System

Parkview Tower

Dallas, TX

Clothes Dryers

Prepared by: jsmith@company.com

February 11, 2026

SYSTEM AT A GLANCE

Building Floors	15
Design CFM	3,000 CFM
Recommended Shaft	24" x 18" Rect
Selected Fan	DEF025
Controller	L152.M
System dP	0.134 in. WC
Status	PASS

LF Systems by RM Manifold

System Summary

Sample content on page 2 with proper footer.