

CLIENT: G. J Gardner homes

Job Name: Example name

Address New residence on 4 briar ct, hamilton

Note Refer to attach site plan

Job No:

169

Date:

07-08-2014

Tested By:

user

TEST

1

Depth (m)	No of Blows	Scale Penetrometer (Blows / 100mm)	SOIL DESCRIPTION	Depth (m)	UNDRAINED SHEAR (kPa)
0.5	1		100 mm topsoil		
	2		sand, orange gray, fine gray, medium dense	0.5	3/4.5
	3				4.5/6
	4				7.5/9
	5				9/10.5
1	6		SAND, minor subrounded gravel, brown	1	12/13.5
	7				13.5/15
	8				
	9		Silt, Grey gray, Stiff		
	10			1.5	6/9
1.5	9				
	8				
	7				
	6				
	5				
2	4			2	13.5/15
	3				3/4.5
	2				
	1		EOB = 2.0 water table		
	7				
2.5				2.5	
3				3	
3.5				3.5	
4				4	
4.5				4.5	

