

CLIENT: G. J Gardner homes

Job Name: Example name

Address New residence on 4 briar ct, hamilton

Note Refer to attach site plan

Job No:

169

Date:

07-08-2014

Tested By:

user

TEST

1

Depth (m)	No of Blows	Scale Penetrometer (Blows / 100mm)	SOIL DESCRIPTION	Depth (m)	UNDRAINED SHEAR (kPa)
0.5	1	1.5	100 mm topsoil	0.5	3/4.5
	2	2.5	sand, orange gray, fine gray, medium dense		4.5/6
	3	3.5			7.5/9
	4	4.5			9/10.5
	5	5.5			12/13.5
1	6	6.5	SAND, minor subrounded gravel, brown	1	13.5/15
	7	7.5			
	8	8.5			
	9	9.5	Silt, Grey gray, Stiff		
	10	10.5			
1.5	9	11.5		1.5	6/9
	8	12.5			
	7	13.5			
	6	14.5			
	5	15.5			
2	4	16.5		2	13.5/15
	3	17.5			3/4.5
	2	18.5			
	1	19.5			
	7	20.5			
2.5				2.5	
3				3	
3.5				3.5	
4				4	
4.5				4.5	

