


Question #	Criteria (CE = Critical Elements)	Explanation/Guidelines	Yes	No	N/A
27 (CE)	Do doors have an opening at least 32 inches wide (at the narrowest point below the opening hardware) when opened to 90°?	<p>When measuring double doors, measure the opening with one door open to 90°.</p>  <p>32 INCHES MIN CLEAR OPENING</p>			