

Property Risk Engineering Report

Survey date 2025-10-02 · Elena Brooks, CSP

Insured:	Meridian Data Centers	Survey date:	2025-10-02
Engineer:	Elena Brooks, CSP	Scope:	COPE, fire protection, natural hazard, rec

LOCATION 1 — MERIDIAN ASHBURN CAMPUS

Address:	6961 Palisade Ave, Ashburn, VA		
Construction:	Fire resistive (ISO 6)	Year built:	2019
Stories:	2	Floor area (sq ft):	1,450,000
Roof covering:	TPO membrane	Roof year (verified):	2019
Occupancy observed:	Data center	Sprinkler protection:	100% of area
Fire alarm:	Central station	Public protection class:	1

The Meridian Ashburn Campus facility is a 2-story fire resistive building of approximately 1,450,000 sq ft built in 2019. Housekeeping was observed to be generally good. The building is fully protected by automatic sprinklers supplied from the municipal main; the system was last tested within 12 months.

Elena Brooks, CSP · Northgate Risk Engineering · 2025-10-02