

# Property Risk Engineering Report

Survey date 2025-05-12 · Elena Brooks, CSP

|           |                       |              |                                               |
|-----------|-----------------------|--------------|-----------------------------------------------|
| Insured:  | Crestline Office REIT | Survey date: | 2025-05-12                                    |
| Engineer: | Elena Brooks, CSP     | Scope:       | COPE, fire protection, natural hazard, record |

## LOCATION 1 — CRESTLINE TOWER COLUMBUS

|                     |                                 |                          |              |
|---------------------|---------------------------------|--------------------------|--------------|
| Address:            | 7327 Quarry Rd, Columbus, OH    |                          |              |
| Construction:       | Modified fire resistive (ISO 5) | Year built:              | 2004         |
| Stories:            | 9                               | Floor area (sq ft):      | 77,364       |
| Roof covering:      | TPO membrane                    | Roof year (verified):    | 2018         |
| Occupancy observed: | Office / professional           | Sprinkler protection:    | 100% of area |
| Fire alarm:         | Central station                 | Public protection class: | 2            |

The Crestline Tower Columbus facility is a 9-story modified fire resistive building of approximately 77,364 sq ft built in 2004. Housekeeping was observed to be generally good. The building is fully protected by automatic sprinklers supplied from the municipal main; the system was last tested within 12 months.

## LOCATION 2 — CRESTLINE TOWER PITTSBURGH

|                     |                                 |                          |              |
|---------------------|---------------------------------|--------------------------|--------------|
| Address:            | 6970 Summit Ave, Pittsburgh, PA |                          |              |
| Construction:       | Fire resistive (ISO 6)          | Year built:              | 2003         |
| Stories:            | 18                              | Floor area (sq ft):      | 76,527       |
| Roof covering:      | TPO membrane                    | Roof year (verified):    | 2020         |
| Occupancy observed: | Office / professional           | Sprinkler protection:    | 100% of area |
| Fire alarm:         | Central station                 | Public protection class: | 2            |

The Crestline Tower Pittsburgh facility is a 18-story fire resistive building of approximately 76,527 sq ft built in 2003. Housekeeping was observed to be generally good. The building is fully protected by automatic sprinklers supplied from the municipal main; the system was last tested within 12 months.

## LOCATION 3 — CRESTLINE TOWER CHICAGO

|                     |                                |                          |              |
|---------------------|--------------------------------|--------------------------|--------------|
| Address:            | 8155 Tidewater Ln, Chicago, IL |                          |              |
| Construction:       | Fire resistive (ISO 6)         | Year built:              | 2009         |
| Stories:            | 10                             | Floor area (sq ft):      | 47,489       |
| Roof covering:      | TPO membrane                   | Roof year (verified):    | 2016         |
| Occupancy observed: | Office / professional          | Sprinkler protection:    | 100% of area |
| Fire alarm:         | Central station                | Public protection class: | 2            |

The Crestline Tower Chicago facility is a 10-story fire resistive building of approximately 47,489 sq ft built in 2009. Housekeeping was observed to be generally good. The building is fully protected by automatic sprinklers supplied from the municipal main; the system was last tested within 12 months.

## LOCATION 4 — CRESTLINE TOWER ATLANTA

|          |                                |
|----------|--------------------------------|
| Address: | 4799 Ironworks Rd, Atlanta, GA |
|----------|--------------------------------|

|                     |                                        |                          |                     |
|---------------------|----------------------------------------|--------------------------|---------------------|
| Construction:       | <b>Modified fire resistive (ISO 5)</b> | Year built:              | <b>2001</b>         |
| Stories:            | <b>12</b>                              | Floor area (sq ft):      | <b>89,560</b>       |
| Roof covering:      | <b>TPO membrane</b>                    | Roof year (verified):    | <b>2018</b>         |
| Occupancy observed: | <b>Office / professional</b>           | Sprinkler protection:    | <b>100% of area</b> |
| Fire alarm:         | <b>Central station</b>                 | Public protection class: | <b>2</b>            |

The Crestline Tower Atlanta facility is a 12-story modified fire resistive building of approximately 89,560 sq ft built in 2001. Housekeeping was observed to be generally good. The building is fully protected by automatic sprinklers supplied from the municipal main; the system was last tested within 12 months.

## LOCATION 5 — CRESTLINE TOWER NASHVILLE

|                     |                                         |                          |                     |
|---------------------|-----------------------------------------|--------------------------|---------------------|
| Address:            | <b>7213 Lakeview Ave, Nashville, TN</b> |                          |                     |
| Construction:       | <b>Modified fire resistive (ISO 5)</b>  | Year built:              | <b>2012</b>         |
| Stories:            | <b>8</b>                                | Floor area (sq ft):      | <b>62,938</b>       |
| Roof covering:      | <b>TPO membrane</b>                     | Roof year (verified):    | <b>2019</b>         |
| Occupancy observed: | <b>Office / professional</b>            | Sprinkler protection:    | <b>100% of area</b> |
| Fire alarm:         | <b>Central station</b>                  | Public protection class: | <b>2</b>            |

The Crestline Tower Nashville facility is a 8-story modified fire resistive building of approximately 62,938 sq ft built in 2012. Housekeeping was observed to be generally good. The building is fully protected by automatic sprinklers supplied from the municipal main; the system was last tested within 12 months.

## LOCATION 6 — CRESTLINE TOWER CHARLOTTE

|                     |                                        |                          |                     |
|---------------------|----------------------------------------|--------------------------|---------------------|
| Address:            | <b>4464 Ashford Cir, Charlotte, NC</b> |                          |                     |
| Construction:       | <b>Fire resistive (ISO 6)</b>          | Year built:              | <b>1996</b>         |
| Stories:            | <b>14</b>                              | Floor area (sq ft):      | <b>50,454</b>       |
| Roof covering:      | <b>TPO membrane</b>                    | Roof year (verified):    | <b>2017</b>         |
| Occupancy observed: | <b>Office / professional</b>           | Sprinkler protection:    | <b>100% of area</b> |
| Fire alarm:         | <b>Central station</b>                 | Public protection class: | <b>2</b>            |

The Crestline Tower Charlotte facility is a 14-story fire resistive building of approximately 50,454 sq ft built in 1996. Housekeeping was observed to be generally good. The building is fully protected by automatic sprinklers supplied from the municipal main; the system was last tested within 12 months.

## LOCATION 7 — CRESTLINE TOWER MINNEAPOLIS

|                     |                                          |                          |                     |
|---------------------|------------------------------------------|--------------------------|---------------------|
| Address:            | <b>922 Meridian Way, Minneapolis, MN</b> |                          |                     |
| Construction:       | <b>Fire resistive (ISO 6)</b>            | Year built:              | <b>2007</b>         |
| Stories:            | <b>12</b>                                | Floor area (sq ft):      | <b>70,908</b>       |
| Roof covering:      | <b>TPO membrane</b>                      | Roof year (verified):    | <b>2021</b>         |
| Occupancy observed: | <b>Office / professional</b>             | Sprinkler protection:    | <b>100% of area</b> |
| Fire alarm:         | <b>Central station</b>                   | Public protection class: | <b>2</b>            |

The Crestline Tower Minneapolis facility is a 12-story fire resistive building of approximately 70,908 sq ft built in 2007. Housekeeping was observed to be generally good. The building is fully protected by automatic sprinklers supplied from the municipal main; the system was last tested within 12 months.

## LOCATION 8 — CRESTLINE TOWER PHILADELPHIA

|          |                                         |
|----------|-----------------------------------------|
| Address: | <b>4011 Quarry Rd, Philadelphia, PA</b> |
|----------|-----------------------------------------|

|                     |                               |                          |                     |
|---------------------|-------------------------------|--------------------------|---------------------|
| Construction:       | <b>Fire resistive (ISO 6)</b> | Year built:              | <b>2011</b>         |
| Stories:            | <b>14</b>                     | Floor area (sq ft):      | <b>50,101</b>       |
| Roof covering:      | <b>TPO membrane</b>           | Roof year (verified):    | <b>2022</b>         |
| Occupancy observed: | <b>Office / professional</b>  | Sprinkler protection:    | <b>100% of area</b> |
| Fire alarm:         | <b>Central station</b>        | Public protection class: | <b>2</b>            |

The Crestline Tower Philadelphia facility is a 14-story fire resistive building of approximately 50,101 sq ft built in 2011. Housekeeping was observed to be generally good. The building is fully protected by automatic sprinklers supplied from the municipal main; the system was last tested within 12 months.

Elena Brooks, CSP · Northgate Risk Engineering · 2025-05-12

SAMPLE