

Property Risk Engineering Report

Survey date 2024-04-02 · Elena Brooks, CSP

Insured:	ABC Manufacturing	Survey date:	2024-04-02
Engineer:	Elena Brooks, CSP	Scope:	COPE, fire protection, natural hazard, rec

LOCATION 3 — RENO WAREHOUSE

Address:	955 Railyard Rd, Reno, NV		
Construction:	Non-combustible (ISO 3)	Year built:	2012
Stories:	1	Floor area (sq ft):	160,000
Roof covering:	TPO membrane	Roof year (verified):	2012
Occupancy observed:	General warehouse	Sprinkler protection:	100% of area
Fire alarm:	Central station	Public protection class:	4
Max storage height (ft):	24	Sprinkler design storage height (ft):	25
Commodity:	General merchandise (Class III)		

The Reno Warehouse facility is a 1-story non-combustible building of approximately 160,000 sq ft built in 2012. Housekeeping was observed to be generally good. The building is fully protected by automatic sprinklers supplied from the municipal main; the system was last tested within 12 months. Storage is in selective steel racking; storage heights were within the sprinkler design at the time of survey.

Elena Brooks, CSP · Northgate Risk Engineering · 2024-04-02