

Property Risk Engineering Report

Survey date 2024-04-10 · Elena Brooks, CSP

Insured:
Engineer:

ABC Manufacturing
Elena Brooks, CSP

Survey date:
Scope:

2024-04-10
COPE, fire protection, natural hazard, rec

LOCATION 4 — AUSTIN COMPONENTS

Address:	7020 Commerce Loop, Austin, TX		
Construction:	Masonry non-combustible (ISO 4)		2001
Stories:	2	Floor area (sq ft):	64,000
Roof covering:	TPO membrane	Roof year (verified):	2008
Occupancy observed:	Light manufacturing	Sprinkler protection:	100% of area
Fire alarm:	Central station	Public protection class:	3

The Austin Components facility is a 2-story masonry non-combustible building of approximately 64,000 sq ft built in 2001. Housekeeping was observed to be generally good. The building is fully protected by automatic sprinklers supplied from the municipal main; the system was last tested within 12 months.

RECOMMENDATIONS

Rec #	Loc	Category	Recommendation	Priority	Target date
R-114	4	Water / plumbing	Replace corroded roof-drain leaders and install water-flow detection ...	High	2025-10-31

Elena Brooks, CSP · Northgate Risk Engineering · 2024-04-10