

Property Risk Engineering Report

Survey date 2024-06-20 · Elena Brooks, CSP

Insured:	Redline Logistics	Survey date:	2024-06-20
Engineer:	Elena Brooks, CSP	Scope:	COPE, fire protection, natural hazard, rec

LOCATION 2 — PHOENIX DC

Address:	9399 Juniper Way, Phoenix, AZ		
Construction:	Masonry non-combustible (ISO 4)		2010
Stories:	1	Floor area (sq ft):	260,000
Roof covering:	TPO membrane	Roof year (verified):	2016
Occupancy observed:	General warehouse	Sprinkler protection:	100% of area
Fire alarm:	Central station	Public protection class:	3
Max storage height (ft):	20	Sprinkler design storage height (ft):	25
Commodity:	General merchandise (Class III)		

The Phoenix DC facility is a 1-story masonry non-combustible building of approximately 260,000 sq ft built in 2010. Housekeeping was observed to be generally good. The building is fully protected by automatic sprinklers supplied from the municipal main; the system was last tested within 12 months. Storage is in selective steel racking; storage heights were within the sprinkler design at the time of survey.

Elena Brooks, CSP · Northgate Risk Engineering · 2024-06-20