

Property Risk Engineering Report

Survey date 2024-07-01 · Elena Brooks, CSP

Insured:	Redline Logistics	Survey date:	2024-07-01
Engineer:	Elena Brooks, CSP	Scope:	COPE, fire protection, natural hazard, rec

LOCATION 3 — ATLANTA DC

Address:	6610 Granite Ct, Atlanta, GA		
Construction:	Non-combustible (ISO 3)	Year built:	2004
Stories:	1	Floor area (sq ft):	190,000
Roof covering:	TPO membrane	Roof year (verified):	2012
Occupancy observed:	General warehouse	Sprinkler protection:	100% of area
Fire alarm:	Central station	Public protection class:	3
Max storage height (ft):	18	Sprinkler design storage height (ft):	20
Commodity:	General merchandise (Class II)		

The Atlanta DC facility is a 1-story non-combustible building of approximately 190,000 sq ft built in 2004. Housekeeping was observed to be generally good. The building is fully protected by automatic sprinklers supplied from the municipal main; the system was last tested within 12 months. Storage is in selective steel racking; storage heights were within the sprinkler design at the time of survey.

Elena Brooks, CSP · Northgate Risk Engineering · 2024-07-01