

# Property Risk Engineering Report

Survey date 2025-09-22 · Elena Brooks, CSP

|           |                                   |              |                                                   |
|-----------|-----------------------------------|--------------|---------------------------------------------------|
| Insured:  | <b>St. Aurelia Medical Center</b> | Survey date: | <b>2025-09-22</b>                                 |
| Engineer: | <b>Elena Brooks, CSP</b>          | Scope:       | <b>COPE, fire protection, natural hazard, rec</b> |

## LOCATION 1 — ST. AURELIA MEDICAL CENTER

|                     |                                             |                          |                     |
|---------------------|---------------------------------------------|--------------------------|---------------------|
| Address:            | <b>2309 Harbor Point Dr, Charleston, SC</b> |                          |                     |
| Construction:       | <b>Fire resistive (ISO 6)</b>               | Year built:              | <b>1987</b>         |
| Stories:            | <b>9</b>                                    | Floor area (sq ft):      | <b>1,150,000</b>    |
| Roof covering:      | <b>TPO membrane</b>                         | Roof year (verified):    | <b>2015</b>         |
| Occupancy observed: | <b>General hospital</b>                     | Sprinkler protection:    | <b>100% of area</b> |
| Fire alarm:         | <b>Central station</b>                      | Public protection class: | <b>1</b>            |

The St. Aurelia Medical Center facility is a 9-story fire resistive building of approximately 1,150,000 sq ft built in 1987. Housekeeping was observed to be generally good. The building is fully protected by automatic sprinklers supplied from the municipal main; the system was last tested within 12 months.

Elena Brooks, CSP · Northgate Risk Engineering · 2025-09-22