

Property Risk Engineering Report

Survey date 2025-08-14 · Elena Brooks, CSP

Insured:
Engineer:

Keystone Plastics
Elena Brooks, CSP

Survey date:
Scope:

2025-08-14
COPE, fire protection, natural hazard, rec

LOCATION 1 — PITTSBURGH MOLDING PLANT

Address:	8214 Heron Bay Dr, Pittsburgh, PA		
Construction:	Non-combustible (ISO 3)	Year built:	1979
Stories:	1	Floor area (sq ft):	210,000
Roof covering:	TPO membrane	Roof year (verified):	2009
Occupancy observed:	Plastics manufacturing	Sprinkler protection:	85% of area
Fire alarm:	Central station	Public protection class:	3

The Pittsburgh Molding Plant facility is a 1-story non-combustible building of approximately 210,000 sq ft built in 1979. Housekeeping was observed to be generally good. Sprinkler protection covers about 85% of the floor area; the unprotected area is used for finishing and storage.

RECOMMENDATIONS

Rec #	Loc	Category	Recommendation	Priority	Target date
R-0412	1	Combustible dust / ex...	Install spark detection & extinguishing on Line 3 dust collector duct...	Critical	2025-12-31
R-0415	1	Housekeeping	Implement documented dust housekeeping program (weekly high-level cle...	High	2025-11-30

Recommendations marked CRITICAL are a condition of binding and must be completed and verified by Northgate Risk Engineering.

Elena Brooks, CSP · Northgate Risk Engineering · 2025-08-14