

Property Risk Engineering Report

Survey date 2025-08-15 · Elena Brooks, CSP

Insured:
Engineer:

Keystone Plastics
Elena Brooks, CSP

Survey date:
Scope:

2025-08-15
COPE, fire protection, natural hazard, rec

LOCATION 2 — COLUMBUS FINISHING

Address:5895 Ironworks Rd, Columbus, OH

Construction:1996

Stories:1Floor area (sq ft):96,000

Roof covering:TPO membraneRoof year (verified):2015

Occupancy observed:Plastics manufacturingSprinkler protection:100% of area

Fire alarm:Central stationPublic protection class:3

The Columbus Finishing facility is a 1-story masonry non-combustible building of approximately 96,000 sq ft built in 1996. Housekeeping was observed to be generally good. The building is fully protected by automatic sprinklers supplied from the municipal main; the system was last tested within 12 months.

RECOMMENDATIONS

Rec #	Loc	Category	Recommendation	Priority	Target date
R-0420	2	Electrical	Infrared thermography of main switchgear annually	Medium	2026-06-30

Elena Brooks, CSP · Northgate Risk Engineering · 2025-08-15