

Our Report No.: SSLA-91-F-P-261100

Dtd: 11.09.2026

IMMEDIATE LOSS ADVICE

Issued without prejudice and does not necessarily mean that the loss is admissible which depends upon the terms, conditions of the policy of Insurance contract.

TIME & DATE OF INSTRUCTION	10 Sep 2026 from National Insurance Co
SOURCE OF INSTRUCTION	Official Email Intimation
INSURER	National Insurance Co
NAME AND ADDRESS OF INSURED	Precision Tech Ltd MIDC Industrial Area Navi Mumbai, State: Maharashtra, Pincode: 400703
TIME & DATE OF VISIT/SURVEY	On 11 September 2026 from 10.00hrs to 12Hrs
REASON FOR DELAY	As per appointment _apparently No delay.
PLACE WHERE THE DAMAGE WAS INSPECTED	Turbhe, Navi Mumbai
PERSON CONTACTED, WITH TELEPHONE NO. & E-MAIL ID	Plant Manager Contact No. +91-9876543210
POLICY SCHEDULE-STANDARD FIRE & SPECIAL PERILS:	POL-FSR-2026-001
PERIOD OF INSURANCE	As per policy
COMMODITY	Plant & Machinery
NATURE OF LOSS	Fire in Electrical Control Room
SUM INSURED	INR 5000000.00/-
POLICY EXCESS	10000.00 as per policy terms
OUR SURVEY AND INSPECTION (CONT'D)	Initial inspection completed
EXTENT OF DAMAGE	Damage to electrical panel
ESTIMATE OF LOSS/AMOUNT CLAIMED:	Insured has provided a loss estimate of INR 450000.00/- Surveyor's Estimated Gross Loss: INR 350000.00/-
CAUSE OF DAMAGE	Short circuit
SALVAGE	Scrap only
LIABILITY UNDER POLICY & BUDGETARY RESERVE TO BE MAINTAINED	Covered under fire peril
RESERVE FOR INSURERS	Budgetary RESERVE recommended at present: INR 350000.00/- , subject to change based upon supporting documents.
REMARKS	The claim is being processed in accordance with the terms and conditions of the policy without Prejudice.

Issued without prejudice.

For, SOTERIA Insurance Surveyors & Loss Assessors Pvt. Ltd.



Gautam Acharyya

Principal Surveyor

Corporate Survey License No: 200146 Valid upto :15.05.2027