



IRPC Public Company Limited (MRI) Division

PRESSURE RELIEF VALVE TESTING FIELD INSPECTION CERTIFICATE

Plant : C32S(SRU)
 Report No. : MRI-SV-LAW-130096
 W/O No. : 20595155
 Test Place : TNK
 Requester : MSSW
 Summary Result :

Total Quantity	1		SET
Acceptable	1		SET
Un-Acceptable	0		SET

Acceptance Criteria for Differential Pressure

(per ASME Section Section-VIII)

Pressure Range		Pressure Range	
Psi	Bar	Psi	Bar
0-70	0-4.82	+/-2	+/-0.13
71-300	4.83-20.68	+/-3%	

Acceptance Criteria for Differential Pressure

(per ASME Section-I PG 72.2)

Pressure Range		Accept Allowance	
Psi	Bar	Psi	Bar
0-70	0-4.82	+/-2	+/-0.13
71-300	4.83-20.68	+/-3%	
301-1000	20.69-68.96	+/-10	+/-0.68
>1001	>68.97	+/-1%	

Issued By : _____
 (_____)
 Date: ____/____/____

Reviewed By : _____
 (_____)
 Date: ____/____/____

Approved By : _____
 (_____)
 Date: ____/____/____

10329000F-024

IRPC Public Company Limited (MRI) Division	PRESSURE RELIEF VALVE TESTING FIELD INSPECTION CERTIFICATE	Plant :C32S(SRU)	No.: MRI-SV-LAW-130096
		Page : 1/1	Date : 27/01/2014

Item	Tag No.	Serial No.	For Line/Equipment No.	Set Pressure	Cold Diff Pressure	Test Date	Test Meduim	Initial Test		Final Test		Result	Remark
								Pop Pressure	Leak	Pop Pressure	Leak		
1	PSV182803	'15287-013'	'18E023	1.37 Bar(g)		27/09/2013	Nitro	0.94 Bar(g)	passing	1.41 Bar(g)	9 Bubble/Min	pass	