

### IRPC Public Company Limited (MRI) Division

# PRESSURE RELIEF VALVE TESTING FIELD INSPECTION CERTIFICATE

| Plant:      | C411(COLD1)   |  |  |  |  |
|-------------|---------------|--|--|--|--|
| Report No.: | MIQA-IR-49141 |  |  |  |  |

W/O No. : 4001 607037

Test Place: TNK

co;ltd.(FurnaceArea)

Requester: K. OPT/ K.MM4.

Summary Result:

| <b>Total Quantity</b> | 3 | SET |
|-----------------------|---|-----|
| Acceptable            | 3 | SET |
| Un-Acceptable         | 0 | SFT |

#### Acceptance Criteria for Differiantial Pressure

(per ASME Section Section-VIII)

| Pressure R | Range      | Pressure Range |         |  |  |  |
|------------|------------|----------------|---------|--|--|--|
| Psi        | Bar        | Psi            | Bar     |  |  |  |
| 0-70       | 0-4.82     | +/-2           | +/-0.13 |  |  |  |
| 71-300     | 4.83-20.68 | +/-3%          |         |  |  |  |

#### Acceptance Criteria for Differential Pressure

(per ASME Section-I PG 72.2)

| Pressure R | Range       | Accept Allowance |         |  |  |  |
|------------|-------------|------------------|---------|--|--|--|
| Psi        | Bar         | Psi              | Bar     |  |  |  |
| 0-70       | 0-4.82      | +/-2             | +/-0.13 |  |  |  |
| 71-300     | 4.83-20.68  | +/-3%            |         |  |  |  |
| 301-1000   | 20.69-68.96 | +/-10            | +/-0.68 |  |  |  |
| >1001      | >68.97      | +/-1%            |         |  |  |  |

| Issued By :     | Reviewed By : | Approved By :     |
|-----------------|---------------|-------------------|
| ()<br>Date: / / | (             | ) ()<br>Date: / / |

10329000F-024

IRPC Public Company Limited (MRI) Division

## PRESSURE RELIEF VALVE TESTING FIELD INSPECTION CERTIFICATE

| Plant :C411(COLD1) | No.: MIQA-IR-4914139 |
|--------------------|----------------------|
| Page : 1/1         | Date: 25/03/2014     |

|      |         |            |                                    |                 |                       |            |                | Initial Test Final Test |      |                 |              |        |        |
|------|---------|------------|------------------------------------|-----------------|-----------------------|------------|----------------|-------------------------|------|-----------------|--------------|--------|--------|
| Item | Tag No. | Serial No. | For<br>Line/Equipment<br>No.       | Set<br>Pressure | Cold Diff<br>Pressure | Test Date  | Test<br>Meduim | Pop<br>Pressure         | Leak | Pop<br>Pressure | Leak         | Result | Remark |
| 1    | PSV4404 | 'TK71793*  | '14X6ER4101AK1(C)&E440<br>6(ETP)c1 | 11 Bar(g)       |                       | 04/10/2006 | Nitro          |                         |      | 11.09 Bar(g)    | 0 Bubble/Min | pass   |        |
| 2    | PSV4601 | 'TK71802*  | '4PR4602AQ1(C)&D4601(E<br>TP)c1    | 13 Bar(g)       |                       | 04/10/2006 | Nitro          |                         |      | 12.89 Bar(g)    | 0 Bubble/Min | pass   |        |
| 3    | PSV4606 | 'TK71891*  | '6PR4639BQ1/D4605(ETP)<br>c1       | 19 Bar(g)       |                       | 04/10/2006 | Nitro          |                         |      | 19.3 Bar(g)     | 0 Bubble/Min | pass   |        |