



**Kenya Bureau of
Standards**

Standards for quality life

KEBS/T008/2019/2020

TO: ALL INTERESTED BIDDERS

REF: ADDENDUM NO. 1 - PROVISION OF REPAIR AND MAINTENANCE SERVICES OF KEBS OFFICES

The Kenya Bureau of standards wishes to provide the following clarifications:

. Page 23, there is a requirement of HND in Plumbing , Do we have such qualifications , Plumbing is done up to craft or trade level, beyond that is Mechanical Engineering , eg Diploma in Mechanical Engineering or HND in Mechanical Engineering or Degree in Mechanical Engineering.

Response: Qualification required should be Diploma in plumbing and not HND

2. Page 29, there is a requirement of HND in Woodwork , Do we have such qualifications , Woodwork is done up to craft or trade level, beyond that is Building / Civil Engineering , eg Diploma in Building / Civil Engineering or HND in Building / Civil Engineering or Degree in Mechanical Engineering.

Response: Qualification required should be Diploma in carpentry and not HND in woodwork

3. On Page 18 ,For Electrical Contractors , apart from National Construction Authority ,there is the Energy and Petroleum Regulatory Authority Registration which should form part of Mandatory .

Response: Proof of registration with EPRA is mandatory

4.

4.Specifics	Query	Response
Item No. 17	<ul style="list-style-type: none">- Kindly give clear details of the Items. It is 4-way extension or 6-Way?? Or that should be omitted.	This should be both 4-way and 6 way extension
Item No. 21	<ul style="list-style-type: none">- Kindly breakdown the exact sizes rather than the general range. This is because one can ignore some cable sizes, since it affects the total BoQ amount which is an evaluation Factor.- Kindly itemize the cable sizes to have each price entry e.g	The unit cost to be per metre for all the range of cable sizes.

	<table><tr><th>Cable size</th><th>Unit Cost</th></tr><tr><td>25mm Single Core Cable- 90Mtr Roll</td><td></td></tr><tr><td>25mm Single Core Cable - 100Mtr Roll</td><td></td></tr><tr><td>35mm Single Core Cable - 90Mtr Roll</td><td></td></tr><tr><td>35mm Single Core Cable - 100Mtr Roll</td><td></td></tr></table> <p>- Or can we have the Unit Price be per Mtr, to avoid confusion on whether it's a 90 Mtr Roll or 100 Mtr Roll</p>	Cable size	Unit Cost	25mm Single Core Cable- 90Mtr Roll		25mm Single Core Cable - 100Mtr Roll		35mm Single Core Cable - 90Mtr Roll		35mm Single Core Cable - 100Mtr Roll		
Cable size	Unit Cost											
25mm Single Core Cable- 90Mtr Roll												
25mm Single Core Cable - 100Mtr Roll												
35mm Single Core Cable - 90Mtr Roll												
35mm Single Core Cable - 100Mtr Roll												
Item No. 20	<p>- Cable description incomplete. Please specify the size of each core, is it (1.5mm, 2.5mm, 4mm, 6mm, 10mm, 16mm)</p> <p>- Please itemize the above Cable sizes, and its respective core for each to have a <i>separate price entry and not lumpsum as existing</i>. This is because one has to have a total amount at the end of the BoQ.</p> <p>- Is the price to be quoted a 100Mtr Roll or 90 Mtr Roll? Or can we have the Unit Price be per Mtr, to avoid confusion on whether it's a 90 Mtr Roll or 100 Mtr Roll</p> <p>-</p>	<p>The sizes as specified breakdown cost per meter for each of the cable size</p> <p>1.5mm, 2.5mm, 4mm, 6mm, 10mm, and 16mm</p>										
Item No. 23	<p>- Kindly itemize the cable sizes needed. Between 1.5mm – 300mm is quite a broad range</p>	<p>The range remains the same include prices of</p>										

	<p>of cables, whereas some cable sizes are not even applicable for facility maintenance needs, unless new projects.</p> <ul style="list-style-type: none"> - Let each cable size has its own price entry. 	<p>each of the sizes per metre.</p> <p>1.5mm to 300mm</p>
Item No. 2	<ul style="list-style-type: none"> - Let each cable size has its own price entry. 	Each cable to be priced independently
Item No. 33 & 34	<ul style="list-style-type: none"> - Kindly clarify on the wattage? 50W, 100W, 150W e.t.c 	The wattage of the items should be 50w, 100w and 150w
Item No. 32 & 36	<ul style="list-style-type: none"> - Is it Single or Twin? 	The switches and boxes should be both single and twin
Item No. 30	<ul style="list-style-type: none"> - Kindly clarify the sizes? 	The sizes to be compatible with voltage of 220v with ranges from 20/30 μ F to 80/138/182 μ F

NOTE THIS ADDENDUM SHALL BE CONSTRUED TO FORM PART OF THE TENDER DOCUMENT

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME

MANAGING DIRECTOR