

Maxxam Job #: B809848
Report Date: 2018/02/13

TETRA TECH CANADA INC.
Client Project #: ENW.VENW03150-01
Site Location: SD68 LEAD DW TESTING
Sampler Initials: BB

ELEMENTS BY ATOMIC SPECTROSCOPY (DRINKING WATER)

Maxxam ID			SY0408	SY0409	SY0410		
Sampling Date			2018/01/29	2018/01/29	2018/01/29		
COC Number			546212-07-01	546212-07-01	546212-07-01		
	UNITS	MAC	18DC17-30S	18DC18-30S	18DC20-30S	RDL	QC Batch
Total Metals by ICPMS							
Total Lead (Pb)	ug/L	10	4.38	4.91	13.3	0.20	8907060
No Fill	No Exceedance						
Grey	Exceeds 1 criteria policy/level						
Black	Exceeds both criteria/levels						
RDL = Reportable Detection Limit							

Maxxam Job #: B809848
Report Date: 2018/02/13

TETRA TECH CANADA INC.
Client Project #: ENW.VENW03150-01
Site Location: SD68 LEAD DW TESTING
Sampler Initials: BB

GENERAL COMMENTS

Each temperature is the average of up to three cooler temperatures taken at receipt

Package 1	8.7°C
-----------	-------

MAC: The guidelines that have been included in this report have been taken from the Canadian Drinking Water Quality Summary Table, February 2017.

Criteria A = Maximum Acceptable Concentration (MAC) / Criteria B = Aesthetic Objectives (AO) / Criteria C = Operational Guidance Values (OG)
It is recommended to consult these guidelines when interpreting your data since there are non-numerical guidelines that are not included on this report.

Turbidity Guidelines:

1. Chemically assisted filtration: less than or equal to 0.3 NTU in 95% of the measurements or 95% of the time each month. Shall not exceed 1.0 NTU at any time.
2. Slow sand / diatomaceous earth filtration: less than or equal to 1.0 NTU in 95% of the measurements or 95% of the time each month. Shall not exceed 3.0 NTU at any time.
3. Membrane filtration: less than or equal to 0.1 NTU in 99% of the measurements made or at least 99% of the time each calendar month. Shall not exceed 0.3 NTU at any time.

Results relate only to the items tested.

Maxxam Job #: B809848
Report Date: 2018/02/13

QUALITY ASSURANCE REPORT

TETRA TECH CANADA INC.
Client Project #: ENW.VENW03150-01
Site Location: SD68 LEAD DW TESTING
Sampler Initials: BB

QC Batch	Parameter	Date	Matrix Spike		Spiked Blank		Method Blank		RPD	
			% Recovery	QC Limits	% Recovery	QC Limits	Value	UNITS	Value (%)	QC Limits
8907050	Total Lead (Pb)	2018/02/09	96	80 - 120	98	80 - 120	<0.20	ug/L	9.0	20
8907060	Total Lead (Pb)	2018/02/10	104	80 - 120	95	80 - 120	<0.20	ug/L	4.7	20

Duplicate: Paired analysis of a separate portion of the same sample. Used to evaluate the variance in the measurement.

Matrix Spike: A sample to which a known amount of the analyte of interest has been added. Used to evaluate sample matrix interference.

Spiked Blank: A blank matrix sample to which a known amount of the analyte, usually from a second source, has been added. Used to evaluate method accuracy.

Method Blank: A blank matrix containing all reagents used in the analytical procedure. Used to identify laboratory contamination.

Maxxam Job #: B809848
Report Date: 2018/02/13

TETRA TECH CANADA INC.
Client Project #: ENW.VENW03150-01
Site Location: SD68 LEAD DW TESTING
Sampler Initials: BB

VALIDATION SIGNATURE PAGE

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).



Rob Reinert, B.Sc., Scientific Specialist

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

INVOICE TO:		Report Information		Project Information	
Company Name: #1433 TETRA TECH CANADA INC.		Company Name: Darren Thomas		Quotation #: B71611	
Contact Name: Darren Thomas		Contact Name: Darren Thomas		P.O. #: ENW.VENW03150-01	
Address: #1 - 4376 BOBAN DRIVE NANAIMO BC V9T 6A7		Address:		Project #: SD65 Lead on Test	
Phone: (250) 756-2256 x Fax: (250) 756-2686 x		Phone:		Project Name: Ben Barton / Darren Thomas	
Email: Darren.Thomas@tetratech.com; EBA.Labdata@tetratec		Email: Darren.Thomas@tetratech.com; EBA.Labdata@tetratec		Site #: Ben Barton / Darren Thomas	
Regulatory Criteria:		Special Instructions:		ANALYSIS REQUESTED (PLEASE BE SPECIFIC)	
☐ CSR ☐ CCME ☐ BC Water Quality ☒ Other Health Canada				Turnaround Time (TAT) Required: Please provide advance notice for rush projects Regular (Standard) TAT: (will be applied if Rush TAT is not specified): Standard TAT = 5-7 Working days for most tests. Please note: Standard TAT for certain tests such as BOD and Dioxins/Furans are > 5 days - contact your Project Manager for details. Job Specific Rush TAT (if applies to entire submission) 1 DAY ☐ 2 Day ☐ 3 Day ☐ Date Required: Rush Confirmation Number: (call lab for #) # of Bottles Comments	
SAMPLES MUST BE KEPT COOL (< 10°C) FROM TIME OF SAMPLING UNTIL DELIVERY TO MAXXAM					
Sample Barcode Label	Sample (Location) Identification	Date Sampled	Time Sampled	Matrix	Metals Field Filtered ? (Y/N)
1	GA05-30s	18/01/29	12:00 midnight water	n	X
2	GA06-30s	↓	↓	n	X
3	GA08-30s			n	X
4	GA12-30s			n	X
5	GA13-30s			n	X
6	GA16-30s			n	X
7	GA20-30s			n	X
8	PA01-30s		03:00	n	X
9	PA02-30s	↓	↓	n	X
10	PA03-30s			n	X
* RELINQUISHED BY: (Signature/Print)		Date: (YY/MM/DD)	Time	RECEIVED BY: (Signature/Print)	
		18/02/07	16:00		
				Date: (YY/MM/DD)	Time
				2018/02/08	08:40
				# jars used and not submitted	Lab Use Only
				Time Sensitive ☐	Temperature (°C) on Receipt: 9.8.9
					Custody Seal Intact on Cooler? ☐ Yes ☒ No N/A
* UNLESS OTHERWISE AGREED TO IN WRITING, WORK SUBMITTED ON THIS CHAIN OF CUSTODY IS SUBJECT TO MAXXAM'S STANDARD TERMS AND CONDITIONS. SIGNING OF THIS CHAIN OF CUSTODY DOCUMENT IS ACKNOWLEDGMENT AND ACCEPTANCE OF OUR TERMS WHICH ARE AVAILABLE FOR VIEWING AT WWW.MAXXAM.CA/TERMS. * IT IS THE RESPONSIBILITY OF THE RELINQUISHER TO ENSURE THE ACCURACY OF THE CHAIN OF CUSTODY RECORD. AN INCOMPLETE CHAIN OF CUSTODY MAY RESULT IN ANALYTICAL TAT DELAYS.					



Page 1 of 7
 Bottle Order #:
 546212
 Project Manager
 Letitia Prefontaine

INVOICE TO:		Report Information		Project Information	
Company Name	#1433 TETRA TECH CANADA INC.	Company Name		Quotation #	B71611
Contact Name	Darren Thomas	Contact Name	Darren Thomas	P.O. #	
Address	#1 - 4376 BOBAN DRIVE NANAIMO BC V9T 6A7 (250) 756-2256 x Fax: (250) 756-2686 x	Address		Project #	ENW.VENW03150-01
Phone		Phone		Project Name	SBSB Old Lead Testing
Email	Darren.Thomas@tetratech.com; EBA.Labdata@tetratec	Email	Darren.Thomas@tetratech.com; EBA.Labdata@tetratec	Site #	
				Sampled By	Ben Dutton Darren Thomas



B809848_COC



C#546212-06-01

ile Order #:



546212

act Manager

Letitia Prefontaine

Regulatory Criteria:	Special Instructions	ANALYSIS REQUESTED (PLEASE BE SPECIFIC)							Turnaround Time (TAT) Required:
☐ CSR									Please provide advance notice for rush projects
☐ CCME									Regular (Standard) TAT: (will be applied if Rush TAT is not specified) Standard TAT = 5-7 Working days for most tests.
☐ BC Water Quality									Please note: Standard TAT for certain tests such as BOD and Dioxins/Furans are > 7 days - contact your Project Manager for details.
☒ Other <i>Health Canada</i>									Job Specific Rush TAT (if applies to entire submission)

SAMPLES MUST BE KEPT COOL ($\leq 10^{\circ}\text{C}$) FROM TIME OF SAMPLING UNTIL DELIVERY TO MAXAM

	Sample Barcode Label	Sample (Location) Identification	Date Sampled	Time Sampled	Matrix	Metal	Lead	# of Bottles	Comments
1		PAD7-30s	18/01/29	03:00	Water	n	+	1	
2		PAV -30s				n	+	1	
3		PA16-30s				n	+	1	
4		PA17-30s				n	+	1	
5		SBO7 PADUP-30s				n	X	1	
6		SBO7-30s				n	+	1	
7		18 STOS-30s				n	+	1	
8		18 STOB-30s				n	+	1	
9		18 DC03-30s				n	+	1	
10		18 DC 04-30s				n	X	1	

* RELINQUISHED BY: (Signature/Print)	Date: (YY/MM/DD)	Time	RECEIVED BY: (Signature/Print)	Date: (YY/MM/DD)	Time	# jers used and not submitted	Lab Use Only	
 Darren Thomas	18/12/07	15:00	 JULIE PEORDACK	20/12/08	08:40		Time Sensitive ☐	Temperature (°C) on Receipt 9.8.9
							Custody Seal Intact on Cooler? ☐ Yes ☐ No 	

* UNLESS OTHERWISE AGREED TO IN WRITING, WORK SUBMITTED ON THIS CHAIN OF CUSTODY IS SUBJECT TO MAXXAM'S STANDARD TERMS AND CONDITIONS. SIGNING OF THIS CHAIN OF CUSTODY DOCUMENT IS ACKNOWLEDGMENT AND ACCEPTANCE OF OUR TERMS WHICH ARE AVAILABLE FOR VIEWING AT WWW.MAXXAM.CATERMIS

IT IS THE RESPONSIBILITY OF THE RELINQUISHER TO ENSURE THE ACCURACY OF THE CHAIN OF CUSTODY RECORD. AN INCOMPLETE CHAIN OF CUSTODY MAY RESULT IN ANALYTICAL TAT DELAYS

Maxxam Analytics International Corporation o/a Maxxam Analytics



Maxxam Analytics International Corporation o/a Maxxam Analytics
4608 Canada Way, Burnaby, British Columbia Canada V5G 1K5 Tel: (604) 734 7276 Toll-free 800-563-6266 Fax: (604) 731 2386 www.maxxam.ca

Page 3 of 3

INVOICE TO:		Report Information		Project Information	
Company Name	#1433 TETRA TECH CANADA INC.	Company Name	Darren Thomas	Quotation #	B71611
Contact Name	Darren Thomas	Contact Name	Darren Thomas	P.O. #	
Address	#1 - 4376 BOBAN DRIVE NANAIMO BC V9T 6A7	Address		Project #	ENW.VENW03150-01
Phone	(250) 756-2256 x	Phone		Project Name	SKS On lead testing
Email	Darren.Thomas@tetratech.com; EBA.Labdata@tetratec	Email	Darren.Thomas@tetratech.com; EBA.Labdata@tetratec	Site #	Res. Benton / Darren Thomas
Regulatory Criteria:		Special Instructions		ANALYSIS REQUESTED (PLEASE BE SPECIFIC)	
☐ CSR ☐ CCME ☐ BC Water Quality ☒ Other <i>Health Canada</i>					
SAMPLER MUST BE KEPT COOL (< 10°C) FROM TIME OF SAMPLING UNTIL DELIVERY TO MAXXAM					
Sample Barcode Label	Sample (Location) Identification	Date Sampled	Time Sampled	Matrix	
1	18 DC 08 - 30s	15/02/29		water	n +
2	18 DC 09 - 30s				n +
3	18 DC 13 - 30s				n +
4	18 DC 17 - 30s				n +
5	18 DC 18 - 30s				n +
6	18 DC 20 - 30s				n +
7	18 ST 09 - 30s				n +
8					
9					
10					
* RELINQUISHED BY: (Signature/Print)		Date: (YY/MM/DD)	Time	RECEIVED BY: (Signature/Print)	
<i>Darren Thomas</i>		15/02/27	12:00	<i>MU PEDRO TACK</i>	
				Date: (YY/MM/DD)	Time
				2015/02/08	08:40
# Jars used and not submitted		Time Sensitive		Temperature (°C) on Receipt	
				9.8.9	
Custody Seal Intact on Cooler?		Custody Seal Intact on Cooler?		Custody Seal Intact on Cooler?	
☐ Yes ☒ No		☐ Yes ☒ No		☐ Yes ☒ No	
White: Maxxam Yellow: Client		White: Maxxam Yellow: Client		White: Maxxam Yellow: Client	

* UNLESS OTHERWISE AGREED TO IN WRITING, WORK SUBMITTED ON THIS CHAIN OF CUSTODY IS SUBJECT TO MAXXAM'S STANDARD TERMS AND CONDITIONS. SIGNING OF THIS CHAIN OF CUSTODY DOCUMENT IS ACKNOWLEDGMENT AND ACCEPTANCE OF OUR TERMS WHICH ARE AVAILABLE FOR VIEWING AT WWW.MAXXAM.CA/TERMS.

* IT IS THE RESPONSIBILITY OF THE RELINQUISHER TO ENSURE THE ACCURACY OF THE CHAIN OF CUSTODY RECORD. AN INCOMPLETE CHAIN OF CUSTODY MAY RESULT IN ANALYTICAL TAT DELAYS.

Maxxam Analytics International Corporation o/a Maxxam Analytics

Your Project #: ENW.VENW03150
Site Location: SD68 DW TESTING

Attention: Ben Barton

TETRA TECH CANADA INC.
#1 - 4376 BOBAN DRIVE
NANAIMO, BC
Canada V9T 6A7

Your C.O.C. #: 545893-11-01, 545893-12-01, 545893-13-01, 545893-14-01, 545893-15-01

Report Date: 2018/02/06
Report #: R2510628
Version: 1 - Final

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: B807281

Received: 2018/01/30, 08:48

Sample Matrix: DRINKING WATER
Samples Received: 47

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Analytical Method
Elements by CRC ICPMS (total)	38	N/A	2018/01/31	BBY7SOP-00003,	EPA 6020b R2 m
Elements by CRC ICPMS (total)	9	N/A	2018/02/02	BBY7SOP-00003,	EPA 6020b R2 m

Remarks:

Maxxam Analytics' laboratories are accredited to ISO/IEC 17025:2005 for specific parameters on scopes of accreditation. Unless otherwise noted, procedures used by Maxxam are based upon recognized Provincial, Federal or US method compendia such as CCME, MDDELCC, EPA, APHA.

All work recorded herein has been done in accordance with procedures and practices ordinarily exercised by professionals in Maxxam's profession using accepted testing methodologies, quality assurance and quality control procedures (except where otherwise agreed by the client and Maxxam in writing). All data is in statistical control and has met quality control and method performance criteria unless otherwise noted. All method blanks are reported; unless indicated otherwise, associated sample data are not blank corrected.

Maxxam Analytics' liability is limited to the actual cost of the requested analyses, unless otherwise agreed in writing. There is no other warranty expressed or implied. Maxxam has been retained to provide analysis of samples provided by the Client using the testing methodology referenced in this report. Interpretation and use of test results are the sole responsibility of the Client and are not within the scope of services provided by Maxxam, unless otherwise agreed in writing.

Solid sample results, except biota, are based on dry weight unless otherwise indicated. Organic analyses are not recovery corrected except for isotope dilution methods.

Results relate to samples tested.

This Certificate shall not be reproduced except in full, without the written approval of the laboratory.

Reference Method suffix "m" indicates test methods incorporate validated modifications from specific reference methods to improve performance.

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

Your Project #: ENW.VENW03150
Site Location: SD68 DW TESTING

Attention: Ben Barton

TETRA TECH CANADA INC.
#1 - 4376 BOBAN DRIVE
NANAIMO, BC
Canada V9T 6A7

Your C.O.C. #: 545893-11-01, 545893-12-01, 545893-13-01, 545893-14-01, 545893-15-01

Report Date: 2018/02/06
Report #: R2510628
Version: 1 - Final

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: B807281
Received: 2018/01/30, 08:48

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.
Letitia Prefontaine, B.Sc., Senior Project Manager
Email: LPrefontaine@maxxam.ca
Phone# (604)639-2616
=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

Maxxam Job #: B807281
Report Date: 2018/02/06

TETRA TECH CANADA INC.
Client Project #: ENW.VENW03150
Site Location: SD68 DW TESTING
Sampler Initials: DT

ELEMENTS BY ATOMIC SPECTROSCOPY (DRINKING WATER)

Maxxam ID			SW7411	SW7412	SW7413	SW7414	SW7415	SW7416		
Sampling Date			2018/01/28 12:00	2018/01/28 12:00	2018/01/28 12:00	2018/01/28 12:00	2018/01/28 12:00	2018/01/28 12:00		
COC Number			545893-11-01	545893-11-01	545893-11-01	545893-11-01	545893-11-01	545893-11-01		
	UNITS	MAC	GA01-OS	GA02-OS	GA03-OS	GA04-OS	GA05-OS	GA06-OS	RDL	QC Batch

Total Metals by ICPMS

Total Lead (Pb)	ug/L	10	6.98	3.76	1.11	7.51	15.8	11.1	0.20	8898737
-----------------	------	----	------	------	------	------	-------------	-------------	------	---------

No Fill	No Exceedance
Grey	Exceeds 1 criteria policy/level
Black	Exceeds both criteria/levels

RDL = Reportable Detection Limit

Maxxam ID			SW7417	SW7418	SW7419	SW7420	SW7421	SW7422		
Sampling Date			2018/01/28 12:00	2018/01/28 12:00	2018/01/28 12:00	2018/01/28 12:00	2018/01/28 12:00	2018/01/28 12:00		
COC Number			545893-11-01	545893-11-01	545893-11-01	545893-11-01	545893-12-01	545893-12-01		
	UNITS	MAC	GA07-OS	GA08-OS	GA09-OS	GA10-OS	GA11-OS	GA12-OS	RDL	QC Batch

Total Metals by ICPMS

Total Lead (Pb)	ug/L	10	6.08	20.7	4.67	0.50	6.46	10.7	0.20	8898737
-----------------	------	----	------	-------------	------	------	------	-------------	------	---------

No Fill	No Exceedance
Grey	Exceeds 1 criteria policy/level
Black	Exceeds both criteria/levels

RDL = Reportable Detection Limit

Maxxam ID			SW7423	SW7424	SW7425	SW7426	SW7427	SW7428		
Sampling Date			2018/01/28 12:00	2018/01/28 12:00	2018/01/28 12:00	2018/01/28 12:00	2018/01/28 12:00	2018/01/28 12:00		
COC Number			545893-12-01	545893-12-01	545893-12-01	545893-12-01	545893-12-01	545893-12-01		
	UNITS	MAC	GA13-OS	GA14-OS	GA15-OS	GA16-OS	GA17-OS	GA18-OS	RDL	QC Batch

Total Metals by ICPMS

Total Lead (Pb)	ug/L	10	12.5	8.13	7.87	13.2	0.55	1.59	0.20	8898737
-----------------	------	----	-------------	------	------	-------------	------	------	------	---------

No Fill	No Exceedance
Grey	Exceeds 1 criteria policy/level
Black	Exceeds both criteria/levels

RDL = Reportable Detection Limit

Maxxam Job #: B807281
Report Date: 2018/02/06

TETRA TECH CANADA INC.
Client Project #: ENW.VENW03150
Site Location: SD68 DW TESTING
Sampler Initials: DT

ELEMENTS BY ATOMIC SPECTROSCOPY (DRINKING WATER)

Maxxam ID			SW7429		SW7430	SW7439	SW7440	SW7441		
Sampling Date			2018/01/28 12:00		2018/01/28 12:00	2018/01/28 12:00	2018/01/28 03:00	2018/01/28 03:00		
COC Number			545893-12-01		545893-12-01	545893-13-01	545893-13-01	545893-13-01		
	UNITS	MAC	GA19-OS	QC Batch	GA20-OS	GADUP-OS	PA01-OS	PA02-OS	RDL	QC Batch
Total Metals by ICPMS										
Total Lead (Pb)	ug/L	10	8.22	8898737	9.32	8.78	13.7	17.3	0.20	8898755
No Fill	No Exceedance									
Grey	Exceeds 1 criteria policy/level									
Black	Exceeds both criteria/levels									
RDL = Reportable Detection Limit										

Maxxam Job #: B807281
Report Date: 2018/02/06

TETRA TECH CANADA INC.
Client Project #: ENW.VENW03150
Site Location: SD68 DW TESTING
Sampler Initials: DT

ELEMENTS BY ATOMIC SPECTROSCOPY (DRINKING WATER)

Maxxam ID			SW7442	SW7443	SW7444	SW7445	SW7446	SW7447		
Sampling Date			2018/01/28 03:00	2018/01/28 03:00	2018/01/28 03:00	2018/01/28 03:00	2018/01/28 03:00	2018/01/28 03:00		
COC Number			545893-13-01	545893-13-01	545893-13-01	545893-13-01	545893-13-01	545893-13-01		
	UNITS	MAC	PA03-OS	PA04-OS	PA05-OS	PA06-OS	PA07-OS	PA08-OS	RDL	QC Batch

Total Metals by ICPMS

Total Lead (Pb)	ug/L	10	18.7	6.60	1.20	1.41	15.0	4.33	0.20	8898755
-----------------	------	----	------	------	------	------	------	------	------	---------

No Fill	No Exceedance
Grey	Exceeds 1 criteria policy/level
Black	Exceeds both criteria/levels

RDL = Reportable Detection Limit

Maxxam ID			SW7448	SW7449	SW7450	SW7451	SW7452	SW7453		
Sampling Date			2018/01/28 03:00	2018/01/28 03:00	2018/01/28 03:00	2018/01/28 03:00	2018/01/28 03:00	2018/01/28 03:00		
COC Number			545893-13-01	545893-14-01	545893-14-01	545893-14-01	545893-14-01	545893-14-01		
	UNITS	MAC	PA09-OS	PA10-OS	PA11-OS	PA12-OS	PA13-OS	PA14-OS	RDL	QC Batch

Total Metals by ICPMS

Total Lead (Pb)	ug/L	10	3.75	1.03	30.2	3.29	3.07	4.19	0.20	8898755
-----------------	------	----	------	------	------	------	------	------	------	---------

No Fill	No Exceedance
Grey	Exceeds 1 criteria policy/level
Black	Exceeds both criteria/levels

RDL = Reportable Detection Limit

Maxxam ID			SW7454	SW7455	SW7456		SW7457	SW7458		
Sampling Date			2018/01/28 03:00	2018/01/28 03:00	2018/01/28 03:00		2018/01/28 03:00	2018/01/28 05:00		
COC Number			545893-14-01	545893-14-01	545893-14-01		545893-14-01	545893-14-01		
	UNITS	MAC	PA15-OS	PA16-OS	PA17-OS	QC Batch	PADUP-OS	SB01-OS	RDL	QC Batch

Total Metals by ICPMS

Total Lead (Pb)	ug/L	10	5.69	17.2	65.1	8898755	49.3	6.68	0.20	8898774
-----------------	------	----	------	------	------	---------	------	------	------	---------

No Fill	No Exceedance
Grey	Exceeds 1 criteria policy/level
Black	Exceeds both criteria/levels

RDL = Reportable Detection Limit

Maxxam Job #: B807281
Report Date: 2018/02/06

TETRA TECH CANADA INC.
Client Project #: ENW.VENW03150
Site Location: SD68 DW TESTING
Sampler Initials: DT

ELEMENTS BY ATOMIC SPECTROSCOPY (DRINKING WATER)

Maxxam ID			SW7460	SW7461	SW7462	SW7463	SW7464	SW7465		
Sampling Date			2018/01/28 05:00	2018/01/28 05:00	2018/01/28 05:00	2018/01/28 05:00	2018/01/28 05:00	2018/01/28 05:00		
COC Number			545893-15-01	545893-15-01	545893-15-01	545893-15-01	545893-15-01	545893-15-01		
	UNITS	MAC	SB02-OS	SB03-OS	SB04-OS	SB05-OS	SB06-OS	SB07-OS	RDL	QC Batch

Total Metals by ICPMS

Total Lead (Pb)	ug/L	10	8.70	4.34	0.47	2.89	0.42	10.8	0.20	8898774
-----------------	------	----	------	------	------	------	------	-------------	------	---------

No Fill	No Exceedance
Grey	Exceeds 1 criteria policy/level
Black	Exceeds both criteria/levels
RDL = Reportable Detection Limit	

Maxxam Job #: B807281
Report Date: 2018/02/06

TETRA TECH CANADA INC.
Client Project #: ENW.VENW03150
Site Location: SD68 DW TESTING
Sampler Initials: DT

ELEMENTS BY ATOMIC SPECTROSCOPY (DRINKING WATER)

Maxxam ID			SW7466		
Sampling Date			2018/01/28 05:00		
COC Number			545893-15-01		
	UNITS	MAC	SBDUP-OS	RDL	QC Batch
Total Metals by ICPMS					
Total Lead (Pb)	ug/L	10	0.75	0.20	8898774
No Fill	No Exceedance				
Grey	Exceeds 1 criteria policy/level				
Black	Exceeds both criteria/levels				
RDL = Reportable Detection Limit					

Maxxam Job #: B807281
Report Date: 2018/02/06

TETRA TECH CANADA INC.
Client Project #: ENW.VENW03150
Site Location: SD68 DW TESTING
Sampler Initials: DT

GENERAL COMMENTS

Each temperature is the average of up to three cooler temperatures taken at receipt

Package 1	4.3°C
-----------	-------

COC page 5 of 5 line # 6, SB06-OS : 1x 120mL plastic preserved with HNO₃ received with incorrect labels. Sample labeled as SB07-OS, inspected as per sample label.

MAC: The guidelines that have been included in this report have been taken from the Canadian Drinking Water Quality Summary Table, February 2017.

Criteria A = Maximum Acceptable Concentration (MAC) / Criteria B = Aesthetic Objectives (AO) / Criteria C = Operational Guidance Values (OG)
It is recommended to consult these guidelines when interpreting your data since there are non-numerical guidelines that are not included on this report.

Turbidity Guidelines:

1. Chemically assisted filtration: less than or equal to 0.3 NTU in 95% of the measurements or 95% of the time each month. Shall not exceed 1.0 NTU at any time.
2. Slow sand / diatomaceous earth filtration: less than or equal to 1.0 NTU in 95% of the measurements or 95% of the time each month. Shall not exceed 3.0 NTU at any time.
3. Membrane filtration: less than or equal to 0.1 NTU in 99% of the measurements made or at least 99% of the time each calendar month. Shall not exceed 0.3 NTU at any time.

Results relate only to the items tested.

Maxxam Job #: B807281
Report Date: 2018/02/06

QUALITY ASSURANCE REPORT

TETRA TECH CANADA INC.
Client Project #: ENW.VENW03150
Site Location: SD68 DW TESTING
Sampler Initials: DT

QC Batch	Parameter	Date	Matrix Spike		Spiked Blank		Method Blank		RPD	
			% Recovery	QC Limits	% Recovery	QC Limits	Value	UNITS	Value (%)	QC Limits
8898737	Total Lead (Pb)	2018/01/31	97	80 - 120	98	80 - 120	<0.20	ug/L	0.40	20
8898755	Total Lead (Pb)	2018/01/31	99	80 - 120	97	80 - 120	<0.20	ug/L	2.2	20
8898774	Total Lead (Pb)	2018/02/02	93	80 - 120	102	80 - 120	<0.20	ug/L	1.5	20

Duplicate: Paired analysis of a separate portion of the same sample. Used to evaluate the variance in the measurement.

Matrix Spike: A sample to which a known amount of the analyte of interest has been added. Used to evaluate sample matrix interference.

Spiked Blank: A blank matrix sample to which a known amount of the analyte, usually from a second source, has been added. Used to evaluate method accuracy.

Method Blank: A blank matrix containing all reagents used in the analytical procedure. Used to identify laboratory contamination.

Maxxam Job #: B807281
Report Date: 2018/02/06

TETRA TECH CANADA INC.
Client Project #: ENW.VENW03150
Site Location: SD68 DW TESTING
Sampler Initials: DT

VALIDATION SIGNATURE PAGE

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).



Andy Lu, Ph.D., P.Chem., Scientific Specialist

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. For Service Group specific validation please refer to the Validation Signature Page.



Maxxam Analytics International Corporation o/a Maxxam Analytics
4606 Canada Way, Burnaby, British Columbia Canada V5G 1K5 Tel: (604) 734 7276 Toll-free 800-563-6256 Fax: (604) 731 2386 www.maxxam.ca

Chain Of Custody Record

1 of 5

INVOICE TO:		Report Information		Project Information	
Company Name:	#1433 TETRA TECH CANADA INC.	Company Name:	Seal as mobile	Quotation #	B60578
Contact Name:	Ben Barton	Contact Name:		P.O. #	
Address:	#1 - 4376 BOBAN DRIVE NANAIMO BC V9T 6A7	Address:		Project #	ENW VENW03150
Phone:	(250) 756-2256 x	Phone:		Project Name:	SD65 New testing
Email:	bbarton@eba.ca; EBA.Labdata@tetratech.com	Email:		Site #	
				Sampled By:	Dan Thomas



B807281_COC

ler #:
:
nager
ntaine

Regulatory Criteria:		Special Instructions		ANALYSIS REQUESTED (PLEASE BE SPECIFIC)										Turnaround Time (TAT) Required:			
☐ CSR ☐ CCME ☐ BC Water Quality ☒ Other <i>BC Health Care de DWQGL</i>														Please provide advance notice for rush projects			
														Regular (Standard) TAT: (will be applied if Rush TAT is not specified) Standard TAT = 5-7 Working days for most tests. Please note: Standard TAT for certain tests such as BOD and Dioxins/Furans are > 5 days - contact your Project Manager for details.			
														Job Specific Rush TAT (if applies to entire submission) 1 DAY ☐ 2 Day ☐ 3 Day ☐ Date Required ☐			
														Rush Confirmation Number: ☐ (call lab for #)			
SAMPLES MUST BE KEPT COOL (< 10°C) FROM TIME OF SAMPLING UNTIL DELIVERY TO MAXXAM														# of Bottles		Comments	
Sample Barcode Label	Sample (Location) Identification	Date Sampled	Time Sampled	Matrix	Metals Field Filtered ? (Y/N)	Lead - Drinking Water											
GA01-0s	GA01-0s	15/01/28	12:00pm	Water	N	X										1	
GA02-0s	GA02-0s				N	X										1	
GA03-0s	GA03-0s				N	X										1	
GA04-0s	GA04-0s				N	X										1	
GA05-0s	GA05-0s				N	X										1	
GA06-0s	GA06-0s				N	X										1	
GA07-0s	GA07-0s				N	X										1	
GA08-0s	GA08-0s				N	X										1	
GA09-0s	GA09-0s				N	X										1	
GA10-0s	GA10-0s				N	X										1	
RELINQUISHED BY: (Signature/Print)		Date: (YY/MM/DD)	Time	RECEIVED BY: (Signature/Print)		Date: (YY/MM/DD)	Time	# jars used and not submitted	Lab Use Only		Time Sensitive		Temperature (°C) on Receipt		Custody Seal Intact on Cooler?		
<i>[Signature]</i>		15/01/28	9:00	<i>[Signature]</i>		2016/01/28	08:46				☐		4, 5, 4		☐ Yes ☒ No		
* UNLESS OTHERWISE AGREED TO IN WRITING, WORK SUBMITTED ON THIS CHAIN OF CUSTODY IS SUBJECT TO MAXXAM'S STANDARD TERMS AND CONDITIONS. SIGNING OF THIS CHAIN OF CUSTODY DOCUMENT IS ACKNOWLEDGMENT AND ACCEPTANCE OF OUR TERMS WHICH ARE AVAILABLE FOR VIEWING AT WWW.MAXXAM.CA/TERMS.																	
* IT IS THE RESPONSIBILITY OF THE RELINQUISHER TO ENSURE THE ACCURACY OF THE CHAIN OF CUSTODY RECORD. AN INCOMPLETE CHAIN OF CUSTODY MAY RESULT IN ANALYTICAL TAT DELAYS.																	

106-485

Maxxam Analytics International Corporation o/a Maxxam Analytics



Maxxam Analytics International Corporation o/a Maxxam Analytics
4606 Canada Way, Burnaby, British Columbia Canada V5G 1K5 Tel: (604) 734 7276 Toll-free 800-563-6266 Fax: (604) 731 2386 www.maxxam.ca

Chain Of Custody Record

Page 2 of 5

INVOICE TO:		Report Information		Project Information	
Company Name	#1433 TETRA TECH CANADA INC.	Company Name	Same as Invoice to	Quotation #	B60578
Contact Name	Ben Barton	Contact Name		P.O. #	
Address	#1 - 4376 BOBAN DRIVE NANAIMO BC V9T 6A7	Address		Project #	ENW.VENW03150
Phone	(250) 756-2256 x Fax: (250) 756-2686 x	Phone		Project Name	SDGS Water Testing
Email	bbarton@eba.ca; EBA.Labdata@tetratech.com	Email		Site #	
				Sampled By	Darren Thomas



B807281_COC

Order #:
93
anager
ontaine

Regulatory Criteria:		Special Instructions		ANALYSIS REQUESTED (PLEASE BE SPECIFIC)										Turnaround Time (TAT) Required:					
☐ CSR ☐ CCME ☐ BC Water Quality ☒ Other Health Canada DRUGS														Please provide advance notice for rush projects					
SAMPLES MUST BE KEPT COOL (< 10°C) FROM TIME OF SAMPLING UNTIL DELIVERY TO MAXXAM														Regular (Standard) TAT:					
														(will be applied if Rush TAT is not specified): Standard TAT = 5-7 Working days for most tests.					
														Please note: Standard TAT for certain tests such as BOD and Dioxins/Furans are > 5 days - contact your Project Manager for details.					
														Job Specific Rush TAT (if applies to entire submission)					
														1 DAY ☐ 2 Day ☐ 3 Day ☐ Date Required: ☐					
														Rush Confirmation Number: ☐					
														(call lab for #)					
														# of Bottles					
														Comments					
Sample Barcode Label	Sample (Location) Identification	Date Sampled	Time Sampled	Matrix	Metals Field Filtered ? (Y/N)	Lead - Drinking Water													
1	GA11-0s	18/01/28	9:00	Water	N	X													
2	GA12-0s				N	X													
3	GA13-0s				N	X													
4	GA14-0s				N	X													
5	GA15-0s				N	X													
6	GA16-0s				N	X													
7	GA17-0s				N	X													
8	GA18-0s				N	X													
9	GA19-0s				N	X													
10	GA20-0s				N	X													
RELINQUISHED BY: (Signature/Print)		Date: (YY/MM/DD)	Time	RECEIVED BY: (Signature/Print)		Date: (YY/MM/DD)	Time	# Jars used and not submitted	Lab Use Only										
Darren Thomas		18/01/28	9:00	POMMER GOTA		20/01/20	08:46		Time Sensitive	Temperature (°C) on Receipt		Custody Seal Intact on Cooler?							
									☐	4.5.4		☐ Yes ☒ No							
* UNLESS OTHERWISE AGREED TO IN WRITING, WORK SUBMITTED ON THIS CHAIN OF CUSTODY IS SUBJECT TO MAXXAM'S STANDARD TERMS AND CONDITIONS. SIGNING OF THIS CHAIN OF CUSTODY DOCUMENT IS ACKNOWLEDGMENT AND ACCEPTANCE OF OUR TERMS WHICH ARE AVAILABLE FOR VIEWING AT WWW.MAXXAM.CA/TERMS.																		White: Maxxam Yellow: Client	
* IT IS THE RESPONSIBILITY OF THE RELINQUISHER TO ENSURE THE ACCURACY OF THE CHAIN OF CUSTODY RECORD. AN INCOMPLETE CHAIN OF CUSTODY MAY RESULT IN ANALYTICAL TAT DELAYS.																			

196-4ES

Maxxam Analytics International Corporation o/a Maxxam Analytics



Maxxam Analytics International Corporation o/a Maxxam Analytics
4606 Canada Way, Burnaby, British Columbia Canada V5G 1K5 Tel: (604) 734 7276 Toll-free: 800-563-6266 Fax: (604) 731 2385 www.maxxam.ca

Chain Of Custody Record

Page 3 of 5

INVOICE TO:		Report Information		Project Information	
Company Name	#1433 TETRA TECH CANADA INC.	Company Name	Same as invoice to	Quotation #	B60578
Contact Name	Ben Barton	Contact Name		P.O. #	
Address	#1 - 4376 BOBAN DRIVE NANAIMO BC V9T 6A7	Address		Project #	ENW VENW03150
Phone	(250) 756-2256 x	Phone		Project Name	SDBS water sampling
Fax	(250) 756-2686 x	Fax		Site #	
Email	bbarton@eba.ca; EBA.Labdata@tetrattech.com	Email		Sampled By	Doreen Palmer



B807281_COC

Regulatory Criteria:		Special Instructions		ANALYSIS REQUESTED (PLEASE BE SPECIFIC)										Turnaround Time (TAT) Required:	
☐ CSR ☐ CCME ☐ BC Water Quality ☒ Other Health Canada DRUG														Please provide advance notice for rush projects	
														Regular (Standard) TAT: (will be applied if Rush TAT is not specified): Standard TAT = 5-7 Working days for most tests. Please note: Standard TAT for certain tests such as BOD and Dioxins/Furans are > 5 days - contact your Project Manager for details.	
														Job Specific Rush TAT (if applies to entire submission) 1 DAY ☐ 2 Day ☐ 3 Day ☐ Date Required: ☐	
														Rush Confirmation Number: ☐ (call lab for #)	
SAMPLES MUST BE KEPT COOL (< 10°C) FROM TIME OF SAMPLING UNTIL DELIVERY TO MAXXAM															
Sample Barcode Label	Sample (Location) Identification	Date Sampled	Time Sampled	Matrix	Metals Field Filtered? (Y/N)	Lead - Drinking Water								# of Bottles	Comments
1	GADP - O ₅	18/01/28	12:00pm	Water	N	X								1	
2	PA01 - O ₅		3:00pm		N	X								1	
3	PA02 - O ₅				N	X								1	
4	PA03 - O ₅				N	X								1	
5	PA04 - O ₅				N	X								1	
6	PA05 - O ₅				N	X								1	
7	PA06 - O ₅				N	X								1	
8	PA07 - O ₅				N	X								1	
9	PA08 - O ₅				N	X								1	
10	PA09 - O ₅				N	X								1	
* RELINQUISHED BY: (Signature/Print)		Date: (YY/MM/DD)	Time	RECEIVED BY: (Signature/Print)		Date: (YY/MM/DD)	Time	# jars used and not submitted		Lab Use Only					
Doreen Palmer		18/01/28	9:00	Doreen Palmer		20/01/30	08:40			Time Sensitive	Temperature (°C) on Receipt	Custody Seal Intact on Cooler?			
										☐	4.5.4	☐ Yes ☒ No			
* UNLESS OTHERWISE AGREED TO IN WRITING, WORK SUBMITTED ON THIS CHAIN OF CUSTODY IS SUBJECT TO MAXXAM'S STANDARD TERMS AND CONDITIONS. SIGNING OF THIS CHAIN OF CUSTODY DOCUMENT IS ACKNOWLEDGMENT AND ACCEPTANCE OF OUR TERMS WHICH ARE AVAILABLE FOR VIEWING AT WWW.MAXXAM.CA/TERMS.															
* IT IS THE RESPONSIBILITY OF THE RELINQUISHING PARTY TO ENSURE THE ACCURACY OF THE CHAIN OF CUSTODY RECORD. AN INCOMPLETE CHAIN OF CUSTODY MAY RESULT IN ANALYTICAL TAT DELAYS.															

100-400

Maxxam Analytics International Corporation o/a Maxxam Analytics

INVOICE TO:		Report Information		Project Information				
Company Name: #1433 TETRA TECH CANADA INC.		Company Name: <i>Serve as check to</i>		Quotation #: B60578				
Contact Name: Ben Barton		Contact Name:		P.O. #:				
Address: #1 - 4376 BOBAN DRIVE NANAIMO BC V9T 6A7		Address:		Project #: ENW.VENW03150				
Phone: (250) 756-2256 x Fax: (250) 756-2686 x		Phone:		Project Name: <i>SDS DW Sampling</i>				
Email: bbarton@eba.ca; EBA.Labdata@tetratech.com		Email:		Site #: <i>Darren Radtke</i>				
Regulatory Criteria:		Special Instructions:		ANALYSIS REQUESTED (PLEASE BE SPECIFIC)				
☐ CSR ☐ CCME ☐ BC Water Quality ☒ Other: <i>Health Canada DWGCL</i>								
SAMPLES MUST BE KEPT COOL (< 10°C) FROM TIME OF SAMPLING UNTIL DELIVERY TO MAXXAM		Metals Field Filtered? (Y/N) <i>N</i> Lead - Drinking Water <i>X</i>						
Sample Barcode Label	Sample (Location) Identification	Date Sampled	Time Sampled	Matrix	# of Bottles	Comments		
1	PA 10 - O ₃	18/01/28	03:50 am	water	1			
2	PA 11 - O ₃	↓	↓	n	1			
3	PA 12 - O ₃			n	1			
4	PA 13 - O ₃			n	1			
5	PA 14 - O ₃			n	1			
6	PA 15 - O ₃			n	1			
7	PA 16 - O ₃			n	1			
8	PA 17 - O ₃			n	1			
9	PA Dup - O ₃			n	1			
10	SBGL - O ₃			5:00 am	n	1		
* RELINQUISHED BY: (Signature/Print)				Date: YY/MM/DD	Time	RECEIVED BY: (Signature/Print)		Date: YY/MM/DD
<i>[Signature]</i>		18/01/28	9:40	<i>KOMMA GATA</i>		2018/01/30	08:41	
# Jars used and not submitted		Lab Use Only		Custody Seal intact on Cooler?				
☐		Temperature (°C) on Receipt: <i>4.5.4</i>		☐ Yes ☐ No				

* UNLESS OTHERWISE AGREED TO IN WRITING, WORK SUBMITTED ON THIS CHAIN OF CUSTODY IS SUBJECT TO MAXXAM'S STANDARD TERMS AND CONDITIONS. SIGNING OF THIS CHAIN OF CUSTODY DOCUMENT IS ACKNOWLEDGMENT AND ACCEPTANCE OF OUR TERMS WHICH ARE AVAILABLE FOR VIEWING AT WWW.MAXXAM.CA/TERMS.

* IT IS THE RESPONSIBILITY OF THE RELINQUISHER TO ENSURE THE ACCURACY OF THE CHAIN OF CUSTODY RECORD. AN INCOMPLETE CHAIN OF CUSTODY MAY RESULT IN ANALYTICAL TAT DELAYS.



Maxxam Analytics International Corporation o/a Maxxam Analytics
4606 Canada Way, Burnaby, British Columbia Canada V5G 1K5 Tel (604) 734 7276 Toll-free: 800-563-6266 Fax (604) 731 2386 www.maxxam.ca

Chain Of Custody Record

Page 5 of 5

INVOICE TO:		Report Information		Project Information	
Company Name	1433 TETRA TECH CANADA INC.	Company Name	See as above to	Quotation #	B60578
Contact Name	Ben Barton	Contact Name		P.O. #	
Address	#1 - 4376 BOBAN DRIVE NANAIMO BC V9T 6A7	Address		Project #	ENW VENW03150
Phone	(250) 756-2256 x	Phone		Project Name	SDGS Du Sampling
Email	bbarton@eba.ca; EBA.Labdata@tetratech.com	Email		Site #	
				Sampled By	Darren Roulet



B807281_COC

der #:
33
anager
ontaine

Regulatory Criteria:		Special Instructions		ANALYSIS REQUESTED (PLEASE BE SPECIFIC)												Turnaround Time (TAT) Required:		
☐ CSR ☐ CCME ☐ BC Water Quality ☒ Other Health Canada DWGL																Please provide advance notice for rush projects		
SAMPLES MUST BE KEPT COOL (< 10°C) FROM TIME OF SAMPLING UNTIL DELIVERY TO MAXXAM																		
Sample Barcode Label	Sample (Location) Identification	Date Sampled	Time Sampled	Matrix	Metals Field Filtered ? (Y/N)	Lead - Drinking Water											# of Bottles	Comments
1	SB02 - 0s	18/01/28	9:00	Water	N	X											1	
2	SB03 - 0s				N	X											1	
3	SB04 - 0s				N	X											1	
4	SB05 - 0s				N	X											1	
5	SB06 - 0s				N	X											1	
6	SB06 - 0s				N	X											1	
7	SB06 - 0s				N	X											1	
8	SB06 - 0s				N	X											1	
9																		
10																		
RELINQUISHED BY: (Signature/Print)		Date: (YY/MM/DD)	Time	RECEIVED BY: (Signature/Print)		Date: (YY/MM/DD)	Time	# jars used and not submitted	Lab Use Only									
Darren Roulet		18/01/28	9:00	POUMER GUY		2018/01/30	08:46		Time Sensitive	Temperature (°C) on Receipt	Custody Seal Intact on Cooler?							
									☐	45.4	☐ Yes ☐ No							
* UNLESS OTHERWISE AGREED TO IN WRITING, WORK SUBMITTED ON THIS CHAIN OF CUSTODY IS SUBJECT TO MAXXAM'S STANDARD TERMS AND CONDITIONS. SIGNING OF THIS CHAIN OF CUSTODY DOCUMENT IS ACKNOWLEDGMENT AND ACCEPTANCE OF OUR TERMS WHICH ARE AVAILABLE FOR VIEWING AT WWW.MAXXAM.CA/TERMS.																		
* IT IS THE RESPONSIBILITY OF THE RELINQUISHER TO ENSURE THE ACCURACY OF THE CHAIN OF CUSTODY RECORD. AN INCOMPLETE CHAIN OF CUSTODY MAY RESULT IN ANALYTICAL TAT DELAYS.																		

Maxxam Analytics International Corporation o/a Maxxam Analytics