


TOWN OF LADYSMITH - ARBUTUS WATER TREATMENT PLANT

APRIL 2024 - MONTHLY REPORT

Date	Daily Flow			Chlorine Residual				CT*	External Lab Testing					
	Stocking Lake	Holland Creek	Combined Flow	Free Min	Free Max	Free Avg	Total		HPC	E.coli	Total Coliforms	Aluminum	THM	HAA
	m³	m³	m³	mg/l	mg/l	mg/l	mg/l		CFU	MPN	MPN	mg/l	mg/l	mg/l
01-Apr	3748	0	3748	0.92	0.96	0.95	1.02	199						
02-Apr	3683	0	3683	0.89	0.96	0.93	1.01	227						
03-Apr	4401	0	4401	0.88	1.00	1.00	0.99	311	< 1	< 1	< 1			
04-Apr	3794	0	3794	0.94	1.10	0.99	1.02	282						
05-Apr	4007	0	4007	0.91	0.99	0.98	1.03	296						
06-Apr	3490	0	3490	0.91	0.98	0.92	1.03	184						
07-Apr	4021	0	4021	0.87	0.99	0.99	0.98	159						
08-Apr	4074	0	7074	0.95	1.01	1.01	1.05	158						
09-Apr	3974	0	3974	0.93	1.01	0.98	1.03	164	< 1	< 1	< 1	0.0091	0.0174	0.0123
10-Apr	3800	0	3800	0.89	0.98	0.91	1.00	199						
11-Apr	3791	0	3791	0.84	0.91	0.91	0.94	186						
12-Apr	3738	0	3738	0.86	1.03	1.03	0.97	141						
13-Apr	3891	0	3891	1.03	1.13	1.12	1.20	253						
14-Apr	3900	0	3900	1.06	1.12	1.10	1.19	184						
15-Apr	3922	0	3922	1.06	1.11	1.06	1.31	119						
16-Apr	3928	0	3928	1.01	1.06	1.02	1.20	176	< 1	< 1	< 1			
17-Apr	4294	0	4294	0.99	1.02	1.01	1.04	157						
18-Apr	4305	0	4305	0.97	1.01	1.00	1.00	152						
19-Apr	4398	0	4398	0.97	1.00	0.99	1.11	124						
20-Apr	4128	0	4128	0.96	0.99	0.97	1.09	192						
21-Apr	3834	0	3834	0.95	1.09	0.97	1.08	180						
22-Apr	4141	0	4141	0.94	0.99	0.98	1.09	193						
23-Apr	4368	0	4368	0.96	1.01	1.01	1.12	184	< 1	< 1	< 1			
24-Apr	2049	1911	3960	0.98	1.01	1.00	1.09	191						
25-Apr	0	4368	4368	0.99	1.02	1.01	1.13	187						
26-Apr	0	3634	3634	0.95	1.01	0.99	1.04	113						
27-Apr	0	3608	3608	0.92	0.96	0.93	1.02	227						
28-Apr	0	3737	3737	0.91	0.93	0.93	1.09	223						
29-Apr	0	3816	3816	0.91	0.96	0.96	1.03	161						
30-Apr	0	4076	4076	0.95	0.97	0.97	1.07	189						

*CT - Recorded as the minimum value at the highest daily flow ** Manual Residual were not taken

Total	93679	25150	121829											
Average	3123	838	4061	0.94	1.01	0.99	1.07	190	< 1	< 1	< 1	0.0091	0.0174	0.01230



Town of Ladysmith Arbutus DWTP

Monthly LRV and Turbidity Report

03/31/2024 - 05/01/2024

LRV Monthly Average

Asset	Parameter	Health	Avg	Std. Dev	Points	LL	LCL	%In	% between L and LL	% below LL	Unit
UF 1	LRV		5.0	0.0	33	4.25	4.5	100 %	0 %	0 %	#
UF 2	LRV		5.0	0.0	32	4.25	4.5	100 %	0 %	0 %	#
UF 3	LRV		5.0	0.0	31	4.25	4.5	100 %	0 %	0 %	#

LRV Daily Values


Asset	Parameter	Mar 31	Apr 01	Apr 02	Apr 03	Apr 04	Apr 05	Apr 06	Apr 07	Apr 08	Apr 09
UF 1	LRV	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0
UF 2	LRV	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0
UF 3	LRV	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0

Asset	Apr 10	Apr 11	Apr 12	Apr 13	Apr 14	Apr 15	Apr 16	Apr 17	Apr 18	Apr 19	Apr 20	Apr 21	Apr 22
UF 1	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0
UF 2	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0
UF 3	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0

Asset	Apr 23	Apr 24	Apr 25	Apr 26	Apr 27	Apr 28	Apr 29	Apr 30	May 01
UF 1	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0
UF 2	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0
UF 3	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	--

LRV Raw Data

UF 1 - LRV (#)




Asset	Apr 10	Apr 11	Apr 12	Apr 13	Apr 14	Apr 15	Apr 16	Apr 17	Apr 18	Apr 19	Apr 20	Apr 21	Apr 22
UF 3	0.018	0.018	0.015	0.012	0.012	0.012	0.012	0.012	0.012	0.012	0.012	0.012	0.012


Asset	Apr 23	Apr 24	Apr 25	Apr 26	Apr 27	Apr 28	Apr 29	Apr 30	May 01
UF 1	0.013	0.013	0.013	0.013	0.013	0.012	0.013	0.012	0.013
UF 2	0.021	0.021	0.017	0.012	0.011	0.011	0.011	0.011	0.011
UF 3	0.011	0.012	0.012	0.012	0.012	0.012	0.012	0.012	0.012
UF 1	0.013	0.013	0.013	0.013	0.013	0.013	0.013	0.013	0.013
UF 2	0.021	0.021	0.016	0.012	0.011	0.011	0.011	0.011	0.011
UF 3	0.012	0.012	0.012	0.012	0.012	0.012	0.012	0.012	0.012

Turbidity Raw Data


UF 1 - PermeateTurbidityAfterBP (NTU)



UF 2 - PermeateTurbidityAfterBP (NTU)



UF 3 - PermeateTurbidityAfterBP (NTU)



CERTIFICATE OF ANALYSIS

Work Order	: VA24A7044	Page	: 1 of 3
Client	: Town of Ladysmith	Laboratory	: ALS Environmental - Vancouver
Contact	: Shawn Baker	Account Manager	: Thomas Chang
Address	: 410 Esplanade PO Box 220 Ladysmith BC Canada V9G 1A2	Address	: 8081 Lougheed Highway Burnaby BC Canada V5A 1W9
Telephone	: ----	Telephone	: +1 604 253 4188
Project	: Arbutus Water Treatment Plant - Weekly Sampling	Date Samples Received	: 04-Apr-2024 10:45
PO	: PO #10880	Date Analysis Commenced	: 04-Apr-2024
C-O-C number	: ----	Issue Date	: 09-Apr-2024 13:54
Sampler	: ----		
Site	: Town of Ladysmith		
Quote number	: VA22-GMSM100-001 Tender# 2022-IS-20		
No. of samples received	: 4		
No. of samples analysed	: 4		

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QC Interpretive report to assist with Quality Review and Sample Receipt Notification (SRN).

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

Signatories	Position	Laboratory Department
Caitlin Macey	Team Leader - Inorganics	Microbiology, Burnaby, British Columbia
Monica Ko	Lab Assistant	Inorganics, Burnaby, British Columbia



General Comments

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Refer to the ALS Quality Control Interpretive report (QCI) for applicable references and methodology summaries. Reference methods may incorporate modifications to improve performance.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

Please refer to Quality Control Interpretive report (QCI) for information regarding Holding Time compliance.

Key : CAS Number: Chemical Abstracts Services number is a unique identifier assigned to discrete substances
LOR: Limit of Reporting (detection limit).

Unit	Description
µS/cm	microsiemens per centimetre
CFU/mL	colony forming units per millilitre
CU	colour units (1 cu = 1 mg/l pt)
mg/L	milligrams per litre
MPN/100mL	most probable number per hundred millilitres
NTU	nephelometric turbidity units
pH units	pH units

<: less than.

>: greater than.

Surrogate: An analyte that is similar in behavior to target analyte(s), but that does not occur naturally in environmental samples. For applicable tests, surrogates are added to samples prior to analysis as a check on recovery.

Test results reported relate only to the samples as received by the laboratory.

UNLESS OTHERWISE STATED on SRN or QCI Report, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.

Workorder Comments

Sample(s) 004: Exceeded Recommended Holding Time prior to receipt at the lab for HPC analysis.



Analytical Results

Sub-Matrix: Water					Client sample ID	Raw Water	DAF Effluent	UF Effluent	Treated Water (post reservoir)	----
(Matrix: Water)										
					Client sampling date / time	03-Apr-2024 10:30	03-Apr-2024 10:30	03-Apr-2024 10:30	03-Apr-2024 10:30	----
Analyte	CAS Number	Method/Lab	LOR	Unit	VA24A7044-001	VA24A7044-002	VA24A7044-003	VA24A7044-004	-----	
					Result	Result	Result	Result	----	
Physical Tests										
Alkalinity, total (as CaCO3)	---	E290/VA	1.0	mg/L	----	----	----	16.2	----	
Colour, true	---	E329/VA	5.0	CU	----	----	----	<5.0	----	
Conductivity	---	E100/VA	2.0	µS/cm	----	----	----	63.7	----	
pH	---	E108/VA	0.10	pH units	----	----	----	7.54	----	
Turbidity	---	E121/VA	0.10	NTU	----	----	----	<0.10	----	
Organic / Inorganic Carbon										
Carbon, dissolved organic [DOC]	---	E358-L/VA	0.50	mg/L	2.76	1.30	1.18	----	----	
Carbon, total organic [TOC]	---	E355-L/VA	0.50	mg/L	2.62	1.32	1.10	----	----	
Microbiological Tests										
Heterotrophic plate count [HPC]	---	E020/VA	1	CFU/mL	----	----	----	<1	----	
Coliforms, Escherichia coli [E. coli]	---	E010/VA	1	MPN/100mL	----	----	----	<1	----	
Coliforms, total	---	E010/VA	1	MPN/100mL	----	----	----	<1	----	

Please refer to the General Comments section for an explanation of any result qualifiers detected.

Please refer to the Accreditation section for an explanation of analyte accreditations.

QUALITY CONTROL INTERPRETIVE REPORT

Work Order	: VA24A7044	Page	: 1 of 7
Client	: Town of Ladysmith	Laboratory	: ALS Environmental - Vancouver
Contact	: Shawn Baker	Account Manager	: Thomas Chang
Address	: 410 Esplanade PO Box 220 Ladysmith BC Canada V9G 1A2	Address	: 8081 Lougheed Highway Burnaby, British Columbia Canada V5A 1W9
Telephone	: ----	Telephone	: +1 604 253 4188
Project	: Arbutus Water Treatment Plant - Weekly Sampling	Date Samples Received	: 04-Apr-2024 10:45
PO	: PO #10880	Issue Date	: 09-Apr-2024 13:55
C-O-C number	: ----		
Sampler	: ----		
Site	: Town of Ladysmith		
Quote number	: VA22-GMSM100-001 Tender# 2022-IS-20		
No. of samples received	: 4		
No. of samples analysed	: 4		

This report is automatically generated by the ALS LIMS (Laboratory Information Management System) through evaluation of Quality Control (QC) results and other QA parameters associated with this submission, and is intended to facilitate rapid data validation by auditors or reviewers. The report highlights any exceptions and outliers to ALS Data Quality Objectives, provides holding time details and exceptions, summarizes QC sample frequencies, and lists applicable methodology references and summaries.

Key

Anonymous: Refers to samples which are not part of this work order, but which formed part of the QC process lot.

CAS Number: Chemical Abstracts Service number is a unique identifier assigned to discrete substances.

DQO: Data Quality Objective.

LOR: Limit of Reporting (detection limit).

RPD: Relative Percent Difference.

Workorder Comments

Holding times are displayed as "----" if no guidance exists from CCME, Canadian provinces, or broadly recognized international references.

Summary of Outliers

Outliers : Quality Control Samples

- No Method Blank value outliers occur.
- No Duplicate outliers occur.
- No Laboratory Control Sample (LCS) outliers occur
- No Matrix Spike outliers occur.
- No Test sample Surrogate recovery outliers exist.

Outliers: Reference Material (RM) Samples

- No Reference Material (RM) Sample outliers occur.

Outliers : Analysis Holding Time Compliance (Breaches)

- Analysis Holding Time Outliers exist - please see following pages for full details.

Outliers : Frequency of Quality Control Samples

- No Quality Control Sample Frequency Outliers occur.

CERTIFICATE OF ANALYSIS

Work Order	: VA24A7541	Page	: 1 of 3
Client	: Town of Ladysmith	Laboratory	: ALS Environmental - Vancouver
Contact	: Shawn Baker	Account Manager	: Thomas Chang
Address	: 410 Esplanade PO Box 220 Ladysmith BC Canada V9G 1A2	Address	: 8081 Lougheed Highway Burnaby BC Canada V5A 1W9
Telephone	: ----	Telephone	: +1 604 253 4188
Project	: Arbutus Water Treatment - Monthly Sampling	Date Samples Received	: 10-Apr-2024 12:35
PO	: 10880	Date Analysis Commenced	: 11-Apr-2024
C-O-C number	: ----	Issue Date	: 16-Apr-2024 10:58
Sampler	: ----		
Site	: Town of Ladysmith		
Quote number	: VA22-GMSM100-001 Tender# 2022-IS-20		
No. of samples received	: 1		
No. of samples analysed	: 1		

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results
- Surrogate Control Limits

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QC Interpretive report to assist with Quality Review and Sample Receipt Notification (SRN).

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

Signatories	Position	Laboratory Department
Rebecca Sit	Supervisor - Organics Extractions	Organics, Burnaby, British Columbia
Robin Weeks	Team Leader - Metals	Metals, Burnaby, British Columbia
Stephanie Pinheiro	Team Leader - LCMS	LCMS, Waterloo, Ontario



General Comments

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Refer to the ALS Quality Control Interpretive report (QCI) for applicable references and methodology summaries. Reference methods may incorporate modifications to improve performance.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

Please refer to Quality Control Interpretive report (QCI) for information regarding Holding Time compliance.

Key : CAS Number: Chemical Abstracts Services number is a unique identifier assigned to discrete substances
LOR: Limit of Reporting (detection limit).

Unit	Description
µg/L	micrograms per litre
mg/L	milligrams per litre

<: less than.

>: greater than.

Surrogate: An analyte that is similar in behavior to target analyte(s), but that does not occur naturally in environmental samples. For applicable tests, surrogates are added to samples prior to analysis as a check on recovery.

Test results reported relate only to the samples as received by the laboratory.

UNLESS OTHERWISE STATED on SRN or QCI Report, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.



Analytical Results

Sub-Matrix: Water (Matrix: Water)					Client sample ID	Treated Water (post reservoir)	----	----	----	----
Client sampling date / time					09-Apr-2024 10:30	----	----	----	----	----
Analyte	CAS Number	Method/Lab	LOR	Unit	VA24A7541-001	Result	-----	-----	-----	-----
Total Metals										
Aluminum, total	7429-90-5	E420/VA	0.0030	mg/L	0.0091	----	----	----	----	----
Volatile Organic Compounds [THMs]										
Bromodichloromethane	75-27-4	E611B/VA	1.0	µg/L	1.3	----	----	----	----	----
Bromoform	75-25-2	E611B/VA	1.0	µg/L	<1.0	----	----	----	----	----
Chloroform	67-66-3	E611B/VA	1.0	µg/L	16.1	----	----	----	----	----
Dibromochloromethane	124-48-1	E611B/VA	1.0	µg/L	<1.0	----	----	----	----	----
Trihalomethanes [THMs], total	----	E611B/VA	2.0	µg/L	17.4	----	----	----	----	----
Volatile Organic Compounds [THMs] Surrogates										
Bromofluorobenzene, 4-	460-00-4	E611B/VA	1.0	%	83.8	----	----	----	----	----
Difluorobenzene, 1,4-	540-36-3	E611B/VA	1.0	%	98.0	----	----	----	----	----
Haloacetic Acids										
Bromochloroacetic acid	5589-96-8	E750/WT	1.00	µg/L	<1.00	----	----	----	----	----
Dibromoacetic acid	631-64-1	E750/WT	1.00	µg/L	<1.00	----	----	----	----	----
Dichloroacetic acid	79-43-6	E750/WT	1.00	µg/L	5.59	----	----	----	----	----
Monobromoacetic acid	79-08-3	E750/WT	1.00	µg/L	<1.00	----	----	----	----	----
Monochloroacetic acid	79-11-8	E750/WT	1.00	µg/L	<1.00	----	----	----	----	----
Trichloroacetic acid	76-03-9	E750/WT	1.00	µg/L	6.74	----	----	----	----	----
Haloacetic acids, total [HAA5]	n/a	E750/WT	5.00	µg/L	12.3	----	----	----	----	----

Please refer to the General Comments section for an explanation of any result qualifiers detected.

Please refer to the Accreditation section for an explanation of analyte accreditations.

QUALITY CONTROL INTERPRETIVE REPORT

Work Order	: VA24A7541	Page	: 1 of 5
Client	: Town of Ladysmith	Laboratory	: ALS Environmental - Vancouver
Contact	: Shawn Baker	Account Manager	: Thomas Chang
Address	: 410 Esplanade PO Box 220 Ladysmith BC Canada V9G 1A2	Address	: 8081 Lougheed Highway Burnaby, British Columbia Canada V5A 1W9
Telephone	: ----	Telephone	: +1 604 253 4188
Project	: Arbutus Water Treatment - Monthly Sampling	Date Samples Received	: 10-Apr-2024 12:35
PO	: 10880	Issue Date	: 16-Apr-2024 10:58
C-O-C number	: ----		
Sampler	: ----		
Site	: Town of Ladysmith		
Quote number	: VA22-GMSM100-001 Tender# 2022-IS-20		
No. of samples received	: 1		
No. of samples analysed	: 1		

This report is automatically generated by the ALS LIMS (Laboratory Information Management System) through evaluation of Quality Control (QC) results and other QA parameters associated with this submission, and is intended to facilitate rapid data validation by auditors or reviewers. The report highlights any exceptions and outliers to ALS Data Quality Objectives, provides holding time details and exceptions, summarizes QC sample frequencies, and lists applicable methodology references and summaries.

Key

Anonymous: Refers to samples which are not part of this work order, but which formed part of the QC process lot.

CAS Number: Chemical Abstracts Service number is a unique identifier assigned to discrete substances.

DQO: Data Quality Objective.

LOR: Limit of Reporting (detection limit).

RPD: Relative Percent Difference.

Workorder Comments

Holding times are displayed as "----" if no guidance exists from CCME, Canadian provinces, or broadly recognized international references.

Summary of Outliers

Outliers : Quality Control Samples

- No Method Blank value outliers occur.
- No Duplicate outliers occur.
- No Laboratory Control Sample (LCS) outliers occur
- No Matrix Spike outliers occur.
- No Matrix Spike Duplicate (MSD) outliers occur - please see following pages for full details.
- No Test sample Surrogate recovery outliers exist.

Outliers: Reference Material (RM) Samples

- No Reference Material (RM) Sample outliers occur.

Outliers : Analysis Holding Time Compliance (Breaches)

- No Analysis Holding Time Outliers exist.

Outliers : Frequency of Quality Control Samples

- No Quality Control Sample Frequency Outliers occur.

CERTIFICATE OF ANALYSIS

Work Order	: VA24A7540	Page	: 1 of 3
Client	: Town of Ladysmith	Laboratory	: ALS Environmental - Vancouver
Contact	: Shawn Baker	Account Manager	: Thomas Chang
Address	: 410 Esplanade PO Box 220 Ladysmith BC Canada V9G 1A2	Address	: 8081 Lougheed Highway Burnaby BC Canada V5A 1W9
Telephone	: ----	Telephone	: +1 604 253 4188
Project	: Arbutus Water Treatment Plant - Weekly Sampling	Date Samples Received	: 10-Apr-2024 12:35
PO	: 10880	Date Analysis Commenced	: 10-Apr-2024
C-O-C number	: ----	Issue Date	: 16-Apr-2024 15:48
Sampler	: ----		
Site	: Town of Ladysmith		
Quote number	: VA22-GMSM100-001 Tender# 2022-IS-20		
No. of samples received	: 4		
No. of samples analysed	: 4		

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QC Interpretive report to assist with Quality Review and Sample Receipt Notification (SRN).

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

<i>Signatories</i>	<i>Position</i>	<i>Laboratory Department</i>
Kevin Duarte	Supervisor - Metals ICP Instrumentation	Inorganics, Burnaby, British Columbia
Miles Gropen	Department Manager - Inorganics	Microbiology, Burnaby, British Columbia
Monica Ko	Lab Assistant	Microbiology, Burnaby, British Columbia



General Comments

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Refer to the ALS Quality Control Interpretive report (QCI) for applicable references and methodology summaries. Reference methods may incorporate modifications to improve performance.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

Please refer to Quality Control Interpretive report (QCI) for information regarding Holding Time compliance.

Key : CAS Number: Chemical Abstracts Services number is a unique identifier assigned to discrete substances
LOR: Limit of Reporting (detection limit).

Unit	Description
µS/cm	microsiemens per centimetre
CFU/mL	colony forming units per millilitre
CU	colour units (1 cu = 1 mg/l pt)
mg/L	milligrams per litre
MPN/100mL	most probable number per hundred millilitres
NTU	nephelometric turbidity units
pH units	pH units

<: less than.

>: greater than.

Surrogate: An analyte that is similar in behavior to target analyte(s), but that does not occur naturally in environmental samples. For applicable tests, surrogates are added to samples prior to analysis as a check on recovery.

Test results reported relate only to the samples as received by the laboratory.

UNLESS OTHERWISE STATED on SRN or QCI Report, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.



Analytical Results

Sub-Matrix: Water					Client sample ID	Raw Water	DAF Effluent	UF Effluent	Treated Water (post reservoir)	----
(Matrix: Water)										
					Client sampling date / time	09-Apr-2024 10:30	09-Apr-2024 10:30	09-Apr-2024 10:30	09-Apr-2024 10:30	----
Analyte	CAS Number	Method/Lab	LOR	Unit	VA24A7540-001	VA24A7540-002	VA24A7540-003	VA24A7540-004	-----	
					Result	Result	Result	Result	----	
Physical Tests										
Alkalinity, total (as CaCO3)	----	E290/VA	1.0	mg/L	----	----	----	15.2	----	----
Colour, true	----	E329/VA	5.0	CU	----	----	----	<5.0	----	----
Conductivity	----	E100/VA	2.0	µS/cm	----	----	----	62.9	----	----
pH	----	E108/VA	0.10	pH units	----	----	----	7.38	----	----
Turbidity	----	E121/VA	0.10	NTU	----	----	----	<0.10	----	----
Organic / Inorganic Carbon										
Carbon, dissolved organic [DOC]	----	E358-L/VA	0.50	mg/L	2.54	1.18	1.23	----	----	----
Carbon, total organic [TOC]	----	E355-L/VA	0.50	mg/L	2.85	1.19	1.40	----	----	----
Microbiological Tests										
Heterotrophic plate count [HPC]	----	E020/VA	1	CFU/mL	----	----	----	<1	----	----
Coliforms, Escherichia coli [E. coli]	----	E010/VA	1	MPN/100mL	----	----	----	<1	----	----
Coliforms, total	----	E010/VA	1	MPN/100mL	----	----	----	<1	----	----

Please refer to the General Comments section for an explanation of any result qualifiers detected.

Please refer to the Accreditation section for an explanation of analyte accreditations.

QUALITY CONTROL INTERPRETIVE REPORT

Work Order	: VA24A7540	Page	: 1 of 7
Client	: Town of Ladysmith	Laboratory	: ALS Environmental - Vancouver
Contact	: Shawn Baker	Account Manager	: Thomas Chang
Address	: 410 Esplanade PO Box 220 Ladysmith BC Canada V9G 1A2	Address	: 8081 Lougheed Highway Burnaby, British Columbia Canada V5A 1W9
Telephone	: ----	Telephone	: +1 604 253 4188
Project	: Arbutus Water Treatment Plant - Weekly Sampling	Date Samples Received	: 10-Apr-2024 12:35
PO	: 10880	Issue Date	: 16-Apr-2024 15:49
C-O-C number	: ----		
Sampler	: ----		
Site	: Town of Ladysmith		
Quote number	: VA22-GMSM100-001 Tender# 2022-IS-20		
No. of samples received	: 4		
No. of samples analysed	: 4		

This report is automatically generated by the ALS LIMS (Laboratory Information Management System) through evaluation of Quality Control (QC) results and other QA parameters associated with this submission, and is intended to facilitate rapid data validation by auditors or reviewers. The report highlights any exceptions and outliers to ALS Data Quality Objectives, provides holding time details and exceptions, summarizes QC sample frequencies, and lists applicable methodology references and summaries.

Key

Anonymous: Refers to samples which are not part of this work order, but which formed part of the QC process lot.

CAS Number: Chemical Abstracts Service number is a unique identifier assigned to discrete substances.

DQO: Data Quality Objective.

LOR: Limit of Reporting (detection limit).

RPD: Relative Percent Difference.

Workorder Comments

Holding times are displayed as "----" if no guidance exists from CCME, Canadian provinces, or broadly recognized international references.

Summary of Outliers

Outliers : Quality Control Samples

- No Method Blank value outliers occur.
- No Duplicate outliers occur.
- No Laboratory Control Sample (LCS) outliers occur
- No Matrix Spike outliers occur.
- No Test sample Surrogate recovery outliers exist.

Outliers: Reference Material (RM) Samples

- No Reference Material (RM) Sample outliers occur.

Outliers : Analysis Holding Time Compliance (Breaches)

- Analysis Holding Time Outliers exist - please see following pages for full details.

Outliers : Frequency of Quality Control Samples

- Quality Control Sample Frequency Outliers occur - please see following pages for full details.

CERTIFICATE OF ANALYSIS

Work Order : **VA24A8131**
Client : **Town of Ladysmith**
Contact : Shawn Baker
Address : 410 Esplanade PO Box 220
Ladysmith BC Canada V9G 1A2
Telephone : ----
Project : Arbutus Water Treatment Plant - Weekly Sampling
PO : PO #10880
C-O-C number : ----
Sampler : ----
Site : Town of Ladysmith
Quote number : VA22-GMSM100-001 Tender# 2022-IS-20
No. of samples received : 4
No. of samples analysed : 4

Page : 1 of 3
Laboratory : ALS Environmental - Vancouver
Account Manager : Thomas Chang
Address : 8081 Lougheed Highway
Burnaby BC Canada V5A 1W9
Telephone : +1 604 253 4188
Date Samples Received : 17-Apr-2024 11:45
Date Analysis Commenced : 17-Apr-2024
Issue Date : 23-Apr-2024 13:21

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QC Interpretive report to assist with Quality Review and Sample Receipt Notification (SRN).

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

<i>Signatories</i>	<i>Position</i>	<i>Laboratory Department</i>
Monica Ko	Lab Assistant	Inorganics, Burnaby, British Columbia
Monica Ko	Lab Assistant	Microbiology, Burnaby, British Columbia



General Comments

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Refer to the ALS Quality Control Interpretive report (QCI) for applicable references and methodology summaries. Reference methods may incorporate modifications to improve performance.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

Please refer to Quality Control Interpretive report (QCI) for information regarding Holding Time compliance.

Key : CAS Number: Chemical Abstracts Services number is a unique identifier assigned to discrete substances
LOR: Limit of Reporting (detection limit).

Unit	Description
µS/cm	microsiemens per centimetre
CFU/mL	colony forming units per millilitre
CU	colour units (1 cu = 1 mg/l pt)
mg/L	milligrams per litre
MPN/100mL	most probable number per hundred millilitres
NTU	nephelometric turbidity units
pH units	pH units

<: less than.

>: greater than.

Surrogate: An analyte that is similar in behavior to target analyte(s), but that does not occur naturally in environmental samples. For applicable tests, surrogates are added to samples prior to analysis as a check on recovery.

Test results reported relate only to the samples as received by the laboratory.

UNLESS OTHERWISE STATED on SRN or QCI Report, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.

Workorder Comments

Sample(s) 004: Exceeded Recommended Holding Time prior to receipt at the lab for HPC analysis.



Analytical Results

Sub-Matrix: Water (Matrix: Water)				Client sample ID	Raw Water	DAF Effluent	UF Effluent	Treated Water (post reservoir)	----
Client sampling date / time					16-Apr-2024 10:30	16-Apr-2024 10:30	16-Apr-2024 10:30	16-Apr-2024 10:30	----
Analyte	CAS Number	Method/Lab	LOR	Unit	VA24A8131-001	VA24A8131-002	VA24A8131-003	VA24A8131-004	-----
					Result	Result	Result	Result	----
Physical Tests									
Alkalinity, total (as CaCO3)	----	E290/VA	1.0	mg/L	----	----	----	15.2	----
Colour, true	----	E329/VA	5.0	CU	----	----	----	<5.0	----
Conductivity	----	E100/VA	2.0	µS/cm	----	----	----	66.1	----
pH	----	E108/VA	0.10	pH units	----	----	----	7.49	----
Turbidity	----	E121/VA	0.10	NTU	----	----	----	<0.10	----
Organic / Inorganic Carbon									
Carbon, dissolved organic [DOC]	----	E358-L/VA	0.50	mg/L	2.29	1.36	1.36	----	----
Carbon, total organic [TOC]	----	E355-L/VA	0.50	mg/L	2.66	1.59	1.20	----	----
Microbiological Tests									
Heterotrophic plate count [HPC]	----	E020/VA	1	CFU/mL	----	----	----	<1	----
Coliforms, Escherichia coli [E. coli]	----	E010/VA	1	MPN/100mL	----	----	----	<1	----
Coliforms, total	----	E010/VA	1	MPN/100mL	----	----	----	<1	----

Please refer to the General Comments section for an explanation of any result qualifiers detected.

Please refer to the Accreditation section for an explanation of analyte accreditations.

QUALITY CONTROL INTERPRETIVE REPORT

Work Order	: VA24A8131	Page	: 1 of 7
Client	: Town of Ladysmith	Laboratory	: ALS Environmental - Vancouver
Contact	: Shawn Baker	Account Manager	: Thomas Chang
Address	: 410 Esplanade PO Box 220 Ladysmith BC Canada V9G 1A2	Address	: 8081 Lougheed Highway Burnaby, British Columbia Canada V5A 1W9
Telephone	: ----	Telephone	: +1 604 253 4188
Project	: Arbutus Water Treatment Plant - Weekly Sampling	Date Samples Received	: 17-Apr-2024 11:45
PO	: PO #10880	Issue Date	: 23-Apr-2024 13:29
C-O-C number	: ----		
Sampler	: ----		
Site	: Town of Ladysmith		
Quote number	: VA22-GMSM100-001 Tender# 2022-IS-20		
No. of samples received	: 4		
No. of samples analysed	: 4		

This report is automatically generated by the ALS LIMS (Laboratory Information Management System) through evaluation of Quality Control (QC) results and other QA parameters associated with this submission, and is intended to facilitate rapid data validation by auditors or reviewers. The report highlights any exceptions and outliers to ALS Data Quality Objectives, provides holding time details and exceptions, summarizes QC sample frequencies, and lists applicable methodology references and summaries.

Key

Anonymous: Refers to samples which are not part of this work order, but which formed part of the QC process lot.

CAS Number: Chemical Abstracts Service number is a unique identifier assigned to discrete substances.

DQO: Data Quality Objective.

LOR: Limit of Reporting (detection limit).

RPD: Relative Percent Difference.

Workorder Comments

Holding times are displayed as "----" if no guidance exists from CCME, Canadian provinces, or broadly recognized international references.

Summary of Outliers

Outliers : Quality Control Samples

- No Method Blank value outliers occur.
- No Duplicate outliers occur.
- No Laboratory Control Sample (LCS) outliers occur
- No Matrix Spike outliers occur.
- No Test sample Surrogate recovery outliers exist.

Outliers: Reference Material (RM) Samples

- No Reference Material (RM) Sample outliers occur.

Outliers : Analysis Holding Time Compliance (Breaches)

- Analysis Holding Time Outliers exist - please see following pages for full details.

Outliers : Frequency of Quality Control Samples

- No Quality Control Sample Frequency Outliers occur.

CERTIFICATE OF ANALYSIS

Work Order	: VA24A8779	Page	: 1 of 3
Client	: Town of Ladysmith	Laboratory	: ALS Environmental - Vancouver
Contact	: Shawn Baker	Account Manager	: Thomas Chang
Address	: 410 Esplanade PO Box 220 Ladysmith BC Canada V9G 1A2	Address	: 8081 Lougheed Highway Burnaby BC Canada V5A 1W9
Telephone	: ----	Telephone	: +1 604 253 4188
Project	: ----	Date Samples Received	: 24-Apr-2024 09:55
PO	: PO #10880	Date Analysis Commenced	: 24-Apr-2024
C-O-C number	: ----	Issue Date	: 30-Apr-2024 09:20
Sampler	: ----		
Site	: Town of Ladysmith		
Quote number	: VA22-GMSM100-001 Tender# 2022-IS-20		
No. of samples received	: 4		
No. of samples analysed	: 4		

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QC Interpretive report to assist with Quality Review and Sample Receipt Notification (SRN).

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

Signatories	Position	Laboratory Department
Brieanna Allen	Production/Validation Manager	Inorganics, Burnaby, British Columbia
Brieanna Allen	Production/Validation Manager	Microbiology, Burnaby, British Columbia



General Comments

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Refer to the ALS Quality Control Interpretive report (QCI) for applicable references and methodology summaries. Reference methods may incorporate modifications to improve performance.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

Please refer to Quality Control Interpretive report (QCI) for information regarding Holding Time compliance.

Key : CAS Number: Chemical Abstracts Services number is a unique identifier assigned to discrete substances
LOR: Limit of Reporting (detection limit).

Unit	Description
µS/cm	microsiemens per centimetre
CFU/mL	colony forming units per millilitre
CU	colour units (1 cu = 1 mg/l pt)
mg/L	milligrams per litre
MPN/100mL	most probable number per hundred millilitres
NTU	nephelometric turbidity units
pH units	pH units

<: less than.

>: greater than.

Surrogate: An analyte that is similar in behavior to target analyte(s), but that does not occur naturally in environmental samples. For applicable tests, surrogates are added to samples prior to analysis as a check on recovery.

Test results reported relate only to the samples as received by the laboratory.

UNLESS OTHERWISE STATED on SRN or QCI Report, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.

Workorder Comments

Sample(s) 004: Exceeded Recommended Holding Time prior to receipt at the lab for HPC analysis.



Analytical Results

Sub-Matrix: Water					Client sample ID	Raw Water	DAF Effluent	UF Effluent	Treated Water (post reservoir)	----
(Matrix: Water)										
Client sampling date / time						23-Apr-2024 10:30	23-Apr-2024 10:30	23-Apr-2024 10:30	23-Apr-2024 10:30	----
Analyte	CAS Number	Method/Lab	LOR	Unit	VA24A8779-001	VA24A8779-002	VA24A8779-003	VA24A8779-004	-----	
					Result	Result	Result	Result	----	
Physical Tests										
Alkalinity, total (as CaCO3)	----	E290/VA	1.0	mg/L	----	----	----	15.2	----	----
Colour, true	----	E329/VA	5.0	CU	----	----	----	<5.0	----	----
Conductivity	----	E100/VA	2.0	µS/cm	----	----	----	65.3	----	----
pH	----	E108/VA	0.10	pH units	----	----	----	7.52	----	----
Turbidity	----	E121/VA	0.10	NTU	----	----	----	<0.10	----	----
Organic / Inorganic Carbon										
Carbon, dissolved organic [DOC]	----	E358-L/VA	0.50	mg/L	2.32	1.30	0.98	----	----	----
Carbon, total organic [TOC]	----	E355-L/VA	0.50	mg/L	2.41	1.32	1.06	----	----	----
Microbiological Tests										
Heterotrophic plate count [HPC]	----	E020/VA	1	CFU/mL	----	----	----	<1	----	----
Coliforms, Escherichia coli [E. coli]	----	E010/VA	1	MPN/100mL	----	----	----	<1	----	----
Coliforms, total	----	E010/VA	1	MPN/100mL	----	----	----	<1	----	----

Please refer to the General Comments section for an explanation of any result qualifiers detected.

Please refer to the Accreditation section for an explanation of analyte accreditations.

QUALITY CONTROL INTERPRETIVE REPORT

Work Order	: VA24A8779	Page	: 1 of 7
Client	: Town of Ladysmith	Laboratory	: ALS Environmental - Vancouver
Contact	: Shawn Baker	Account Manager	: Thomas Chang
Address	: 410 Esplanade PO Box 220 Ladysmith BC Canada V9G 1A2	Address	: 8081 Lougheed Highway Burnaby, British Columbia Canada V5A 1W9
Telephone	: ----	Telephone	: +1 604 253 4188
Project	: ----	Date Samples Received	: 24-Apr-2024 09:55
PO	: PO #10880	Issue Date	: 30-Apr-2024 09:20
C-O-C number	: ----		
Sampler	: ----		
Site	: Town of Ladysmith		
Quote number	: VA22-GMSM100-001 Tender# 2022-IS-20		
No. of samples received	: 4		
No. of samples analysed	: 4		

This report is automatically generated by the ALS LIMS (Laboratory Information Management System) through evaluation of Quality Control (QC) results and other QA parameters associated with this submission, and is intended to facilitate rapid data validation by auditors or reviewers. The report highlights any exceptions and outliers to ALS Data Quality Objectives, provides holding time details and exceptions, summarizes QC sample frequencies, and lists applicable methodology references and summaries.

Key

Anonymous: Refers to samples which are not part of this work order, but which formed part of the QC process lot.

CAS Number: Chemical Abstracts Service number is a unique identifier assigned to discrete substances.

DQO: Data Quality Objective.

LOR: Limit of Reporting (detection limit).

RPD: Relative Percent Difference.

Workorder Comments

Holding times are displayed as "----" if no guidance exists from CCME, Canadian provinces, or broadly recognized international references.

Summary of Outliers

Outliers : Quality Control Samples

- No Method Blank value outliers occur.
- No Duplicate outliers occur.
- No Laboratory Control Sample (LCS) outliers occur
- No Matrix Spike outliers occur.
- No Test sample Surrogate recovery outliers exist.

Outliers: Reference Material (RM) Samples

- No Reference Material (RM) Sample outliers occur.

Outliers : Analysis Holding Time Compliance (Breaches)

- Analysis Holding Time Outliers exist - please see following pages for full details.

Outliers : Frequency of Quality Control Samples

- Quality Control Sample Frequency Outliers occur - please see following pages for full details.