

Project Name:	Date :
Location of Scaffolding:	Doc No:
Frequency: To be filled up on a weekly basis	

S. No.	Points to be checked	Yes / No	N/A	Remarks
1	Is the work area secured against unauthorized entry?			
2	Is toe board provided and in good condition?			
3	Proper access and egress provided ?			
4	All the materials Stand, brace, base plate, sole boards, platform plank/MS challis, toe board are in good condition?			
5	Check for type of surface uneven surface / filled area and any chances for settlement			
6	Any defects observed in scaffolding?(write in remarks)			
7	All the ties are checked and are in good condition?			
8	Are all connections of scaffolding bracings in good condition?			
9	Are diagonal bracings provided and it is in good condition?			
10	Are transverse diagonal bracing provided and it is in good condition?			
11	Clearance maintained between scaffolds and power lines ?			
12	Are scaffolding inner and outer legs (stand) are connected to the tie to support?			
13	Are scaffolding ties provided as per standard?			
14	Found any damaged component in the scaffolding?			
15	Is the scaffolding maintained in plumb vertical? (no swing and no sway)			
16	Are scaffolding (Excluding work platforms) earthed if erected on concreted slab properly?			
17	If mobile scaffolding, does it have locking arrangements against movement?			
18	Are hand rail, mid rail, toe board provided in case of mobile scaffold?			
19	Is cantilever provided scaffolding erected below 4 mtr height 3 mtr width?			
20	Are scaffolding ties provided erected above 4mtr height and below 3mtr width?			

Action				
1	Scaffolding "Red" tagged as damaged and removed from use.			
2	Scaffolding is in good condition "green" tagged.			

Remarks:

Inspected by EHS Officer:	Approved by Area In-charge:
Name:	Name:
Signature:	Signature:
Date: pp	Date: