
VALVES



F.O. FAIL OPEN

F.C. FAIL CLOSE

F.L. FAIL LAST (LOCK)

SOLID = NORMALLY CLOSED

HOLLOW = NORMALLY OPEN

INSTRUMENTS



ISA letters on top, KKS tag below.

First letter: F flow, L level, P pressure,

T temperature, Trans. T transmitter,

I indicator, C controller, S switch,

AL alarm low, AH alarm high, LL low-low.

KKS TAG: UU SSS NN AA NNN

UU unit, SSS system code, NN system no.

AA item code, NNN item no.

Example: 20LFC20AA102 (LCV)

ITEM CODES

AA valve

AC heat exchanger

AP pump

AT column / separator

BB vessel / drum

CF flow CL level CP pressure ET temperature

NUMBER RANGES (AA valves)

001-180 valves in main pipes

101-150 control valves

151-190 pressure reducers


191-199 safety valves

251-299 pneumatic shut off valves

instruments: 001-180 transmitter / controller

101-199 switch / alarm


EQUIPMENT







LINES



PIPE FLAG



SYSTEM CODES (UNIT 20)

LFB10 FEED SURGE AND FEED PUMPS

LFC20 FEED PREHEAT

LFC10 SPLITTER COLUMN AND PRESSURE CONTROL

LFC30 OVERHEAD CONDENSING AND REFLUX

LFC30 REBOILER AND TEMPERATURE CONTROL

LFD00 BOTTOMS TO STORAGE

SYNTHETIC DEMO DATA
NOT A REAL PLANT

MERIDIAN GAS PROCESSING - HARBOR TERMINAL
SYNTHETIC DEMO DATA - NOT A REAL PLANT
LEGEND FOR UNIT 200 P&IDs
DWG NO: PID-000
REV: C