

**GOVERNMENT OF ANDHRA PRADESH
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT**

From:
Sri N.Aswartha,BSc,Bed.,
Station Fire Officer,
Hindupur.

To:
The District Educational Officer,
Anantapuramu.

Rc.No.98/SFO/HDP/2015, Dated: 21-08-2015.

Sub: Andhra Pradesh Disaster Response & Fire Services Department – Southern Region – Anantapur District – Issue of 2nd Renewal No Objection Certificate for occupancy to the Existing Educational Building of LRG Vidyalayam, S.Y.No.210-1A And 210-1B, At Kirikera, Hindupur, Anantapuramu District-Regarding.

- Ref: 1. Letter from the Head Master of **LRG Vidyalayam, S.Y.No.210-1A And 210-1B,At Kirikera,Hindupur,Anantapuramu District.**
2. Renewal of NOC Rc.No.2634/ADFO/B2/2014, Dt, 20-08-2014 of the Assistant District Fire Officer, Anantapuramu.
3. Rc.No.2305/B2/2007, Dt, 02-09-2014 of the Director General of State Disaster Response and Fire Services Department.

--:--

In obedience to the recence 1st cited above , the Head Master of **LRG Vidyalayam, S.Y.No.210-1A And 210-1B,At Kirikera,Hindupur,Anantapuramu District.** has applied for 2nd Renewal Occupancy No Objection Certificate.

2. Vide reference 3rd cited, I have Inspected the above Educational Building on 21-08-2015 and renew the No Objection Certificate as the Educational Building is not changed or altered from the date of 1st Renewal No Objection Certificate issuing and provided required Fire Safety Measures as per furnished below.

3) i) Particulars of the Building:

a)	Address of the Building	LRG Vidyalayam, S.Y.No.210-1A And 210-1B,At Kirikera,Hindupur,Anantapuramu District.
b)	Area of plot / Height of the building	32000Sqmts, 10.50 Mts
c)	No. of blocks / floors	01 No's. / (Ground + 2nd Floor only.)

ii) Open Spaces:

Side	Open Space required as per NBC	Open space provided	Deficit / Remarks
North	06.00 Mtrs.,	44.00 Mtrs.,	Nil
East	06.00 Mtrs.,	06.00Mtrs.,	Nil
South	06.00 Mtrs.,	06.00 Mtrs.,	Nil
West	06.00 Mtrs.,	52.00 Mtrs.,	Nil

iii) Floor wise particular

Sl. No.	Floor	Area in Sq. Mts.	Occupancy	Occupant Load Declare By management
1.	Ground	2102.70	Educational	526
2.	First	1585.00	Educational	200
3.	Second	851.00	Educational	100
	Total:	4538.70	--	826

iv). Means of Escape (a):

Sl.No.	No. of Staircases	Width in Meters	Total Width
1.	Internal staircase - 03 Nos.	1.40+1.40+1.20 Mtrs	04.00Mtrs,
	Total: 3 No.s	04.00 Mtrs	