

This report sets out the independent adjuster's assessment of the claim below, including the inspection findings and the recommended settlement figure.

CLAIM DETAILS

Claim number	CLM-2026-01003
Policy number	HZN-HO-448210
Policyholder / payee	Rachel Morris, Red Maple Construction
Property	1845 Willow Creek Rd, Austin, TX 78701
Insurer	Horizon Inc.
Payment reference	BP-01003

INSPECTION

Date of loss	2 March 2026
Inspection date	9 March 2026
Adjuster	Daniel Ortiz, Licensed Adjuster #TX-2219841
Cause of loss	Wind-driven rain during a storm

FINDINGS

- Water staining to the ceiling drywall in the rear storage room (approx. 3.5 m²).
- One cracked asphalt shingle course above the rear eave allowing water ingress.
- No structural damage to framing; moisture readings normal at the time of inspection.
- Contents unaffected; no mould observed.

RECOMMENDATION

The adjuster recommends settlement of **\$487.00** covering repair of the shingles, drywall and paint, as itemised in the Repair Cost Estimate. The policy deductible has already been applied.

Daniel Ortiz, Independent Adjuster

Date: 18 March 2026