Log Sheet

Control Sheet Number	:
Test Date	:
Inspector	:

EQUIPMENT UNIQUE NUMBER	EQUIPMENT DESCRIPTION *SERIAL NUMBER*	EQUIPMENT CLASS I	II	ELV	DOMESTIC USE ONLY*	FUSE SIZE A	REMEDIAL WORK NEW FUSE	NEW PLUG	REPAIR	VISUAL RESULT	1 EARTH CONTINUITY Ω	2 INSULATION RESISTANCE MΩ	3 POLARITY Extension & IEC Leads **ONLY**	4 *OPTIONAL* CURRENT LEAKAGE mA	6 FUNCTION	OVERALL RESULT	RETEST MONTHS Based upon **RISK**
1										PASS FAIL			PASS FAIL		PASS FAIL	PASS FAIL	
2										PASS FAIL			PASS FAIL		PASS FAIL	PASS FAIL	
3										PASS FAIL			PASS FAIL		PASS FAIL	PASS FAIL	
4										PASS FAIL			PASS FAIL		PASS FAIL	PASS FAIL	
5										PASS FAIL			PASS FAIL		PASS FAIL	PASS FAIL	
6										PASS FAIL			PASS FAIL		PASS FAIL	PASS FAIL	
7										PASS FAIL			PASS FAIL		PASS FAIL	PASS FAIL	
8										PASS FAIL			PASS FAIL		PASS FAIL	PASS FAIL	
9										PASS FAIL			PASS FAIL		PASS FAIL	PASS FAIL	
10										PASS FAIL			PASS FAIL		PASS FAIL	PASS FAIL	
11										PASS FAIL			PASS FAIL		PASS FAIL	PASS FAIL	
12										PASS FAIL			PASS FAIL		PASS FAIL	PASS FAIL	
13										PASS FAIL			PASS FAIL		PASS FAIL	PASS FAIL	
14										PASS FAIL			PASS FAIL		PASS FAIL	PASS FAIL	
15										PASS FAIL			PASS FAIL		PASS FAIL	PASS FAIL	
16										PASS FAIL			PASS FAIL		PASS FAIL	PASS FAIL	
17										PASS FAIL			PASS FAIL		PASS FAIL	PASS FAIL	
18										PASS FAIL			PASS FAIL		PASS FAIL	PASS FAIL	
19										PASS FAIL			PASS FAIL		PASS FAIL	PASS FAIL	
20										PASS FAIL			PASS FAIL		PASS FAIL	PASS FAIL	

* Carry out a Risk Assessment to decide appliance suitability (Environment Check)

Key Information

- Failed items are to be disabled, labelled, recorded and removed to a quarantine area
- Remove old 'PAT Test' labels before applying the new label
- Never put 'PAT Test' labels on plugtops - put them on the equipment or fixed cord
- Repairs should only be carried out by competent personnel

Earth Continuity	0.00Ω to 0.10Ω	Instant Pass
	Greater than 0.10Ω	Apply Lead Compensation
Insulation Resistance	≥ 1.0 MΩ	Instant Pass - Class I
	≥ 2.0 MΩ	Instant Pass - Class II
Current Leakage	≤ 5.0 mA	Instant Pass - Class I & Class II

Repairs

EQUIPMENT UNIQUE NUMBER	EQUIPMENT DESCRIPTION	AUTHORISED REPAIRS CARRIED OUT	WHO CARRIED OUT THE REPAIR?

Failed Equipment

EQUIPMENT UNIQUE NUMBER	EQUIPMENT DESCRIPTION	VISUAL INSPECTION RESULT	ELECTRICAL TEST RESULT	REASON FOR FAIL	ACTION TAKEN
		PASS FAIL	PASS FAIL		
		PASS FAIL	PASS FAIL		
		PASS FAIL	PASS FAIL		
		PASS FAIL	PASS FAIL		
		PASS FAIL	PASS FAIL		
		PASS FAIL	PASS FAIL		