

## FIRE PUMP & JOCKEY PUMP MAINTENANCE CHECKLIST

DATE: \_\_\_\_\_

| Item             | Description                                                              | YES | NO | NA | Remarks | Inspected By<br>(Initials) |
|------------------|--------------------------------------------------------------------------|-----|----|----|---------|----------------------------|
| <b>➤ Weekly</b>  |                                                                          |     |    |    |         |                            |
| 1                | Pump room clean, ventilated, and temperature w/in limits (4.4°C to 49°C) |     |    |    |         |                            |
| 2                | Inspect pump casing, seals, bearings for leaks/ wear                     |     |    |    |         |                            |
| 3                | Verify suction/ discharge pressure gauges                                |     |    |    |         |                            |
| 4                | Test automatic start (simulate pressure drop)                            |     |    |    |         |                            |
| 5                | Chek controller status lights and alarms                                 |     |    |    |         |                            |
| 6                | Jockey pump: inspect for leaks, vibration, unusual noise                 |     |    |    |         |                            |
| 7                | Jockey pump: verify automatic start/stop operation                       |     |    |    |         |                            |
| <b>➤ Monthly</b> |                                                                          |     |    |    |         |                            |
| 1                | Fire pump churn test (no-flow run)                                       |     |    |    |         |                            |

|                    |                                                                  |  |  |  |  |  |
|--------------------|------------------------------------------------------------------|--|--|--|--|--|
| 2                  | Inspect strainers, valves, and relief valves                     |  |  |  |  |  |
| 3                  | Lubricate bearings and couplings                                 |  |  |  |  |  |
| 4                  | Jockey pump: run manually to confirm smooth operation            |  |  |  |  |  |
| 5                  | Jockey pump: inspect electrical connections and motor insulation |  |  |  |  |  |
| 6                  | Jockey pump: check for overheating during operation              |  |  |  |  |  |
| <b>&gt; Annual</b> |                                                                  |  |  |  |  |  |
| 1                  | Fire pump full flow test (compare with design specs)             |  |  |  |  |  |
| 2                  | Inspect and clean strainers, suction screens, and piping         |  |  |  |  |  |
| 3                  | Jockey pump: overhaul bearings, seals, and motor alignment       |  |  |  |  |  |
| 4                  | Jockey pump: inspect impeller and casing for wear/ corrosion     |  |  |  |  |  |
| 5                  | Jockey pump: test pressure switch calibration                    |  |  |  |  |  |
| 6                  | Jockey pump: clean strainers and suction piping                  |  |  |  |  |  |

PREPARED BY:

**Engr. Roan Paul B. Gallegos/ Elmer Esteban**

Building Maintenance

FCLGC

INSPECTED BY:

**Martin Naimes/ Crispin De Gracia/ George Ybanez**

BM Technician

FCLGC