

SEWAGE TREATMENT PLANT (STP) MAINTENANCE CHECKLIST

DATE: _____

Item	Description	YES	NO	NA	Remarks	Inspected By (Initials)
➤ Daily						
1	Inspect clarifiers for sludge removal and flow balance					
2	Check aeration tank blower operation and dissolved oxygen levels					
3	Clean screens and filters to prevent clogging					
4	Verify chemical dosing (disinfectants/coagulants)					
5	Measure effluent pH, turbidity, and odor					
6	Remove debris from scum and grease traps					
➤ Weekly						
1	Inspect sludge pumps and lines for blockages					
2	Clean grease traps and scum collectors					
3	Inspect PPE and emergency safety equipment					

4	Inspect electrical panels and sensors					
➤Monthly						
1	Inspect tanks and pipelines for cracks, leaks, or corrosion					
2	Test alarms, and control panels					
3	Lubricate pumps and motors; check bearings					
4	Conduct lab analysis (BOD, COD, TSS)					
➤Annual						
1	Sludge removal and proper disposal					
2	Calibration of instruments (flow meter, sensor)					
3	Structural inspection of tanks and pipelines					
4	Prevetive servicing of motors and gearboxes					

PREPARED BY:

Engr. Roan Paul B. Gallegos/ Elmer Esteban

Building Maintenance

FCLGC

INSPECTED BY:

Martin Naimes/ Crispin De Gracia/ George Ybanez

BM Technician

FCLGC