

TITLE:

FIRE PUMP & JOCKEY PUMP PROCEDURE MANUAL

Revision No.	Brief Description of Change	Effectivity Date
0	Origination	

	Name	Signature
Originated/ Revised by:	Engr. Roan Paul B. Gallegos Building Maintenance Manager	SEE DCN
Reviwed By:	Engr. Virtron K. Bumal-o QA/QC Manager	SEE DCN
	Engr. Michael D. Corpuz Operations Manager	SEE DCN
	Ms. Richelle D. Eslava HR Manager/QMR	SEE DCN

Approved by:	Ms. Lorraine Ashley Laranang-Josue Finance Director	SEE DCN
Date Approved		

Distribution List

☒ President/CEO
☒ QMR/BOD's

☒ Property Management Office
☒ Building Maintenance Office

☒ Admin (HRD/Fin/ Fac.)
☒ Doc. Con

TITLE:

FIRE PUMP & JOCKEY PUMP PROCEDURE MANUAL**1.0 PURPOSE & SCOPE**

This manual defines the preventive maintenance program for Fire Pump and Jockey Pump systems to ensure continuous readiness, compliance with NFPA 20 (Standard for the Installation of stationary pumps for Fire Protection) and local fire safety regulations, and protection of life and property. It covers weekly, monthly, and annual inspection and servicing of pumps, controllers, piping, valves, and electrical connections, with clear responsibilities, documentation requirements, and safety protocols such as PPE use and Lock-Out/Tag-Out procedures.

2.0 REFERENCES:

- NFPA 20: Standards for the Installation of Stationary Pumps for Fire Protection.
- Local Fire Code Regulations.
- Manufacturer's Operation & Maintenance Manuals.

3.0 DEFINITIONS & ABBREVIATIONS:**3.1 DEFINITIONS**

Fire Pump - The primary pump that supplies water to the fire protection system during emergency conditions.

Jockey Pump - A small auxiliary pump designed to maintain system pressure and prevent unnecessary operation of the fire pump.

Controller - Electrical device that monitors pump status and initiates automatic start/stop functions.

LOTO (Lock-out/Tag-out) - A safety Procedure ensuring equipment is properly shut off and not restarted until maintenance is complete.

PPE (Personal Protective Equipment) - Safety gear such as gloves, helmets, goggles, and protective clothing required during maintenance activities.

NFPA 20 - Standard for the Installation of Stationary Pumps for Fire Protection, issued by the National Fire Protection Association.

PSI (Pounds per Square Inch) - Unit of measurement for system pressure.

RPM (Revolutions per Minute) - Unit of measurement for pump motor speed.

O&M Manual (Operation and Maintenance Manual) - Manufacturer's guide for proper use and servicing of equipment.

TITLE:

FIRE PUMP & JOCKEY PUMP PROCEDURE MANUAL**3.2 ABBREVIATIONS****FP** - Fire Pump**JP** - Jockey Pump**LOTO** - Lock-Out/Tag-Out**PPE** - Personal Protective Equipment**NFPA** - National Fire Protection Association**O&M** - Operation and Maintenance**PSI** - Pounds per Square Inch (pressure unit)**RPM** - Revolutions per Minute (motor speed)**kW** - Kilowatt (motor power rating)**4.0 GENERAL REQUIREMENTS:**

All preventive maintenance activities for Fire Pump and Jockey Pump systems shall comply with NFPA 20 and local fire code regulations, be performed using proper PPE and Lock-Out/Tag-Out procedures, documented in logbooks and reports, and immediately reported if abnormalities are observed to ensure continuous operational readiness and safety.

5.0 PROCEDURE INSTRUCTIONS**PROCEDURE OUTLINE****5.1 Weekly Maintenance****5.2 Monthly Maintenance****5.3 Annual Maintenance****5.4 Documentation****5.5 Safety Precautions**

TITLE:

FIRE PUMP & JOCKEY PUMP PROCEDURE MANUAL

6.0 PROCEDURE DETAILS

<i>Responsible Person</i>	<i>Activities</i>	<i>Interface Document/ Person</i>
	5.1 Weekly Maintenance	
BM Team	Perform weekly checks to ensure pumps are operational and free of defects. - Inspect pump room cleanliness, ventilation, and temperature (4.4°C-49°C) - Check casing, seals, and bearings for leaks/wear - Verify suction/discharge pressure gauges - Test automatic start by simulating pressure drop - Inspect jockey pump for leaks, vibration, and noise	BM Supervisor
	5.2 Monthly Maintenance	
BM Team	Conduct monthly functional tests and lubrication to maintain reliability. - Perform fire pump churn test (no-flow run) - Inspect strainers, valves, and relief valves - Lubricate bearings and couplings - Run jockey pump manually to confirm smooth operation - Inspect electrical connections and insulation - Check jockey pump for overheating	BM Supervisor
	5.3 Annual Maintenance	
BM Team	Carry out full system tests and component overhauls annually. - Conduct fire pump full flow test (compare with design specs) - Clean strainers, suction screens, and piping - Overhaul jockey pump bearings, seals and motor alignment - Inspect impeller and casing for wear/ corrosion - Test and calibrate pressure switch - Flush suction piping	BM Supervisor

TITLE:

FIRE PUMP & JOCKEY PUMP PROCEDURE MANUAL

5.4 Documentation

Maintain accurate records for audits and preventive maintenance tracking.

BM Team/ Supervisor

- Record findings in maintenance checklist
- Note corrective actions under remarks
- Initial each inspection entry
- Retain records for minimum of 12 months.

BM Supervisor

5.5 Safety Precautions

Ensure safety protocols are followed during all maintenance activities.

BM Team/ Supervisor

- Lock-out/ Tag-out electrical sources before servicing
 - Wear PPE (gloves, goggles, hearing protection)
- Report abnormal vibration, noise, or overheating immediately

BM Supervisor

6.0 APPENDICES

- Preventive Maintenance Checklist
- Incident Report Form
- Purchase Requisition Form