LIGHTING FIXTURE AND LAMP TABLE

ROOM NO.	ROOM NAME	FIXTURE TYPE	NUMBER OF FIXTURE	LAMP TYPE	NO. OF LAMPS	BALLAST TYPE
1A01	ADMIN RECEPTION	A2	2	F32T8/4100K	4	ELECTRONIC
1A02	RMO ANALYST	A2	3	F32T8/4100K	4	ELECTRONIC
1A03	TRI CARE OFFICE	B1	2	F32T8/4100K	2	ELECTRONIC
1A04	TRI CARE OFFICE	B1	2	F32T8/4100K	2	ELECTRONIC
1A05	TRI CARE OFFICE	B1	2	F32T8/4100K	2	ELECTRONIC
1A06	TRI CARE OFFICE	B1	2	F32T8/4100K	2	ELECTRONIC
1A07	TRI CARE OFFICE	B1	2	F32T8/4100K	2	ELECTRONIC
1A08	PHARM. OFFICE	B1	2	F32T8/4100K	2	ELECTRONIC
1A09	W. TOILET	B1	1	F32T8/4100K	2	ELECTRONIC
		E2	1	F17T8/4100K	2	ELECTRONIC
1A10	LOUNGE	B1	2	F32T8/4100K	2	ELECTRONIC
1A11	JAN.	Q1	1	F32T8/4100K	1	ELECTRONIC
1A12	M. TOILET	B1	1	F32T8/4100K	2	ELECTRONIC
		E2	1	F32T8/4100K	2	ELECTRONIC
1A13	STAFF TOILET	B3	1	F32T8/4100K	2	ELECTRONIC
		E2	1	F32T8/4100K	2	ELECTRONIC
1A14	SUPER/NCOIC	A2	1	F32T8/4100K	2	ELECTRONIC
1A15	COUNSELING	B1	2	F32T8/4100K	2	ELECTRONIC
1A16	PHARM. DISP.	A2	10	F32T8/4100K	2	ELECTRONIC
		A2B	3	F32T8/4100K	2	ELECTRONIC
1AC1	CORRIDOR	T1	6	F32T8/4100K	2	ELECTRONIC
		LV	12	M16/HALOGEN	1	NA
1AC2	CORRIDOR	SD	10	CF-QT26W4100K	2	ELECTRONIC
		SDB	6	CF-QT26W4100K	2	ELECTRONIC
		B3	1	F32T8/4100K	2	ELECTRONIC
		B3B	1	F32T8/4100K	2	ELECTRONIC
		X1	2	LED		NA
1AC3	CORRIDOR	B3	2	F32T8/4100K	2	ELECTRONIC
		B3B	1	F32T8/4100K	2	ELECTRONIC
		X1	1	LED		NA
1AC4	CORRIDOR	A2	1	F32T8/4100K	2	ELECTRONIC
		X1	1	LED		NA
1AC5	CORRIDOR	A2	2	F32T8/4100K	2	ELECTRONIC
		B3	1	F32T8/4100K	2	ELECTRONIC
		A2B	1	F32T8/4100K	2	ELECTRONIC
		B3B	1	F32T8/4100K	2	ELECTRONIC
		X1	1	LED		NA
1AS1	STAIRS	E1	1	F32T8/4100K	2	ELECTRONIC
1B01	RECEPT	B1	2	F32T8/4100K	2	ELECTRONIC
1B02	SPECIMEN TOILET	B3	1	F32T8/4100K	2	ELECTRONIC
		E2	1	F32T8/4100K	2	ELECTRONIC
1B03	BLOOD DRAW	C1	1	F32T8/4100K	3	ELECTRONIC
		C1B	1	F32T8/4100K	3	ELECTRONIC
1B04	LAB	B1	7	F32T8/4100K	2	ELECTRONIC
		B1B	2	F32T8/4100K	2	ELECTRONIC
1B05	STAFF TOILET	B3	1	F32T8/4100K	2	ELECTRONIC
		E2	1	F32T8/4100K	2	ELECTRONIC

LIGHTING FIXTURE AND LAMP TABLE

ROOM NO.	ROOM NAME	FIXTURE TYPE	NUMBER OF FIXTURE	LAMP TYPE	NO. OF LAMPS	BALLAST TYPE
1B06	LAB OFFICE	B1	2	F32T8/4100K	2	ELECTRONIC
1B07	DRESSING	R1	1	F32T8/4100K	2	ELECTRONIC
1B08	STORAGE	B1	2	F32T8/4100K	2	ELECTRONIC
1B09	DRESSING	R1	1	F32T8/4100K	2	ELECTRONIC
1B10	LOUNGE	B1	2	F32T8/4100K	2	ELECTRONIC
1B11	STAFF TOILET	B3	1	F32T8/4100K	2	ELECTRONIC
		E2	1	F32T8/4100K	2	ELECTRONIC
1B12	SUPPLY	R1	1	F32T8/4100K	2	ELECTRONIC
1B13	RECEPT	B1	3	F32T8/4100K	2	ELECTRONIC
1B14	UTILITY	R1	1	F32T8/4100K	2	ELECTRONIC
1B15	FILM VIEWING	C1D	1	F32T8/4100K	2	ELE/DIM
1B16	JAN.	Q1	1	F32T8/4100K	1	ELECTRONIC
1B17	TECH WK. RM	B1	4	F32T8/4100K	2	ELECTRONIC
		B1B	1	F32T8/4100K	2	ELECTRONIC
1B19	RADIOGRAPHIC RM	B3D	6	F32T8/4100K	2	ELE/DIM
		B3DB	2	F32T8/4100K	2	ELE/DIM
		SD	1	CF-QT26W4100K	2	ELECTRONIC
1B21	COMM. RM	Q4	1	F32T8/4100K	2	ELECTRONIC
		Q4B	1	F32T8/4100K	2	ELECTRONIC
1B23	ELEC. RM	Q4	1	F32T8/4100K	2	ELECTRONIC
		Q4B	1	F32T8/4100K	2	ELECTRONIC
1BC1	CORRIDOR	B3B	1	F32T8/4100K	2	ELECTRONIC
		X1	1	LED		NA
1BC2	CORRIDOR	B3	3	F32T8/4100K	2	ELECTRONIC
		B3B	2	F32T8/4100K	2	ELECTRONIC
		X1	1	LED		NA
1BC3	CORRIDOR	B3	2	F32T8/4100K	2	ELECTRONIC
		B3B	1	F32T8/4100K	2	ELECTRONIC
		X1	2	LED		NA
1BC4	CORRIDOR	B3	4	F32T8/4100K	2	ELECTRONIC
		B3B	2	F32T8/4100K	2	ELECTRONIC
		X1	1	LED		NA
1BS2	STAIRS	E1	2	F32T8/4100K	2	ELECTRONIC
		X1	1	LED		NA
	ELEVATOR	Z	1	100W/MED BASE	1	NA
1C01	WAITING	SD	4	CF-QT26W4100K	2	ELECTRONIC
1C02	RECEPT	SB	3	CF-QT18W/4100K	1	ELECTRONIC
		B1	1	F32T8/4100K	2	ELECTRONIC
1C03	JAN.	Q4	1	F32T8/4100K	2	ELECTRONIC
1C04	FITTING DISP.	C1	2	F32T8/4100K	2	ELECTRONIC
1C05	VISUAL FIELD	C1D	2	F32T8/4100K	2	ELE/DIM
1C06	TRASH	B1	1	F32T8/4100K	2	ELECTRONIC
1C07	OPT. EXAM/OFF	B18	2	F32T8/4100K	2	ELECTRONIC
		SB	5	CF-QT18W/4100K	1	ELECTRONIC
1C08	SCREEN EYE TEST	B1D	2	F32T8/4100K	2	ELE/DIM
1C09	FUNDUS CAMERA	B1D	2	F32T8/4100K	2	ELE/DIM
1C10	OPT. EXAM/OFF	B18	2	F32T8/4100K	2	ELECTRONIC

LIGHTING FIXTURE AND LAMP TABLE

ROOM NO.	ROOM NAME	FIXTURE TYPE	NUMBER OF FIXTURE	LAMP TYPE	NO. OF LAMPS	BALLAST TYPE
		SB	5	CF-QT18W/4100K	1	ELECTRONIC
1C11	ELECT. CL.	Q1	1	F32T8/4100K	1	ELECTRONIC
1C12	TOILET	B3	1	F32T8/4100K	2	ELECTRONIC
		E2	1	F32T8/4100K	2	ELECTRONIC
1C13	COMM. RM	Q4	2	F32T8/4100K	2	ELECTRONIC
1C14	HIST./INTV.	B1	2	F32T8/4100K	2	ELECTRONIC
1C15	PES. ADMIN.OFFICE	C1	3	F32T8/4100K	2	ELECTRONIC
1C16	ECG TEST	B18	2	F32T8/4100K	2	ELECTRONIC
1C17	CHIEF AERO MED.	B1	2	F32T8/4100K	2	ELECTRONIC
1C18	PHYSICAL EXAM	C18	8	F32T8/4100K	3	ELECTRONIC
		B18B	2	F32T8/4100K	3	ELECTRONIC
		X1	1	LED		NA
1C19	AUDIO	B18	2	F32T8/4100K	2	ELECTRONIC
1CC1	CORRIDOR	B3	4	F32T8/4100K	2	ELECTRONIC
		B3B	2	F32T8/4100K	2	ELECTRONIC
		X1	2	LED		NA
1CC2	CORRIDOR	B3	1	F32T8/4100K	2	ELECTRONIC
		X1	1	LED		NA
1CC3	CORRIDOR	B3	2	F32T8/4100K	2	ELECTRONIC
		B3B	2	F32T8/4100K	2	ELECTRONIC
		X1	1	LED		NA
1CS3	STAIRS	E1	2	F32T8/4100K	2	ELECTRONIC
1D01	SL. LIN/TRASH	B3	1	F32T8/4100K	2	ELECTRONIC
1D02	INTERACTION STATION	C18	2	F32T8/4100K	3	ELECTRONIC
1D03	CLEAN U.					
1D04	TOILET	B3	1	F32T8/4100K	2	ELECTRONIC
		E2	1	F32T8/4100K	2	ELECTRONIC
1D05	TRMT RM. DIRTY PROC.	C18	2	F32T8/4100K	3	ELECTROMAG
		C18B	1	F32T8/4100K	3	ELECTROMAG
1D06	SCOPE WASH/DECON	C1	2	F32T8/4100K	2	ELECTRONIC
1D07	INTERACTION STATION	C18	2	F32T8/4100K	3	ELECTRONIC
1D08	INTERACTION STATION	C18	2	F32T8/4100K	3	ELECTRONIC
1D09	INTERACTION STATION	C18	2	F32T8/4100K	3	ELECTRONIC
1D10	INTERACTION STATION	C18	2	F32T8/4100K	3	ELECTRONIC
1D11	INTERACTION STATION	C18	2	F32T8/4100K	3	ELECTRONIC
1D12	SPECIMEN COLL LAB	B18	2	F32T8/4100K	2	ELECTRONIC
1D13	INTERACTION STATION	C18	2	F32T8/4100K	3	ELECTRONIC
1D14	SPECIMEN TOILET	B3	1	F32T8/4100K	2	ELECTRONIC
		E2	1	F32T8/4100K	2	ELECTRONIC
1D15	WHT. & MEAS. RM	B1	1	F32T8/4100K	2	ELECTRONIC
1D16	PROVIDER CUBICLES	B1	9	F32T8/4100K	2	ELECTRONIC
		B1B	2	F32T8/4100K	2	ELECTRONIC
1D17	JAN.	Q1	1	F32T8/4100K	1	ELECTRONIC
1D18	TOILET	B1	1	F32T8/4100K	2	ELECTRONIC
		E2	1	F32T8/4100K	2	ELECTRONIC
1D19	MDIS VIEW	C1	1	F32T8/4100K	2	ELECTRONIC
1D20	APPMTS	B1	2	F32T8/4100K	2	ELECTRONIC

LIGHTING FIXTURE AND LAMP TABLE

ROOM NO.	ROOM NAME	FIXTURE TYPE	NUMBER OF FIXTURE	LAMP TYPE	NO. OF LAMPS	BALLAST TYPE
1D21	GROUP IS	B1	4	F32T8/4100K	2	ELECTRONIC
1D22	TEAM INTERACTION	B1	2	F32T8/4100K	2	ELECTRONIC
		B1B	1	F32T8/4100K	2	ELECTRONIC
		SB	2	CF-QT18W/4100K	1	ELECTRONIC
1D23	GROUP IS	B1	4	F32T8/4100K	2	ELECTRONIC
1D24	RECORDS	B1	2	F32T8/4100K	2	ELECTRONIC
1D25	PROVIDER CUBICLES	B1	9	F32T8/4100K	2	ELECTRONIC
		B1B	2	F32T8/4100K	2	ELECTRONIC
1D26	TOILET	B3	1	F32T8/4100K	2	ELECTRONIC
		E2	1	F32T8/4100K	2	ELECTRONIC
1D27	ADMIN. WK STATION	B1	2	F32T8/4100K	2	ELECTRONIC
1D28	INTERACTION STATION	C18	2	F32T8/4100K	3	ELECTRONIC
1D30	WTS. & MEAS. RM	B1	2	F32T8/4100K	2	ELECTRONIC
1D31	PEDS. WTS. MEAS. RM	B1	2	F32T8/4100K	2	ELECTRONIC
1D32	INTERACTION STATION	C18	2	F32T8/4100K	3	ELECTRONIC
1D33	PEDS WAITING	B1	2	F32T8/4100K	2	ELECTRONIC
1D34	INTERACTION STATION	C18	2	F32T8/4100K	3	ELECTRONIC
1D35	INTERACTION STATION	C18	2	F32T8/4100K	3	ELECTRONIC
1D36	INTERACTION STATION	C18	2	F32T8/4100K	3	ELECTRONIC
1D37	CLEAN U.					
1D38	TRMT RM.	C18	3	F32T8/4100K	3	ELECTROMAG
		C18B	1	F32T8/4100K	3	ELECTROMAG
1D39	SL. LIN/TRASH	B3	1	F32T8/4100K	2	ELECTRONIC
1D40	IMMUNIZATION RM	A28	3	F32T8/5000K	4	ELECTRONIC
1DC1	WAITING	LV	4	50W/HALOGEN	1	NA
	RECEPT	P1	4	F32T8/4100K	3	ELECTRONIC
		SB	5	PL-C18/4100	1	ELECTRONIC
		SBB	3	PL-C18/4100	1	ELECTRONIC
		X1	2	LED		NA
	ADMIN	P1	3	F32T8/4100K	3	ELECTRONIC
		SB	8	PL-C18/4100	1	ELECTRONIC
		SBB	2	PL-C18/4100	1	ELECTRONIC
1DC2	CORRIDOR	B3B	1	F32T8/4100K	2	ELECTRONIC
		X1	1	LED		NA
1DC3	CORRIDOR	B3	4	F32T8/4100K	2	ELECTRONIC
		B3B	2	F32T8/4100K	2	ELECTRONIC
		X1	2	LED		NA
1DC4	CORRIDOR	B3	1	F32T8/4100K	2	ELECTRONIC
		B3B	1	F32T8/4100K	2	ELECTRONIC
1DC5	CORRIDOR	B3	2	F32T8/4100K	2	ELECTRONIC
		B3B	2	F32T8/4100K	2	ELECTRONIC
		X1	2	LED		NA
		X2	2	LED		NA
		SB	2	PL-C18/4100	1	ELECTRONIC
1DC6	CORRIDOR	B3	1	F32T8/4100K	2	ELECTRONIC
		B3B	1	F32T8/4100K	2	ELECTRONIC
		X1	1	LED		NA

LIGHTING FIXTURE AND LAMP TABLE

ROOM NO.	ROOM NAME	FIXTURE TYPE	NUMBER OF FIXTURE	LAMP TYPE	NO. OF LAMPS	BALLAST TYPE
1DC7	CORRIDOR	B3	4	F32T8/4100K	2	ELECTRONIC
		B3B	2	F32T8/4100K	2	ELECTRONIC
		X1	1	LED		NA
		X2	1	LED		NA
1DC8	CORRIDOR	B3B	1	F32T8/4100K	2	ELECTRONIC
		X1	1	LED		NA
1E01	HK EQUIP. SUP. STOR	B1	1	F32T8/4100K	2	ELECTRONIC
1E02	ELEV. EQUIP	Q4	1	F32T8/4100K	2	ELECTRONIC
1E03	JAN.	Q4	1	F32T8/4100K	2	ELECTRONIC
1E04	HK BREAK RM	B1	1	F32T8/4100K	2	ELECTRONIC
1E05	CHIEF LOG OFFICE	B1	2	F32T8/4100K	2	ELECTRONIC
1E06	TECH WRK. STA.	B1	5	F32T8/4100K	2	ELECTRONIC
		B1B	1	F32T8/4100K	2	ELECTRONIC
1E07	CINF LIBRARY	B1	4	F32T8/4100K	2	ELECTRONIC
1E08	SUPER.	B1	2	F32T8/4100K	2	ELECTRONIC
1E09	W. TOILET	B3	1	F32T8/4100K	2	ELECTRONIC
		E2	1	F32T8/4100K	2	ELECTRONIC
1E10	M. TOILET	B3	1	F32T8/4100K	2	ELECTRONIC
		E2	1	F32T8/4100K	2	ELECTRONIC
1E11	STAFF LOUNGE	B1	2	F32T8/4100K	2	ELECTRONIC
1E12	ISOLATION TOILET	B3	1	F32T8/4100K	2	ELECTRONIC
		E2	1	F32T8/4100K	2	ELECTRONIC
1E14	MEDICAL READINESS	B1	3	F32T8/4100K	2	ELECTRONIC
1E15	CENTRAL MECH. RM	Q4	3	F32T8/4100K	2	ELECTRONIC
		Q4B	1	F32T8/4100K	2	ELECTRONIC
1E15A	GAS STORAGE	Q4	2	F32T8/4100K	2	ELECTRONIC
1E16	BMET WK STATION	B1	8	F32T8/4100K	2	ELECTRONIC
		B1B	2	F32T8/4100K	2	ELECTRONIC
1E17	HAZ. STOR.	Q4	1	F32T8/4100K	2	ELECTRONIC
1E18	BIOMED MAINT. ADMIN.	B1	3	F32T8/4100K	2	ELECTRONIC
1E19	ELEC. RM	Q4	1	F32T8/4100K	2	ELECTRONIC
		Q4B	1	F32T8/4100K	2	ELECTRONIC
1E20	TRASH	Q4	1	F32T8/4100K	2	ELECTRONIC
		Q4B	1	F32T8/4100K	2	ELECTRONIC
1E21	FLAM. STOR	SD	2	CF-QT26W4100K	2	ELECTRONIC
		SDB	1	CF-QT26W4100K	2	ELECTRONIC
1E22	SEC. STOR.	B1	1	F32T8/4100K	2	ELECTRONIC
1E23	BEE EQUIP. STOR.	B1	2	F32T8/4100K	2	ELECTRONIC
1E24	RECEIVE./PROCESS.	B1	14	F32T8/4100K	2	ELECTRONIC
		B1B	2	F32T8/4100K	2	ELECTRONIC
1E25	BENCHSTOCK STOR.	C1	2	F32T8/4100K	2	ELECTRONIC
1E26	ADP. EQUIP. SPACE	B1	3	F32T8/4100K	2	ELECTRONIC
		B1B	1	F32T8/4100K	2	ELECTRONIC
1E27	FAC MGR. OFFICE	B1	1	F32T8/4100K	2	ELECTRONIC
1E28	WK. RM.	B1	2	F32T8/4100K	2	ELECTRONIC
1E29	HK SUPV. OFFICE	B1	2	F32T8/4100K	2	ELECTRONIC
1E30	S. LIN.	B1	1	F32T8/4100K	2	ELECTRONIC

LIGHTING FIXTURE AND LAMP TABLE

ROOM NO.	ROOM NAME	FIXTURE TYPE	NUMBER OF FIXTURE	LAMP TYPE	NO. OF LAMPS	BALLAST TYPE
1E33	ISOL. INTERACT. STA.	B1	2	F32T8/4100K	2	ELECTRONIC
1EC1	CORRIDOR	B3	6	F32T8/4100K	2	ELECTRONIC
		B3B	4	F32T8/4100K	2	ELECTRONIC
		X1	3	LED		NA
1EC2	CORRIDOR	B3	1	F32T8/4100K	2	ELECTRONIC
		B3B	1	F32T8/4100K	2	ELECTRONIC
1EC3	CORRIDOR	B3	1	F32T8/4100K	2	ELECTRONIC
1EC4	CORRIDOR	B3	1	F32T8/4100K	2	ELECTRONIC
		B3B	1	F32T8/4100K	2	ELECTRONIC
2A01	LIBRARY/CINF RM.	B3	5	F32T8/4100K	2	ELECTRONIC
		B3B	1	F32T8/4100K	2	ELECTRONIC
		S	9	75W/MED BASE	1	NA
2A02	SUPER. OFF.	B1	2	F32T8/4100K	2	ELECTRONIC
2A03	SEC. OFF.	B1	2	F32T8/4100K	2	ELECTRONIC
		SC	3	CF-TT32W/4100K	2	ELECTRONIC
2A04	DENTAL SURGEON OFF.	B1	2	F32T8/4100K	2	ELECTRONIC
		SC	3	CF-TT32W/4100K	2	ELECTRONIC
2A05	OH DTR #1	A3	4	F32T8/5000K	6	ELECTRONIC
2A06	OH DTR #2	A3	4	F32T8/5000K	6	ELECTRONIC
2A07	OH DTR #3	A3	4	F32T8/5000K	6	ELECTRONIC
2A08	OH DTR #4	A3	4	F32T8/5000K	6	ELECTRONIC
2A09	OH DTR #5	A3	4	F32T8/5000K	6	ELECTRONIC
2A10	DENTAL WAITING	B1	2	F32T8/4100K	2	ELECTRONIC
2A11	DENTAL WAITING	B1	3	F32T8/4100K	2	ELECTRONIC
		B1B	2	F32T8/4100K	2	ELECTRONIC
2A12	X-RAY	A2	2	F32T8/4100K	2	ELECTRONIC
		A2B	1	F32T8/4100K	2	ELECTRONIC
		Y1	1	CF-DT7W	2	NA
2A12A	X-RAY ALCOVE	SC	1	CF-TT32W/4100K	2	ELECTRONIC
2A13	DEVELOPING	B1	1	F32T8/4100K	2	ELECTRONIC
		Y2	1	CF-DT7W	1	NA
2A14	ADMIN. WK STATION	B1	5	F32T8/4100K	2	ELECTRONIC
		B1B	1	F32T8/4100K	2	ELECTRONIC
2AC1	CORRIDOR	DM175	4	175W/HALIDE	1	HID CCB
		M175	4	175W/HALIDE	1	HID CCB
		M250	4	250W/HALIDE	1	HID CCB
		M400	6	400W/HALIDE	1	HID CCB
		SC	5	CF-TT32W/4100K	2	ELECTRONIC
		SCB	1	CF-TT32W/4100K	2	ELECTRONIC
2AC2	CORRIDOR	B3	1	F32T8/4100K	2	ELECTRONIC
		B3B	2	F32T8/4100K	2	ELECTRONIC
		X1	1	LED		NA
2AC3		B3	3	F32T8/4100K	2	ELECTRONIC
		B3B	2	F32T8/4100K	2	ELECTRONIC
		X1	1	LED		NA
		X2	1	LED		NA
2AC4	CORRIDOR	B3	1	F32T8/4100K	2	ELECTRONIC

LIGHTING FIXTURE AND LAMP TABLE

ROOM NO.	ROOM NAME	FIXTURE TYPE	NUMBER OF FIXTURE	LAMP TYPE	NO. OF LAMPS	BALLAST TYPE
		B3B	1	F32T8/4100K	2	ELECTRONIC
		X1	1	LED		NA
2AC5	CORRIDOR	B3	1	F32T8/4100K	2	ELECTRONIC
		B3B	1	F32T8/4100K	2	ELECTRONIC
		X1	1	LED		NA
2AS1	STAIRS	SCB	1	CF-TT32W/4100K	2	ELECTRONIC
2B01	OFFICE	B1	2	F32T8/4100K	2	ELECTRONIC
2B02	JAN. CL.	Q1	1	F32T8/4100K	1	ELECTRONIC
2B03	CONF./GROUP THERAPY	B1	4	F32T8/4100K	2	ELECTRONIC
2B04	PSYCH TEST	C1	2	F32T8/4100K	3	ELECTRONIC
2B05	F. TLT	B3	1	F32T8/4100K	2	ELECTRONIC
		E2	1	F32T8/4100K	2	ELECTRONIC
2B06	STAFF TOILET	B3	1	F32T8/4100K	2	ELECTRONIC
		E2	1	F32T8/4100K	2	ELECTRONIC
2B07	TECH. OFF.	B1	2	F32T8/4100K	2	ELECTRONIC
2B08	OFF. EXAM	B1	3	F32T8/4100K	2	ELECTRONIC
2B09	TECH. OFF.	B1	2	F32T8/4100K	2	ELECTRONIC
2B10	RECEPT	B1	3	F32T8/4100K	2	ELECTRONIC
		B1B	1	F32T8/4100K	2	ELECTRONIC
2B11	WAITING	SC	6	CF-TT32W/4100K	2	ELECTRONIC
2B12	COMM. RM	Q1	1	F32T8/4100K	1	ELECTRONIC
		Q1B	1	F32T8/4100K	1	ELECTRONIC
2B13	ELECTRICAL	Q1	1	F32T8/4100K	1	ELECTRONIC
		Q1B	1	F32T8/4100K	1	ELECTRONIC
2B14	RECS/FORMS STOR	B1	2	F32T8/4100K	2	ELECTRONIC
2B15	WAIT/ERGOM	C1	2	F32T8/4100K	3	ELECTRONIC
2B16	PH TECH	B1	2	F32T8/4100K	2	ELECTRONIC
2B17	CL. UTIL/KITCHENET	C1	1	F32T8/4100K	3	ELECTRONIC
2B18	PH TECH	B1	2	F32T8/4100K	2	ELECTRONIC
2B19	WATER LAB	B1	2	F32T8/4100K	2	ELECTRONIC
2B20	JAN. CL.	Q1	1	F32T8/4100K	1	ELECTRONIC
2B21	PH SUPER	B1	2	F32T8/4100K	2	ELECTRONIC
2B22	M. TOILET	B3	1	F32T8/4100K	2	ELECTRONIC
		E2	1	F32T8/4100K	2	ELECTRONIC
2B23	BEE TECH	B1	2	F32T8/4100K	2	ELECTRONIC
2B24	BEE TECH	B1	2	F32T8/4100K	2	ELECTRONIC
2B25	S. UTL. TRASH	B1	1	F32T8/4100K	2	ELECTRONIC
2BC1	CORRIDOR	SB	3	PL-C18/4100K	1	ELECTRONIC
		SBB	2	PL-C18/4100K	1	ELECTRONIC
		X1B	1	LED		NA
2BC2	CORRIDOR	B3	2	F32T8/4100K	2	ELECTRONIC
		B3	2	F32T8/4100K	2	ELECTRONIC
		X1	2	LED		NA
2BC3	CORRIDOR	B3	3	F32T8/4100K	2	ELECTRONIC
		B3	2	F32T8/4100K	2	ELECTRONIC
		X1	1	LED		NA
2BC4	CORRIDOR	B3	1	F32T8/4100K	2	ELECTRONIC

LIGHTING FIXTURE AND LAMP TABLE

ROOM NO.	ROOM NAME	FIXTURE TYPE	NUMBER OF FIXTURE	LAMP TYPE	NO. OF LAMPS	BALLAST TYPE
		B3	1	F32T8/4100K	2	ELECTRONIC
		X1	1	LED		NA
2BC5	CORRIDOR	B3	3	F32T8/4100K	2	ELECTRONIC
		B3	2	F32T8/4100K	2	ELECTRONIC
		X1	1	LED		NA
2BC6	CORRIDOR	B3	1	F32T8/4100K	2	ELECTRONIC
		B3	1	F32T8/4100K	2	ELECTRONIC
		X1	1	LED		NA
2BS2	STAIRS	E1	1	F32T8/4100K	2	ELECTRONIC
2C01	DTR SUPPORT	C1	2	F32T8/4100K	3	ELECTRONIC
2C02	GEN. DENT. DTR #6	A3	4	F32T8/5000K	4	ELECTRONIC
2C03	CONSULT	C1	4	F32T8/4100K	3	ELECTRONIC
		B3	1	F32T8/4100K	2	ELECTRONIC
2C04	GEN. DENT. DTR #7	A3	4	F32T8/5000K	4	ELECTRONIC
2C05	JAN. CL.	Q1	1	F32T8/4100K	1	ELECTRONIC
2C06	GEN. DENT. DTR #8	A3	4	F32T8/5000K	4	ELECTROMAG
2C07	M. STAFF LOCKER/TLT	B1	2	F32T8/4100K	2	ELECTRONIC
		B3	1	F32T8/4100K	2	ELECTRONIC
		SA	1	CF-DT13W/4100K	1	ELECTRONIC
		E2	1	F17T8/4100K	2	ELECTRONIC
2C08	F. STAFF LOCKER/TLT	B1	2	F32T8/4100K	2	ELECTRONIC
		B1B	1	F32T8/4100K	2	ELECTRONIC
		SA	1	CF-DT13W/4100K	1	ELECTRONIC
		E2	1	F17T8/4100K		ELECTRONIC
2C09	GEN. DENT. DTR #9	A3	4	F32T8/5000K	4	ELECTROMAG
2C10	DIPC DECON	A2	2	F32T8/4100K	4	ELECTRONIC
2C11	HK	C1	1	F32T8/4100K	3	ELECTRONIC
2C12	DIPC CLEAN	A2	3	F32T8/4100K	4	ELECTRONIC
2C13	TRASH	B1	1	F32T8/4100K	2	ELECTRONIC
2C14	GEN. DENT. DTR #10	A3	4	F32T8/5000K	4	ELECTRONIC
2C15	COMM. RM	Q4	1	F32T8/4100K	2	ELECTRONIC
		Q4B	1	F32T8/4100K	2	ELECTRONIC
2C16	CERAMIC	A28	2	F32T8/5000K	4	ELECTRONIC
2C17	PROSTH LAB	D18	6	F32T8/5000K	3	ELECTRONIC
2C18	ELECTRICAL	Q4	1	F32T8/4100K	2	ELECTRONIC
		Q4B	1	F32T8/4100K	2	ELECTRONIC
2C19	CENTRAL ISSUE	B1	3	F32T8/4100K	2	ELECTRONIC
2C22	LOUNGE	B1	2	F32T8/4100K	2	ELECTRONIC
2C23	MEN TLT	B1B	1	F32T8/4100K	2	ELECTRONIC
		E2	1	F17T8/4100K	2	ELECTRONIC
2C24	WOMANS TLT	B1B	1	F32T8/4100K	2	ELECTRONIC
		E2	1	F17T8/4100K	2	ELECTRONIC
2CC1	CORRIDOR	B3	2	F32T8/4100K	2	ELECTRONIC
		B3B	1	F32T8/4100K	2	ELECTRONIC
2CC2	CORRIDOR	B3	2	F32T8/4100K	2	ELECTRONIC
		B3B	1	F32T8/4100K	2	ELECTRONIC
2CC3	CORRIDOR	B3	2	F32T8/4100K	2	ELECTRONIC

LIGHTING FIXTURE AND LAMP TABLE

ROOM NO.	ROOM NAME	FIXTURE TYPE	NUMBER OF FIXTURE	LAMP TYPE	NO. OF LAMPS	BALLAST TYPE
		B3B	2	F32T8/4100K	2	ELECTRONIC
		X1	1	LED		NA
		X2	1	LED		NA
2CC4	CORRIDOR	B3	2	F32T8/4100K	2	ELECTRONIC
		X1	1	LED		NA
2CC5	CORRIDOR	B3	1	F32T8/4100K	2	ELECTRONIC
		B3B	1	F32T8/4100K	2	ELECTRONIC
2CS3	STAIRS	E1	1	F32T8/4100K	2	ELECTRONIC
2D01	PARTS STOR	B1	1	F32T8/4100K	2	ELECTRONIC
2D02	DATA/ARCHIVE STOR	B1	1	F32T8/4100K	2	ELECTRONIC
2D03	DIR INFO MGR	B1	2	F32T8/4100K	2	ELECTRONIC
2D04	SYS ANALYST	B1	2	F32T8/4100K	2	ELECTRONIC
		B1B	1	F32T8/4100K	2	ELECTRONIC
2D04A	COMPUTER RM	B1	6	F32T8/4100K	2	ELECTRONIC
2D05	MAIN MECH. RM	Q4	20	F32T8/4100K	2	ELECTRONIC
		Q4B	4	F32T8/4100K	2	ELECTRONIC
		X1B	1	LED		NA
2D06	COPY/FILE/MAIL BOX ARE	B1	2	F32T8/4100K	2	ELECTRONIC
2D07	SUPER	B1	2	F32T8/4100K	2	ELECTRONIC
2D08	QA/HRD DIRECTOR	B1	2	F32T8/4100K	2	ELECTRONIC
2D09	ADMIN. OFFICE	B1	2	F32T8/4100K	2	ELECTRONIC
2D10	SEC/WAIT	C1	2	F32T8/4100K	3	ELECTRONIC
		C1B	1	F32T8/4100K	3	ELECTRONIC
		SD	3	CF-QT26W4100K	2	ELECTRONIC
2D11	CMDR OFF	B1	2	F32T8/4100K	2	ELECTRONIC
		SE	4	CF-QT26W4100K	2	ELECTRONIC
2D12	VESTIBULE	SE	1	CF-QT26W4100K	2	ELECTRONIC
2D13	TOILET	B3	1	F32T8/4100K	2	ELECTRONIC
		E2	1	F17T8/4100K	2	ELECTRONIC
2D14	OPS SQUAD CWDR	B1	2	F32T8/4100K	2	ELECTRONIC
2D15	1st SGT	B1	2	F32T8/4100K	2	ELECTRONIC
2D16	RMO CMDR	B1	2	F32T8/4100K	2	ELECTRONIC
2D17	CREDENTIALS MGR	B1	2	F32T8/4100K	2	ELECTRONIC
2D18	TECH. OFF.	PI	6	F32T8/4100K	3	ELECTRONIC
		SB	7	CF-QT18W/4100K	1	ELECTRONIC
		SBB	5	CF-QT18W/4100K	1	ELECTRONIC
		SC	2	CF-TT32W/4100K	2	ELECTRONIC
		SCB	1	CF-TT32W/4100K	2	ELECTRONIC
2D19	READINESS NCOIC OFF	B1	2	F32T8/4100K	2	ELECTRONIC
2D20	CONF. ROOM	B1	5	F32T8/4100K	2	ELECTRONIC
		B1B	1	F32T8/4100K	2	ELECTRONIC
2D21	LIBRARY/CLASSROOM	B1	6	F32T8/4100K	2	ELECTRONIC
2DC1	CORRIDOR	B3	3	F32T8/4100K	2	ELECTRONIC
		B3B	1	F32T8/4100K	2	ELECTRONIC
		X1	1	LED		NA
2DC2	CORRIDOR	B3	3	F32T8/4100K	2	ELECTRONIC
		B3B	1	F32T8/4100K	2	ELECTRONIC

LIGHTING FIXTURE AND LAMP TABLE

ROOM NO.	ROOM NAME	FIXTURE TYPE	NUMBER OF FIXTURE	LAMP TYPE	NO. OF LAMPS	BALLAST TYPE
		X1	1	LED		NA
	BUILDING EXTERIOR	SD	1	CF-QT26W4100K	2	ELECTRONIC
		SDB	4	CF-QT26W4100K	2	ELECTRONIC
		MGB	2	100W/HALIDE	1	HID CCB
		N2	1	F32T8/4100K	2	ELECTRONIC
		HPS	3	150W/HPS	1	HID CCB
	AREA LIGHTING	HAJ1		400W/HPS	1	HID CCB
		HAJ2		400W/HPS	1	HID CCB
		HYF		70W/HPS	1	HID CCB

LIGHTING FIXTURE AND LAMP TABLE

	ABBREVIATIONS FOR FIXTURE TYPE	FIXTURE TOTALS
A2	Z	26
A2B	SAME AS A2 WITH EMERGENCY BATTERY PACK	5
A28	600mm x 4100mm FLUORESCENT TROFFER	5
A3	SAME AS A28 WITH EMERGENCY BATTERY PACK	40
B1	600mm x 4100mm TROFFER W/32 CELL, 78mm DEEP	248
B1B	SAME AS B1 WITH EMERGENCY BATTERY PACK	23
B1D	SAME AS B1 WITH DIMMING BALLAST	4
B18	SAME AS B1 WITH 85 COLOR RENDERING LAMPS	10
B18B	SAME AS B18 WITH EMERGENCY BATTERY PACK	2
B3	600mm x 600mm FLUORESCENT TROFFER (U SHAPED)	105
B3B	SAME AS B3 WITH EMERGENCY BATTERY PACK	43
B3D	SAME AS B3 WITH DIMMING BALLAST	6
B3BD	SAME AS B3D WITH EMERGENCY BATTERY PACK	2
C1	600mm x 4100mm (NORMAL) FLUORESCENT TROFFER	25
C1D	SAME AS C1 WITH DIMMING BALLAST	3
C1B	SAME AS C1 WITH EMERGENCY BATTERY PACK	2
C18	SAME AS C1 WITH 85 COLOR RENDERING LAMPS	37
C18B	SAME AS C18 WITH EMERGENCY BATTERY PACK	2
DM175	RECESSED METAL HALIDE UP LIGHT	4
D18	610mm x 4100mm RECESSES TROFFER	6
D18B	SAME AS D18 WITH EMERGENCY BATTERY PACK	
E1	4100mm SURFACE MOUNTED UP LIGHT	7
E2	610mm SURFACE MOUNTED DOWN LIGHT	22
HAJ1	SINGLE HEAD HIGH PRESSURE SODIUM POLE LIGHT	
HAJ2	SAME AS HAJ1 WITH TWO HEADS	
HYF	HIGH PRESSURE SODIUM SQUARE BOLLARD	
HPS	2286mm WALL MOUNTED HIGH PRESSURE SODIUM	
LV	RECESSED HALOGEN DOWN LIGHT	16
MGB	IN-GROUND METAL HALIDE	
M175	SURFACE MOUNTED METAL HALIDE	4
M250	SURFACE MOUNTED METAL HALIDE	4
M400	SURFACE MOUNTED METAL HALIDE	6
N2	244mm x 4100mm SURFACE MOUNT FLUORESCENT	
P1	LINEAR FLUORESCENT UP LIGHT	13
Q1	4100mm SINGLE LAMP STRIP W/WIRE GUARD	9
Q1B	SAME AS Q1 WITH EMERGENCY BATTERY PACK	2
Q4	4100mm TWO LAMP STRIP W/WIRE GUARD	37
Q4B	SAME AS Q4 WITH EMERGENCY BATTERY PACK	11
R1	305mm x 4100mm (NORMAL) FLUORESCENT TROFFER	4
S	RECESSED INCANDESCENT DOWN LIGHT	9
SA	152mm RECESSED FLUORESCENT SHOWER LIGHT	2
SB	102mm RECESSED FLUORESCENT DOWN LIGHT	40
SBB	SAME AS SB WITH EMERGENCY BATTERY PACK	12
SC	213mm RECESSED COMPACT FLUORESCENT DOWN LIGHT	20
SCB	SAME AS SC WITH EMERGENCY BATTERY PACK	3

LIGHTING FIXTURE AND LAMP TABLE

SD	213mm RECESSED COMPACT FLUORESCENT DOWN LIGHT		20
SDB	SAME AS SDB WITH EMERGENCY BATTERY PACK		7
SE	213mm RECESSED COMPACT FLUORESCENT DOWN LIGHT		5
T1	LINEAR FLUORESCENT WALL MOUNTED UP LIGHT		6
X1	SINGLE FACE CEILING MOUNTED LED EXIT LIGHT		42
X1B	BACK OR SIDE MOUNTED EXIT LIGHT WITH BATTERY PACK		2
X2	DOUBLE FACE CEILING MOUNTED EXIT FIXTURE		1
Y	SURFACE MOUNTED "X-RAY IN USE" FIXTURE		
Y1	RECESSED "DARKROOM IN USE" FIXTURE		1
Y2	CEILING MOUNTED DARKROOM SAFE FIXTURE		1
Z	ELEVATOR PIT WALL FIXTURE		1
	BALLAST DEFINITIONS		
HID CCB	HIGH INTENSITY DISCHARGE, CORE AND COIL BALLAST		
NA	NON-APPLICABLE		
ELE/DIM	ELECTRONIC BALLAST W/DIMMING		
ELETROMAG	ELECTROMAGNETIC BALLAST		