Work Completion Report for Solar Power Plant

Sr.No	Component	Observation
1	Name	
2	Consumer number	
3	Site/Location With Complete Address	
4	Category: Govt/Private Sector	Private
5	Total Capacity (KWP)	
6	Sanctioned Capacity of solar PV system (KW)	
	Installed Capacity of solar PV system (KW)	
7	Make of Module	
	Wattage per module	
	No. of Module	
	ALMM Model Number	
8	Make & Model Number of Inverter	
	Rating	5 star
	Type of charge controller/ MPPT	1mppt
	Capacity of Inverter	
	HPD	N.A.
	Year of manufacturing	2026
9	No. of Separate Earthings with Earth Resistance	3
	It is certified that the Earth Resistance measure in presence of Licensed Electrical Contractor/Supervisor and found in order i.e. < 5 Ohms as per MNRE OM Dtd. 07.06.24 for CFA Component.	Yes
10	Lightening Arrester	Yes

This is to Certified above Installed Solar PV System is working properly with electrical safety & Islanding switch in case of any presence of backup inverter an arrangement should be made in such way the backup inverter supply should never be synchronized with solar inverter to avoid any electrical accident due to back feeding. We will be held responsible for non-working of islanding mechanism and back feed to the de-energized grid.

We, & , bearing Consumer Number , have obtained requisite permissions from the concerned authority. If in the future, by virtue of any means due to collapsing or damage to the installed solar power plant, MSEDCL will not be held responsible for any loss to property or human life, if any.

Signature

Signature

Guarantee Certificate Undertaking to be submitted by VENDOR

The undersigned will provide the services to the consumers for repairs/maintenance of the RTS plant free of cost for 5 years of the comprehensive Maintenance Contract (CMC) period from the date of commissioning of the plant. Non-performing/under-performing system component will be replaced/repaired free of cost in the CMC period.

Vendor Signature

Consumer Number:
Aadhar Number: