

=====

DEFAULT AI

=====

:TYPE ANALOG_INPUT
:SERVICE YES
:SCANT 1s
:CONV_PAR 0
:IMPL 1

DEFAULT AIS

=====

:UNIT %
:RANGEMAX 100.000
:RANGEMIN -100.000
:DEC 2
:ERR_TR 0
:CLASS 0
:DESCR

*** END OF DEFAULTS ***

AI1.1

:NAME "BOILER_PRESS_TR_01"
:DESCR "Boiler Steam Drum Pressure"
:UNIT "BAR"
:RANGEMAX 150.000
:RANGEMIN 0.000
:ACTUAL 84.5

AI1.2

:NAME "FEEDWATER_FLOW_01"
:DESCR "Boiler Feedwater Inlet Flow Rate"
:UNIT "M3/H"
:RANGEMAX 500.000
:RANGEMIN 0.000
:ACTUAL 320.0

=====

DEFAULT AO

=====

:TYPE OUTPUT_4_20MA
:SERVICE YES
:CONV_PAR 1

DEFAULT AOS

=====

:UNIT %
:RANGEMAX 100.000
:RANGEMIN 0.000
:DEC 2

*** END OF DEFAULTS ***

A02.1

:NAME "STEAM_VALVE_OUT_01"
:DESCR "Main Steam Control Valve Position Demand"
:RANGEMAX 100.0
:ACTUAL 62.4

A02.2

:NAME "FEEDWATER_PUMP_SPEED"
:DESCR "Feedwater VFD Speed Setpoint Output"
:UNIT "RPM"
:RANGEMAX 3000.0
:ACTUAL 2450.0

=====

DEFAULT PIDCON

=====

:GAIN 1.0
:TI 30.0
:TD 0.0
:SP 50.0
:MODE AUTO
:ACT 1
:DEC 2

*** END OF DEFAULTS ***

PIDCON1

:NAME "DRUM_PRESS_CTRL"
:DESCR "Steam Drum Pressure PID Controller"
:GAIN 2.5
:TI 45.0
:SP 85.0
:PV 84.5
:OUT 62.4

=====

DEFAULT MOTCON

=====

:TRIP FALSE
:RUNNING FALSE
:CURRENT 0.0
:COMMAND STOP
:UNIT A

*** END OF DEFAULTS ***

MOTCON1

:NAME "MAIN_PUMP_M01"
:DESCR "High Pressure Boiler Feed Pump Motor"
:RUNNING TRUE
:CURRENT 142.5
:COMMAND "START"

=====

DEFAULT VALVECON

=====

:OPEN FALSE
:CLOSED TRUE
:FAULT FALSE
:POSITION 0.0

*** END OF DEFAULTS ***

VALVECON1

:NAME "EMERGENCY_VENT_V01"
:DESCR "Emergency Safety Vent Valve"
:OPEN TRUE
:CLOSED FALSE
:POSITION 100.0

DS1

:NAME "PLANT_STATUS_FLAG"
:DESCR "Overall Plant Operational State"
:VALUE "NORMAL_OPERATION"

DAT1

:NAME "CYCLE_TIME_MS"
:DESCR "Controller Task Cycle Duration"
:VALUE 50